

Solicitation No. 36C26218Q9792

RFI Questions and Answers #1

Services for Automatic Transfer Switches and Switch Gear Maintenance at VA Greater Los Angeles Healthcare System

RFI #1 -Please confirm if all the units that are listed on the solicitation are all ATS. Job walk shows all units were ATS.

Government Response to RFI Question #1 – VA Greater Los Angeles has 2 switch gear at 4160 volts. The rest are all ATS. They are described in the Statement of Work.