



GENERAL NOTES

1. PROVIDE WIRE MESH OVER RETURN AIR OPENING OF ALL FAN COIL UNITS.

DRAWING NOTES

- | | |
|---------------------------|---------------------------------------|
| 1. 48022 RA TO H-AHU-14 | 12. 30X14 EA TO H-KEF-2 |
| 2. 42024 SA FROM H-AHU-14 | 13. 30X30 EA TO H-KEF-4 |
| 3. 30X18 EA TO H-EP-14 | 14. 12X10 EA TO H-KEF-7 |
| 4. 24X34 SA FROM H-AHU-28 | 15. 12X12 EA TO H-KEF-6 |
| 5. 48026 RA TO H-AHU-7 | 16. 44X40 RA TO H-AHU-15 |
| 6. 30X36 RA TO H-AHU-6 | 17. 30X30 EA TO H-KEF-3 |
| 7. 30X50 SA FROM H-AHU-6 | 18. 14X14 EA TO H-KEF-5 |
| 8. 30X28 EA TO H-KEF-7 | 19. 42X34 SA FROM H-AHU-15 |
| 9. 30X28 EA TO H-KEF-7 | 20. 40X24 RA TO H-AHU-28 |
| 10. 30X40 SA FROM H-AHU-7 | 21. 20X18 EA TO H-EP-15 |
| 11. 38X16 EA TO H-KEF-1 | 22. PROVIDE 2 HR FIRE RATED DUCT WRAP |



KEY PLAN
AREA D, ZONE 2

BUILDING IS FULLY SPRINKLERED

No.	Description	Date	CONSULTANTS:	Professional Seals:	ARCHITECT/ENGINEERS:	Drawing Title	Project Title	Project Number	Office of Facilities Management
1	CPR 034	02/23/2011				HOSPITAL/CLINIC	A NEW HOSPITAL FOR	675-950	
2	CPR 066	04/29/2011				LEVEL 3, AREA D, ZONE 2	VAMC ORLANDO, FLORIDA	01 AND 02	
3	CPR 067	05/09/2011				INTERSTITIAL DUCTWORK PLAN			
4	CPR 229	02/27/2012				Approved: Project Director	Location	H-MH1.3ND2	
5	CPR 270	04/18/2012					Orlando, Florida		
							Date	04 JUNE, 2010	
							Checked	POJ	
							Drawn	EB / RLF	
								Dep. 2339 of 4322	