

REQUEST FOR INFORMATION (RFI)
VA-251-12-B-0085

PROJECT NUMBER:	515-304	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.	
PROJECT TITLE:	Ambulatory Care Expansion B2		
PROJECT LOCATION:	Department of Veterans Affairs Battle Creek VA Medical Center 5500 Armstrong Road Battle Creek, MI 49037		
SUBMITTED BY:	N/A	City/State:	N/A
PHONE NO.:	N/A		

TO:

Sonny Earls, Contract Specialist
Department of Veterans Affairs
Aleda E. Lutz VA Medical Center
1500 Weiss St.
Saginaw, MI 48602

RFI NO.:	DATE:	SPEC/DWG. REFERENCE:
REPLY NEEDED BY:		

INFORMATION NEEDED:

I am inquiring about the PACS system for this project. The specifications for this project refer to a Hirsch Physical Access Control system, however there doesn't appear to be anything plotted on the prints as to exact locations. I'm referring to the sheets ET110 and ET120. Can you please clarify that this system either has a PACS system or not and where would the layout be found.

REPLY:

Although there was a PACS Specification included in the specification, currently there are no Access controls required in the project.

There are no new IT closets in the project.
Exterior door card readers are indicated as "future" on the ET110.

REPLY FROM:	DATE:
ATTACHMENTS: None	COPY TO: www.fbo.gov