



- SECOND FLOOR FIRE ALARM DEMO NOTES:**
- EXISTING FATC TO REMAIN. RELABEL PER FIRE ALARM PLAN.
 - EXISTING ADDRESSABLE SMOKE DETECTOR AT EXISTING ELEVATOR LOBBY, PROGRAMMED FOR ELEVATOR RECALL FUNCTION, TO REMAIN.
 - EXISTING ADDRESSABLE MANUAL PULL STATION TO REMAIN. EXISTING PULL STATION IS MOUNTED APPROXIMATELY 50" FROM CENTER OF BOX ABOVE FINISHED FLOOR. PROVIDE NEW FLUSH OUTLET WITH NEW CONDUIT AND WIRING IN WALL TO RELOCATE EXISTING PULL STATION TO 45" FROM CENTER OF BOX ABOVE FINISHED FLOOR.
 - REMOVE EXISTING MANUAL PULL STATION AND RELATED CONDUITS AND WIRING.
 - EXISTING ADDRESSABLE DUCT SMOKE DETECTOR TO REMAIN.
 - EXISTING HORN/STROBE TO BE REMOVED OR REPLACED. REMOVE EXISTING DEVICE, CONDUITS AND WIRING. BLANK OFF OUTLET.
 - EXISTING FIRE ALARM CONDUIT WITH ONE "A" CABLE + 2#12 (24VDC) FROM EXISTING FIRE ALARM DEVICES IN AUDITORIUM FIRST FLOOR, TO REMAIN.
 - EXISTING FIRE ALARM CONDUIT WITH ONE "A" CABLE, 4#12 (2 NAC) + 2#12 (24VDC) FROM EXISTING FIRE ALARM DEVICES IN FIRST FLOOR EQUIPMENT ROOM, TO REMAIN. PROVIDE NEW SUPPORT PER CODE FOR EXISTING CONDUIT.
 - EXISTING FIRE ALARM CONDUIT WITH ONE "A" CABLE, 2#12 (NAC) + 2#12 (24VDC) TO EXISTING FATC #2 ON THIRD FLOOR, TO REMAIN. PROVIDE NEW SUPPORT PER CODE FOR EXISTING CONDUIT.
 - EXISTING FIRE ALARM CONDUIT AND WIRING FROM EXISTING FATC #4 IN FIRST FLOOR. EXISTING WIRING TO BE REPLACED. REMOVE EXISTING WIRING. PROVIDE NEW SUPPORT PER CODE FOR EXISTING CONDUIT.
 - EXISTING FIRE ALARM CONDUIT AND WIRING TO EXISTING FATC #6 ON THIRD FLOOR. EXISTING WIRING TO BE REPLACED. REMOVE EXISTING WIRING. PROVIDE NEW SUPPORT PER CODE FOR EXISTING CONDUIT.
 - EXISTING FIRE ALARM CONDUIT WITH ONE "A" CABLE + 2#12 (24VDC), TO REMAIN.
 - REMOVE EXISTING FIRE ALARM CONDUITS AND WIRING.

- GENERAL FIRE ALARM SYSTEM NOTES:**
- EXISTING BLDG CURRENTLY HAS A MANUAL FIRE ALARM SYSTEM. SCOPE OF FIRE ALARM WORK IS TO EXTEND THE EXISTING MANUAL FIRE ALARM PER CURRENT NFPA 101 AND ADA REQUIREMENT.
 - EXISTING FIRE ALARM SYSTEM CONSISTS OF A SIMPLEX #4100 ADDRESSABLE FIRE ALARM CONTROL PANEL WITH SIMPLEX ADDRESSABLE INITIATION DEVICES AND NAC DEVICES. ALL NEW DEVICES SHALL BE AS MANUFACTURED BY SIMPLEX, COMPATIBLE WITH THE EXISTING #4100 FIRE ALARM SYSTEM.
 - FIRE ALARM SYSTEM SUPPLIER SHALL ASSIST ELECTRICAL CONTRACTOR IN THE DEMO FIRE ALARM WORK AND NEW FIRE ALARM WORK TO ACCOMMODATE PHASING OF THE PROJECT.
 - ALL PROGRAMMING AND TESTING AS REQUIRED FOR A COMPLETE OPERABLE MANUAL FIRE ALARM SYSTEM SHALL BE DONE BY EXISTING FIRE ALARM SYSTEM SUPPLIER AND ALL COST SHALL BE INCLUDED IN THE CONTRACT.
 - CONTRACTOR SHALL PROVIDE NEW SUPPORT PER CODE FOR ALL EXISTING FIRE ALARM CONDUITS THAT REMAIN, IN ATTIC OR SURFACE MOUNTED ON CEILINGS AND WALLS.

1 DEMOLITION SECOND FLOOR FIRE ALARM PLAN
1/8" = 1'-0"

CONSULTANTS:

LP Consulting Engineers, Inc.
895 W. Ashlan Ave, Suite 101 Clovis, CA 93612
p 559-432-1249 • f 559-432-1628
www.lpeengineers.com
Job #: 10-1098

ARCHITECT/ENGINEERS:

HMC Architects
1827 E. Fir Avenue, Studio 103 / Fresno, CA 93720
T 559 322 2444 / www.hmcarchitects.com

Drawing Title
**DEMOLITION SECOND FLOOR
FIRE ALARM PLAN**

Approved: Project Director

Project Title
**BUILDING 24
SEISMIC CORRECTION
AND ADDITION**

Location
VAMC FRESNO, CA

Date
January 31, 2012

Checked
PK

Drawn
PK/LS

Project Number
570-215

Building Number
24

Drawing Number
ED203
Dwg. 161 of 180

Office of
Construction
and Facilities
Management

