



- FIRST FLOOR FIRE ALARM PLAN NOTES:**
- 1 EXISTING FACP TO REMAIN.
 - 2 EXISTING ABANDONED FACP, BEING USED AS FATC, TO REMAIN.
 - 3 EXISTING FIRE ALARM ANNUNCIATOR TO REMAIN.
 - 4 TYPICAL: REFER TO SHEET ES001 FOR FIRE ALARM LEGEND.
 - 5 EXISTING FIRE ALARM DEVICES TO REMAIN.
 - 6 PROVIDE NEW ADDRESSABLE INITIATION DEVICES.
 - 7 TYPICAL: PROVIDE NEW NAC DEVICE, ON WALL UNLESS OTHERWISE NOTED.
 - 8 TYPICAL: "C" DENOTES CEILING MOUNTED NAC DEVICE.
 - 9 3/4" C WITH ONE "A" ADDRESSABLE DEVICE CABLE.
 - 10 3/4" C WITH 2#12.
 - 11 3/4" C WITH 4#12.
 - 12 1" C WITH ONE "A" ADDRESSABLE DEVICE CABLE, + 2#12.
 - 13 EXISTING FIRE ALARM CONDUIT TO EXISTING FACP #1A. REPLACE EXISTING WIRING WITH ONE "A" ADDRESSABLE DEVICE CABLE, + 2#12.

- GENERAL FIRE ALARM SYSTEM NOTES:**
1. EXISTING BLDG CURRENTLY HAS A MANUAL FIRE ALARM SYSTEM. SCOPE OF FIRE ALARM WORK IS TO EXTEND THE EXISTING MANUAL FIRE ALARM PER CURRENT NFPA 101 AND ADA REQUIREMENT.
 2. EXISTING FIRE ALARM SYSTEM CONSISTS OF A SIMPLEX #4100 ADDRESSABLE FIRE ALARM CONTROL PANEL WITH SIMPLEX ADDRESSABLE INITIATION DEVICES AND NAC DEVICES. ALL NEW DEVICES SHALL BE AS MANUFACTURED BY SIMPLEX, COMPATIBLE WITH THE EXISTING #4100 FIRE ALARM SYSTEM.
 3. FIRE ALARM SYSTEM SUPPLIER SHALL ASSIST ELECTRICAL CONTRACTOR IN THE DEMO FIRE ALARM WORK AND NEW FIRE ALARM WORK TO ACCOMMODATE PHASING OF THE PROJECT.
 4. ALL PROGRAMMING AND TESTING AS REQUIRED FOR A COMPLETE OPERABLE MANUAL FIRE ALARM SYSTEM SHALL BE DONE BY EXISTING FIRE ALARM SYSTEM SUPPLIER AND ALL COST SHALL BE INCLUDED IN THE CONTRACT.
 5. CONTRACTOR SHALL PROVIDE NEW SUPPORT PER CODE FOR ALL EXISTING FIRE ALARM CONDUITS THAT REMAIN, IN ATTIC OR SURFACE MOUNTED ON CEILINGS AND WALLS.

1 FIRST FLOOR FIRE ALARM PLAN
1/8" = 1'-0"

2 FIRST FLOOR FIRE ALARM PLAN - DEDUCTIVE ALTERNATE 1
1/8" = 1'-0"

A three inches = one foot
 B one and one half inches = one foot
 C one inch = one foot
 D three quarters inch = one foot
 E one half inch = one foot
 F three eighths inch = one foot
 G one quarter inch = one foot
 H one eighth inch = one foot

<p>Revisions</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 5%;">No.</th> <th style="width: 15%;">Description</th> <th style="width: 10%;">Date</th> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </table>	No.	Description	Date				<p>CONSULTANTS:</p> <div style="display: flex; align-items: center;"> <p>LP Consulting Engineers, Inc. 886 W. Ashlan Ave, Suite 101 Clovis, CA 93612 p 559-432-1249 - f 559-432-1626 www.lpeengineers.com Job #: 10-1098</p> </div>	<p>ARCHITECT/ENGINEERS:</p> <div style="display: flex; align-items: center;"> <p>HMC Architects 1827 E. Fir Avenue, Studio 103 / Fresno, CA 93720 T 559 322 2444 / www.hmcarchitects.com</p> </div>	<p>Drawing Title FIRST FLOOR FIRE ALARM PLAN</p> <p>Approved Project Director</p>	<p>Project Title BUILDING 24 SEISMIC CORRECTION AND ADDITION</p> <p>Location VAMC FRESNO, CA</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th>Date</th> <th>Checked</th> <th>Drawn</th> </tr> <tr> <td>January 31, 2012</td> <td>PK</td> <td>PK/LS</td> </tr> </table>	Date	Checked	Drawn	January 31, 2012	PK	PK/LS	<p>Project Number 570-215</p> <p>Building Number 24</p> <p>Drawing Number ES103 Dwg 169 of 180</p>	<p>Office of Construction and Facilities Management</p> <p>Department of Veterans Affairs</p>
No.	Description	Date																
Date	Checked	Drawn																
January 31, 2012	PK	PK/LS																