



- SECOND FLOOR LIGHTING PLAN NOTES:**
- ① TYPICAL: PROVIDE NEW WALL MOUNTED DUAL TECHNOLOGY DUAL SWITCHING OCCUPANCY SENSOR WITH NEW WIRING TO CONTROL LIGHTS IN ROOM. SEE SPEC #260923.
 - ② TYPICAL: PROVIDE NEW CEILING MOUNTED DUAL TECHNOLOGY OCCUPANCY SENSOR WITH NEW WIRING TO CONTROL LIGHTS IN ROOM. WALL SWITCHES SHOWN IN ROOM SHALL BE CONNECTED ON DOWNSTREAM OF OCCUPANCY SENSOR CONTROL FOR LOCAL SWITCHING. SEE SPEC #260923.
 - ③ TYPICAL: DENOTES FIXTURE TYPE. SEE SCHEDULE ON ES005.

① SECOND FLOOR LIGHTING PLAN
1/8" = 1'-0"

② SECOND FLOOR LIGHTING PLAN - DEDUCTIVE ALTERNATE 1
1/8" = 1'-0"

CONSULTANTS: LP Consulting Engineers, Inc. 895 W. Ashlan Ave., Suite 101, Clovis, CA 93612 p 559-432-1249 • f 559-432-1625 www.lpeengineers.com Job #: 10-1095		ARCHITECT/ENGINEERS: HMC Architects 1827 E. Fir Avenue, Studio 103 / Fresno, CA 93720 T 559 322 2444 / www.hmcarchitects.com		Drawing Title SECOND FLOOR LIGHTING PLAN		Project Title BUILDING 24 SEISMIC CORRECTION AND ADDITION		Project Number 570-215 Building Number 24		Office of Construction and Facilities Management 	
Revisions Date				Approved Project Director		Location VAMC FRESNO, CA		Drawing Number ES201 Dwg 171 of 180			
						Date January 31, 2012		Checked PK		Drawn PK/LS	

VA FORM 08-6231