



- SECOND FLOOR HVAC ELECTRICAL PLAN NOTES:**
- ① NEW VAV BOX TO REPLACE EXISTING. RECONNECT EXISTING CONTROL WIRING.
 - ② NEW AIR HANDLER MOTORS TO REPLACE EXISTING. DISCONNECT EXISTING ELECTRICAL. CONNECT NEW MOTORS TO EXISTING POWER WIRING.
 - ③ TYPICAL: DENOTE MECHANICAL UNIT IDENTIFICATION. REFER TO SCHEDULES ON SHEETS MH600 & MH601.

① SECOND FLOOR HVAC ELECTRICAL PLAN
1/8" = 1'-0"

② SECOND FLOOR HVAC ELECTRICAL PLAN - DEDUCTIVE ALTERNATE 1
1/8" = 1'-0"

one eighth inch = one foot
one quarter inch = one foot
three eighths inch = one foot
one half inch = one foot
three quarters inch = one foot
one inch = one foot
one and one half inches = one foot
two inches = one foot
three inches = one foot

CONSULTANTS: LP Consulting Engineers, Inc. 895 W. Ashlan Ave, Suite 101 Clovis, CA 93612 p 559-432-1240 • f 559-432-1625 www.lpeengineers.com Job #: 10-1096		ARCHITECT/ENGINEERS: HMC Architects 1827 E. Fir Avenue, Studio 103 / Fresno, CA 93720 T 559 322 2444 / www.hmcarchitects.com		Drawing Title SECOND FLOOR HVAC ELECTRICAL PLAN Approved Project Director		Project Title BUILDING 24 SEISMIC CORRECTION AND ADDITION Location VAMC FRESNO, CA		Project Number 570-215 Building Number 24 Drawing Number ES204 Dwg. 174 of 180		Office of Construction and Facilities Management 	
Revisions:		Date:		Date: January 31, 2012		Checked: PK		Drawn: PK/LS			