



Request for Information (RFI) Log

Move MRI Trailer

Construction

Project: 600-18-103

21 August 2018

Long Beach, California VA Health Care System (600)

RFI Number	Date	Question	Answer
001	8/20/2018	Will the VA set up a conference call for contractors to participate in the public bid opening for those who emailed bids sent from outside of Phoenix?	The VA does not intend to host a teleconference as part of the public bid opening.
002	8/13/2018	<ol style="list-style-type: none">1. Can the 200 amp plug be reused or does it have to be replaced?2. Can chain-link fabric be reused on new fence around MRI trailer?	<ol style="list-style-type: none">1. It depends on how much time it will take to relocate the plug, disconnect switch, and re-routing the power and data lines.2. Yes, the chain link fabric can be re-sued.