

- Line 3 – you need single face plate that have 2 ports: 1 for RJ45 jack (but you do not want RJ45 jack installed) and it also says “with F/ ¼” with pigtail” – what is “with F/ ¼” with pigtail”? Do you need that face plate to have coax pass thru connector RG6 installed in 2nd port and short less than 10” RG6 pigtail cable connected to back of coax connector? Am I right? Or can you email picture or PDF spec?

RIGHT NOW WE ARE TRANSITIONING OUR SIGNAL PROVIDOR. CURRENTLY, WE ARE PUSHING SIGNAL OVER A TYPICAL CO-AXIAL CABLE; HOWEVER, WE ANTICIPATE SWITCHING TO A SIGNAL THAT WILL UTILIZE THE CAT6 CABLE SOON. WE DON'T HAVE A STANDARD JACK AT THIS POINT SO PLEASE SUBMIT OPTIONS THAT YOU ARE ABLE TO PROVIDE...

- Line 6 - this is Cat6 copper patch cord, 3ft, black, shielded, correct? Or is it Cat6A?

Yes, CAT6

- Regarding installation: we need to install TV mounts, mount TVs and what do we do with lines 3-7? Is someone installing other TV cabling from comm room to each TV location?

Contractor building the facility will do the connection from the IT closet to each tv location.

- Do we need to wire bed to TVs? –

No

- Do we only install TVs, wall mounts and other parts show in table?

Yes install all items

- Do we need to provide a remote control with each TV since TVs do not come with remote. See attached page 3 under OPTIONAL ACCESSORY REMOTES. Let me know what remotes you need if any.

NO the pillow speaker would be used

- In case we do need to provide remotes or remotes with speaker built-in as shown on page 3 in attached, can we get this info too?
- The nurse call feature is on the pillow speaker remote. It is commonly used in hospitals. It is the remote that has the speaker on it. I would need more information to quote pricing on the pillow speaker. –

The TV which is the basis of design has the pillow speaker follow those guidelines.

- Do you have a part # of the pillow speaker they currently use?

SEE ATTACHED. ADVISE IF ADDITIONAL INFORMATION IS REQUIRED.

- Or can you get us a picture of the front/back of the current pillow speaker? ***SEE ATTACHED. ADVISE IF ADDITIONAL INFORMATION IS REQUIRED.***

- If you can't provide that info, to provide pricing, we will need more information...

- Can you let us know what nurse call system is used at this facility?
HILL-ROM
- Plug style?
SEE ATTACHED. ADVISE IF ADDITIONAL INFORMATION IS REQUIRED.
- Auxiliary functions (if any)? Light buttons? Shade buttons? –
NO
- Any special features?
- The attached sheet can help guide you with the info we would need.