

~	
Q	
J	

9
MEMBRANE ROOFING ON 2" RIGID INSULATION OVER 5/8" ROOF SHEATHING WITH MIN. 1/4" SLOPE
MTL. EDGE FLASHING
8", 18GA MTL JOIST (800S162-43) AT EACH STUD. SLOPED STRUCT. FOR ROOF SLOPE 1/4" MIN.
8", 18GA TRACK, #12 TEK SCREW @ EACH JOIST 6", 18GA TRACK, TYP.
3 5/8", 18GA (362S162-43) MTL. STUD @ 16"O.C. TRIM FLANGES @ VERT STUDS AND JOIST. (IF NECESSARY)
(4) #12 TEK SCREWS EA END, TYP. 6", 16GA (600S250-54) MTL STUD @ 16" O.C. INSTALL BRIDGING @ 6'-0" O.C. MAX. TYP.
ACOUSTICAL CEILING TILE SEE PROJECT MANUAL
<ul> <li>T1-11 PLYWOOD SIDING ON BUILDING PAPER ON 5/8" EXT. SHEATHING WITH R 13 FIBERGLASS INSULATION AND 5/8" WALLBOARD</li> </ul>
— WD. WINDOW SILL PAINTED
<ul> <li>— 6", 18GA TRACK AT HEAD &amp; SILL, CLIP FLANGE &amp; BEND WEB TO CONNECT TO JAMB STUD</li> </ul>
<ul> <li>— 1 1/2" DIA. STAINLESS STL HANDRAIL</li> </ul>
VCT FLOORING ON 2 LAYERS OF 3/4" SUB FLOOR
<ul> <li>8", 18GA MTL JOIST (800S162-43)</li> <li>@ EA MTL STUD</li> <li>4" VINYL BASE</li> </ul>
(4) #12 TEK SCREWS EA END OF JOIST.
BENT PL 12GA 4"X2"X4" LONG @ EA STUD. CONNECT TO STUD W/ (4) #12 TEK SCREWS, TYP. — CONT. #4 BAR, TYP.
— 1/2" DIA, 6" LONG SIMPSON TITEN HD
@ EA STUD, TYP. — KEEP FINISH GRADE 6" BELOW FINISH FLOOR ELEVATION