




LEGEND	
	HORIZONTAL THERMAL SYSTEM INSULATION (TSI) ON PIPING (M 1 OR M 2, BOTH BACK)
	VERTICAL TSI (M 1 OR M 2, BOTH BACK)
	MATTED JOINT FITTINGS (MJFS) ON THERMAL SYSTEM INSULATION (TSI)
	FREE STANDING MAF
	VERTICAL TSI WITH MAF
	HORIZONTAL CONFLUENCE MAF
	VERTICAL/HORIZONTAL CONFLUENCE MAF
NOTES	
A. LOCATIONS ARE APPROXIMATE.	
B. NO FRIABLE ASBESTOS AND PIPE CHANGES WERE OBSERVABLE.	
C. FRIABLE ASBESTOS INSULATION WAS OBSERVED IN SOME AREAS BUT IS NOT ILLUSTRATED HERE.	



Confirmed Friable Asbestos-Containing Materials, Thermal Systems Insulation Locations  
VA Hospital - Building 1, First Floor  
Miles City, Montana



INDUSTRIAL HYGIENE  
& ENVIRONMENTAL

GREAT FALLS, MT  
(406)452-3321  
Fax (406)454-1873

DRAWN BY: CJB  
CHECKED BY: KC  
DATE: 03/21/2011  
CTA #: GEHENY10059  
CAD FILE: F1-5  
DIR: GEHENY10059

SHEET  
Figure 1-5

1 CONFIRMED FRIABLE ACM TSI LOCATIONS  
F1-5 BUILDING 1 - 1ST FLOOR  
NOT TO SCALE