






















PLUMBING FIELD STUDY KEY SYMBOLS	
<p>TYPE A – PIPE LENGTH GREATER THAN TWICE THE DIAMETER OF THE PIPE SIZE TERMINATING AT CAP, VALVE, OR FITTING.</p> <p>TYPE B – PIPE LENGTH GREATER THAN TWICE THE DIAMETER OF THE PIPES TERMINATING AT AN INFREQUENTLY USED PLUMBING FITTING.</p> <p>TYPE C – PIPE LENGTH GREATER THAN 25 FEET TERMINATING AT A FREQUENTLY USED PLUMBING FITTING.</p>	
	DEAD LEG TAG
	MIXING VALVE TAG
	REMEDATE DEAD LEG
	NON-INSULATED PIPE REFER TO SCHEDULE

[illegible]

100% WORKING DRAWINGS SUBMISSION