



DAILY SITE REPORT

PROJECT NAME : Salisbury National Cemetery	PROJECT # : 120280.000
CLIENT : Daniels Building Company	DATE : 2/11/12
CONTRACTOR : Daniels Building Company	REPORT # : 12042.1
CESI REP : L Parks	WEATHER : Cloudy

A CESI Technician was on site to perform nuclear density tests on material placed for the VAMC stockpile. A total of six nuclear density tests were performed. Results indicate that the compaction was in compliance with project requirements at all but one of the locations and elevations tested.