



DAILY SITE REPORT

PROJECT NAME : Salisbury National Cemetery	PROJECT # : 120280.000
CLIENT : Daniels Building Company	DATE : 2/10/12
CONTRACTOR : Daniels Building Company	REPORT # : 12041.1
CESI REP : L Parks	WEATHER : Cloudy

A CESI Technician was on site to perform field density tests on material placed for the on-site stockpile and the VAMC stockpile. A total of ten field density tests were performed. Results indicate that the compaction was in compliance with project requirements at all but one of the locations and elevations tested. Failing test will be dried, recompact and retested prior to further fill placement.