FIELD DENSITY TEST REPORT

PROJECT NAME:	Salisbury National Cemetery CMT		PROJECT NO.: 120208.000
CLIENT:	Daniels Building Company		DATE: 02/03/12
REPORT NO.:	12034.1A	TECHNICIAN: L Parks	WEATHER: Clear

Test No.	Dry Density (pcf)	Moisture Content	Percent Density	Percent Density Required	Proctor No.	Depth Below Subgrade	Location
1	102.7	17.4%	100	95	1pt/Q	-6'	VAMC - 48' NE from culvert transition box
2	102.1	18.7%	100	95	1pt/Q	-5'	VAMC - 88' NE from culvert transition box

Proctor Information

Proctor No.	MDD	OMC
1pt/Q	102.4	20.3%

Tests were performed in accordance with ASTM D 2937 and referenced to the Standard Proctor (ASTM D 698)

Notes: MDD = Maximum Dry Density OMC = Optimum Moisture Content