FIELD DENSITY TEST REPORT

PROJECT NAME:	Salisbury National Cemetery CMT		PROJECT NO.: 120208.000
CLIENT:	Daniels Building Company		DATE: 02/15/12
REPORT NO.:	12046.1A	TECHNICIAN: L Parks	WEATHER: Clear

Test No.	Dry Density (pcf)	Moisture Content	Percent Density	Percent Density Required	Proctor No.	Depth Below Subgrade	Location
1	106.2	16.4%	97	95	1pt/N	-5'	VAMC - @ transition box
2	97.7	24.0%	98	95	1	-0'	VAMC - 30' S, 12' W of SW corner of BLDG 15

Proctor Information

Proctor No.	MDD	OMC
1pt/N	109.6	16.4%
1	100.0	23.0%

Tests were performed in accordance with ASTM D 2937 and referenced to the Standard Proctor (ASTM D 698)

Notes: MDD = Maximum Dry Density OMC = Optimum Moisture Content