

Section 1: Contractor Questions with Answers

Q1. Does the Government want to replace battery system for the following items on Base year October 2018 and Option 3 October 2021.

- a. Qty. 2, 50KVA at 120/208V UPS Qty 3 as of 9-11-2018 (UPS-IRM-A, UPS-19 MICU, UPS-OR)
- b. Qty. 1, 100KVA at 120/208V UPS Qty 1 as of 9-11-2018 (UPS-IRM-B)
- c. Qty. 1, 48 VOLT DIRECT CURRENT SYSTEM Qty 1 as of 9-11-2018
- d. Qty. 1, 125 VOLT BATTERY SYSTEM Qty 1 as of 9-11-2018

Q2. Does the Government not want to replace battery system for the following items?

- a. 48 VOLT DIRECT CURRENT SYSTEM No battery Replacement
- b. 125 VOLT BATTERY SYSTEM No battery Replacement

Q3. The request for semi-annual Maintenon, but no Battery and capacitor replacement for above two items? Correct