

VA LEAVENWORTH DRAWING INDEX

DRAWING NO.	DESCRIPTION	TRANSFORMER NO.	BLDG/S SERVED
E-00A	INDEX TO DRAWINGS	-	-
E-00B	SITE PLAN	-	-
E-00C	SITE PLAN	-	-
E-00D	4160V DISTRIBUTION PLAN	-	-
E-00E	PROPOSED 4160V DISTRIBUTION PLAN	-	-
E-1,2,61	ELECTRICAL ONE-LINE	T3	1,2,61
E-3,4	ELECTRICAL ONE-LINE	T4	3,4
E-6,7,8,9,10,14,21	ELECTRICAL ONE-LINE	T24,T25	6,7,8,9,10,14,21
E-10,11,12,13	ELECTRICAL ONE-LINE	T21,T34	10,11,12,13
E-18,64	ELECTRICAL ONE-LINE	T38	18,64
E-19	ELECTRICAL ONE-LINE	T32,T33	19
E-28,77,81,97,117	ELECTRICAL ONE-LINE	T35,T36	28,77,81,97,117
E-33,53,54,55,110,141	ELECTRICAL ONE-LINE	T7	33,53,54,55,110,141
E-34,44,56,76,114	ELECTRICAL ONE-LINE	T8,T9	34,44,56,76,114
E-37,39,95,129	ELECTRICAL ONE-LINE	T37	37,39,95,129
E-41	ELECTRICAL ONE-LINE	T5	41
E-42,45,48,49,51	ELECTRICAL ONE-LINE	T1,T6	42,45,48,49,51
E-43,46,57,68,94	ELECTRICAL ONE-LINE	T12,T13,T20	43,46,57,68,94
E-47,66,100	ELECTRICAL ONE-LINE	T11	47,66,100
E-58	ELECTRICAL ONE-LINE	T42	58,CEMENTERY OFFICE
E-71	ELECTRICAL ONE-LINE	T19	71
E-88,89	ELECTRICAL ONE-LINE	T27	88,89
E-88,89,90,91	ELECTRICAL ONE-LINE	-	88,89,90,91
E-90	ELECTRICAL ONE-LINE	T28	90
E-91	ELECTRICAL ONE-LINE	T21,T17	91
E-91C	ELECTRICAL ONE-LINE	T16	91C
E-122,157	ELECTRICAL ONE-LINE	T22,T41	122,157
E-152	ELECTRICAL ONE-LINE	T39	152
E-153	ELECTRICAL ONE-LINE	T40	153
E-156,161,161A	ELECTRICAL ONE-LINE	T26,TCP	156,161,161A
E-160	ELECTRICAL ONE-LINE	TD0M1,TD0M2,T18	160
EB01	MEDIUM VOLTAGE SKM ONE-LINE SCENARIO 2		
EB02	LOW VOLTAGE SKM ONE-LINE SCENARIO 2		
EB03	LOW VOLTAGE SKM ONE-LINE SCENARIO 2		
EB04	LOW VOLTAGE SKM ONE-LINE SCENARIO 2		
EB05	LOW VOLTAGE SKM ONE-LINE SCENARIO 2		
EB06	LOW VOLTAGE SKM ONE-LINE SCENARIO 2		
EB07	LOW VOLTAGE SKM ONE-LINE SCENARIO 2		
EB08	LOW VOLTAGE SKM ONE-LINE SCENARIO 2		



Revisions 	Date
-------------------	--------------

Drawing Title ELECTRICAL DRAWING INDEX	Project Title VA LEAVENWORTH ELECTRICAL STUDY	Date 01/30/09	Project No. 4611,0150
Approve: Division Chief 	Building Number DOE YAMC LEAVENWORTH, KANSAS	Drawing No. E-00A	Project No. 4611,0150
Approve: Service Director 	Checked <input type="checkbox"/> PG <input type="checkbox"/> JG	Page 1 of 39	