


Revisions	
Date	

BUILDINGS 88.89.90.91 EMERGENCY POWER ELECTRICAL ONE-LINE	Project Title VA LEAVENWORTH ELECTRICAL STUDY		
Approved: Division Chief	Building Number 88.89.90.91	Drawn PG	Drawn JG
Approved: Service Director	Location DDE VAAC LEAVENWORTH, KANSAS		

Date	01/30/09
Project No.	4611.0150
DRAWING NO.	E-88,89,90,91 Pgs. 23 of 39



GENERAL COMMENTS:

1. FUSE SIZES NOT SHOWN ON THE ONE-LINE DIAGRAM WILL REQUIRE POWER OUTAGES FOR FIELD VERIFICATION, OR REFER TO DWG. E-00D FOR MEDIUM VOLTAGE DETAIL

GENERAL COMMENTS:

1. FUSE SIZES NOT SHOWN ON THE ONE-LINE DIAGRAM WILL REQUIRE POWER OUTAGES FOR FIELD VERIFICATION, OR REFER TO DWG. E-00D FOR MEDIUM VOLTAGE DETAIL