

ATTACHMENT 7, FUEL TANK SERIAL AND FORM NUMBERS

Mont. Location	tank	Size & Type	Serial No.	Form No.	Diameter
Bldg. 8	E-85 AST	5,000 Double Walled	612297	8463-91-607	4" float* Mag +
Bldg. 14 Boiler Plant	Diesel UST	10,000 Gal Double Walled	647909	8473-90-107	4" float
Bldg. 14 Boiler Plant	Diesel UST	10,000 Gal Double Walled	647910	8473-90-107	4" float
Bldg. 14 Boiler Plant	E-10 UST gasoline	2,500 Gal Double Walled	660358	8473-90-104	4" float
Main hospital generator room	Diesel UST	6,000 gal Double Walled	647911	8473-20-107	3" riser 3" float kit

Tuskegee Location	Tank	Size & Type	Serial No.	Form No.	Diameter
Bldg. 129	Diesel AST	2,000 Gal Doubled walled	836000	8473-90-106	4" float
Bldg.. 120	Diesel AST	4,000 Gal Doubled Walled	385362	8463-90-107	4" float
Bldg. 124	Diesel AST	2,000 Gal Doubled Walled	393438	8473-90-106	4" float
Bldg. 123 **Not fully Functional	Diesel AST	2,000 Gal Doubled Walled	393436	8472-90-103	4" float
Bldg.. 121	Diesel AST	4,000 Gal Doubled walled	394208	8473-90-107	4' float
Bldg. 65	E-85 AST	5,000 Gal Doubled walled	666655	8463-91-607	4" float* Mag +
Bldg. 15	E-10 UST gasoline	4,000 Gal Doubled Walled	441860	8473-90-104	4" float

***For the two E-85 AST tanks, the existing probes and floats are to be reused. Only the monitors are to be removed and replaced.**

****For the Tuskegee Building 123, the emergency overfill alarm is not functioning and the monitor indicates the probe is not work.**