

Question: Please provide further clarification on what panels are to be demolished under the One Line Demo plan. Some of the same panels are shown under the new work diagram but according to the panel schedules none are listed as existing. Are all panels to be replaced?

Answer:

On drawing E001 in the Electrical Legend there are two sections for line types that show how we shown equipment for demolition and new work items. In the demolition riser diagram panel shown in solid (6ELA, GNHA, 6NLA and MCC) are to be removed and dashed equipment is to remain. On New work riser diagram panels shown in solid (6ELA, 6HNA, 6NLA, 6CLAA and 6EHB) are new and dashed equipment is to remain.