

one eighth inch = one foot
0 4 8 16

one quarter inch = one foot
0 4 8

three eighths inch = one foot
0 4 8

one half inch = one foot
0 4

one quarter inch = one foot
0 4 8

one eighth inch = one foot
0 4 8 16

one and one half inches = one foot
0 6"

two inches = one foot
0 6"

three inches = one foot
0 6"

one eighth inch = one foot

one quarter inch = one foot

three eighths inch = one foot

AIR DEVICE SCHEDULE (LINEAR)															
MARK	TYPE	AIRFLOW	MAX APD	MIN THROW	MAX THROW	PANEL/FR AME SIZE	# OF SLOTS	SLOT WIDTH	NECK SIZE ROUND	THROW PATTERN	THROW TYPE	MAX NC	DAMPER	FINISH	REMARKS
SD-005	LINEAR SLOT	155 CFM	0.06 in-wg	5'	15'	48"	3	1"	10" Ø	2 WAY	VERTICAL	23		WHITE	1
SD-006	LINEAR SLOT	155 CFM	0.06 in-wg	5'	15'	48"	3	1"	10" Ø	2 WAY	VERTICAL	23		WHITE	1
SD-011	LINEAR SLOT	160 CFM	0.06 in-wg	5'	15'	48"	3	1"	10" Ø	2 WAY	VERTICAL	23		WHITE	1
SD-012	LINEAR SLOT	160 CFM	0.06 in-wg	5'	15'	48"	3	1"	10" Ø	2 WAY	VERTICAL	23		WHITE	1
SD-044	LINEAR SLOT	200 CFM	0.06 in-wg	5'	15'	48"	3	1"	10" Ø	2 WAY	VERTICAL	23		WHITE	1
SD-045	LINEAR SLOT	200 CFM	0.06 in-wg	5'	15'	48"	3	1"	10" Ø	2 WAY	VERTICAL	23		WHITE	1
SD-046	LINEAR SLOT	200 CFM	0.06 in-wg	5'	15'	48"	3	1"	10" Ø	2 WAY	VERTICAL	23		WHITE	1
SD-047	LINEAR SLOT	200 CFM	0.06 in-wg	5'	15'	48"	3	1"	10" Ø	2 WAY	VERTICAL	23		WHITE	1
SD-056	LINEAR SLOT	190 CFM	0.06 in-wg	5'	15'	48"	3	1"	10" Ø	2 WAY	VERTICAL	23		WHITE	2
SD-066	LINEAR SLOT	185 CFM	0.07 in-wg	7'	17'	48"	4	1"	10" Ø	2 WAY	VERTICAL	24		WHITE	1
SD-067	LINEAR SLOT	185 CFM	0.07 in-wg	7'	17'	48"	4	1"	10" Ø	2 WAY	VERTICAL	24		WHITE	1
SD-068	LINEAR SLOT	185 CFM	0.07 in-wg	7'	17'	48"	4	1"	10" Ø	2 WAY	VERTICAL	24		WHITE	1
SD-069	LINEAR SLOT	185 CFM	0.07 in-wg	7'	17'	48"	4	1"	10" Ø	2 WAY	VERTICAL	24		WHITE	1
SD-070	LINEAR SLOT	250 CFM	0.07 in-wg	7'	17'	48"	4	1"	10" Ø	2 WAY	VERTICAL	24		WHITE	1
SD-071	LINEAR SLOT	250 CFM	0.07 in-wg	7'	17'	48"	4	1"	10" Ø	2 WAY	VERTICAL	24		WHITE	1
SD-072	LINEAR SLOT	240 CFM	0.07 in-wg	7'	17'	48"	4	1"	10" Ø	2 WAY	VERTICAL	24		WHITE	1
SD-090	LINEAR SLOT	240 CFM	0.06 in-wg	5'	15'	48"	3	1"	10" Ø	2 WAY	VERTICAL	23		WHITE	2
SD-091	LINEAR SLOT	240 CFM	0.06 in-wg	5'	15'	48"	3	1"	10" Ø	2 WAY	VERTICAL	23		WHITE	2

NOTES:

1. PROVIDE WITH UNIT MOUNTED THERMOSTAT.

CLEAN STEAM GENERATOR SCHEDULE													
MARK	SOURCE OF MAKEUP	WATER CONDITIONS		PRODUCED STEAM FLOW	PRODUCED STEAM PRESSURE	STEAM PRESSURE		CONTROL VALVE	TRAP			VOLTAGE	MCA
		FLOW	EWT			ENT. CONTROL	ENT. HEAT EXCHANGER		MARK	#	CAPACITY		
CSG-42	POTABLE	0.30 GPM	40 °F	150	5	5	5	N/A	42-ST-1	1	0	120 V	3 A


APOGEE
Consulting Group
www.acg-pa.com

Raleigh, NC
Indianapolis, IN
Philadelphia, PA
Pittsburgh, PA
Virginia Beach, VA
Fort Collins, CO
(919) 858-7420

LOUVER SCHEDULE							
MARK	LOCATION	AREA AND/OR ROOM SERVED	SIZE	AIRFLOW	APD	MOUNTING	APPLICATION
LV-42A	102	BUILDING 42	96" x 102"	5,500 CFM	0.02 in-wg	WALL	EXHAUST
LV-42B	102	BUILDING 42	30" x 36"	5,500 CFM	0.02 in-wg	DUCT	OUTDOOR AIR

MECHANICAL SCHEDULES		Project Title VA Durham Specialty Care Building 42		Project Number 558-321		Office of Construction and Facilities Management
				Building Number 42		
Project Director		Location Durham, North Carolina		Drawing Number M-603		
		Date 04/28/2015	Checked JWM	Drawn SPG	Dwg. 20 of 20	

Office of
Construction
and Facilities
Management

 Department of
Veterans Affairs