

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.

1. CONTRACT ID CODE

PAGE

OF PAGES

1

2

2. AMENDMENT/MODIFICATION NUMBER

0001

3. EFFECTIVE DATE

09-21-2018

4. REQUISITION/PURCHASE REQ. NUMBER

570-18-4-751-1383

5. PROJECT NUMBER (if applicable)

6. ISSUED BY

CODE

612MCP

7. ADMINISTERED BY (If other than Item 6)

CODE

612MCP

Department of Veterans Affairs
 VA Sierra Pacific Network (VISN 21)
 VA Northern California HealthCare System
 5342 Dudley Blvd, Bldg 209
 McClellan CA 95652-2609

Department of Veterans Affairs
 Department of Veterans Affairs
 VA Northern California HealthCare System
 3230 Peacekeeper Way, Bldg. 209
 McClellan CA 95652-1012

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)

To all Offerors/Bidders

(X)

9A. AMENDMENT OF SOLICITATION NUMBER

36C26118Q9697

X

9B. DATED (SEE ITEM 11)

09-21-2018

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED (SEE ITEM 13)

CODE

FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.

B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).

C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:

D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The purpose of this amendment is to provides responses to questions that have been received and to provide supplemental information to the vendors. Please review the following attachments:

- 1) As Built Drawings-Building 22A 9
- 2) 262921 Enclosed Switches and C Startup
- 3) 263623 Automatic Transfer Swit Startup

The quote due date/time remains unchanged.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)

16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)

Michael P. Hodahkwen
 Contracting Officer

15B. CONTRACTOR/OFFEROR

15C. DATE SIGNED

16B. UNITED STATES OF AMERICA

16C. DATE SIGNED

 (Signature of person authorized to sign)

BY _____
 (Signature of Contracting Officer)

09/21/2018

**Inspection of Power Distribution System
Central California Health Care System
Questions and Answers
36C26118Q9697
Amend #1**

1. What is the normal operation of the chillers (work altogether or some are standby, etc.)? If they not working altogether, it is possible to turn off the MCC's, one by one, to do test work?

All three chillers are currently off line pending repair. There are some pieces of equipment still dependent on the power distribution equipment included in this work however they can be temporarily powered from other sources. Shutting down the MCC's one by one is possible.

2. Information needed:

For Distribution Switchboard Section:

- Type of breakers; The attachment labeled 262921 Enclosed Switches and Circuit Breakers Commissioning Records provides breaker types for the distribution switch boards, MCC-E1, MCC-6 and MCC-7
- Type of Meter. The meter on the transformer is a Qualitrol 118 ITM. There is a display on the ATS which provides limited metering information. There are no other meters that I am aware of.

For MCC-E1, MCC-6 and MCC-7:

- Type of breakers (main and feeders)

For 12.7kV lines:

- How they been protected; I assume this question is asking if the 12 KV have a TVSS. To my knowledge they do not.
- Single line diagram. The attachment As Built Drawings-Building 22A9 contains a one line diagram for the 12kV system

For ATS: The attachment 263623 Automatic Transfer Switch Startup provides this information.