

---

# NASHVILLE VA PARKING GARAGE - SHORT CIRCUIT AND COORDINATION STUDY

---

Prepared by



Checking is only for general conformance with the design concept of the project and general compliance with the information given in the contract documents. Any action shown is subject to the requirements of the plans and specifications. Contractor is responsible for dimensions which shall be confirmed and correlated at the job site, fabrication processes and techniques of construction, coordination of the work, and the satisfactory performance of the work.

- NO EXCEPTION TAKEN
- MAKE CORRECTIONS NOTED
- REVISE AND RESUBMIT
- REJECTED, SEE REMARKS

---

# NASHVILLE VA PARKING GARAGE - SHORT CIRCUIT AND COORDINATION STUDY

Updated by  
**Drew Philippo**  
January 30, 2012



---

*This study is a fault-current and coordination study of an existing electrical system design. This study is not an evaluation of the system's design, design methodology, or design intent. The author of this study disclaims any responsibility for the design, safety, or suitability of the electrical system and components. Any distribution-system modifications suggested herein are intended for the use of the owner to aid in their assessment of the distribution system.*

# OVERVIEW

Purpose	<p>This report consists of two studies—a fault-current calculation study and an overcurrent-protection coordination study.</p> <p>The purpose of the fault-current study is to determine the available fault current at each panel and device in the facility’s distribution system. This data is then used to calculate the incident fault energy at each point in the system.</p> <p>The purpose of the overcurrent-protection coordination study is to assess the coordination between upstream and downstream devices in the facility’s distribution system. This study provides circuit-breaker settings to maximize coordination between those devices.</p>
Scope	<p>The scope of this report includes the new panelboards in the parking garage.</p>
Description of Sections	<p>The results are divided into four sections, providing the following information:</p> <ul style="list-style-type: none"><li>• The <b><i>System Description</i></b> section contains the one-line drawing used to perform the calculations along with the input data for the system components.</li><li>• The <b><i>Fault-Current Results</i></b> section presents the results of the fault-current calculation study. It shows a summary table of the available fault current for all devices within the scope of this project along with an equipment evaluation table for all of the equipment. It also includes the computer program output summary results.</li><li>• The <b><i>Time-Current Coordination (TCC) Results</i></b> section provides a summary of the overcurrent-protection coordination study. It includes a table of recommended circuit-breaker settings along with the associated time-current coordination curves.</li><li>• The <b><i>Study Methodology</i></b> section, presents a summary of the calculation methodology used to create this report. It also lists any assumptions that were made during the course of the calculations. Backup information provided to perform the study is also included in this section.</li></ul>
Executive Summary	<p>The calculations and the relevant input and output information are included in the sections described above. Overall the study yielded</p>


positive results for the various calculations with no problematic issues.

- **Fault Current:** All of the AIC ratings for the equipment are adequate for the available fault at the equipment.
- **Time-Current Coordination:** Overall there is good coordination in the system. Where there is a lack of coordination, it is in the normal bus or between devices in the parking garage and should not be considered a cause for concern.

# SYSTEM DESCRIPTION

Summary

The first page in this section contains the one-line drawing used to perform the calculations. Following the one-line drawing is the input data for all of the system components.



Online: ~One-Line

January 30, 2012

**Project: Nashville VA Parking Garage**

**DAPPER Fault Analysis Input Report (English)**

**Utilities**

Contribution From Name	Bus Name	In/Out Service	Nominal Voltage	----- Contribution Data -----			PU (100 MVA Base)		
				Duty	Units	X/R	R PU	X PU	
UTIL-BB	PNL-BB	In	480	<b>3P:</b>	30,050	Amps	8.00	<b>Pos:</b> 0.496	3.972
				<b>SLG:</b>	30,050	Amps	8.00	<b>Zero:</b> 0.496	3.972
UTIL-E-SWBD	E-SWBD	In	480	<b>3P:</b>	10,617	Amps	8.00	<b>Pos:</b> 1.405	11.242
				<b>SLG:</b>	10,617	Amps	8.00	<b>Zero:</b> 1.405	11.242
UTIL-N-SWBD	N-SWBD	In	480	<b>3P:</b>	15,900	Amps	8.00	<b>Pos:</b> 0.938	7.506
				<b>SLG:</b>	15,900	Amps	8.00	<b>Zero:</b> 0.938	7.506

**Motors**

Contribution From Name	# of Motors	Bus Name	In/Out Service	Nominal Voltage	----- Contribution Data -----			PU (100 MVA Base)	
					Base kVA	Xd"	X/R	R PU	X PU
ELEVATORS	2	PNL-ED2	In	480	40.11	0.1692	10.00	21.092	210.933

**Cables**

Cable Name	From Bus To Bus	In/Out Service	Qty /Ph	Length Feet	----- Cable Description -----			Per Unit (100 MVA Base)		
					Size	Cond. Type	Duct Type	Insul	R pu	jX pu
CBL-ATS-11-E	E-SWBD	In	1	28	350	Copper	Magnetic	PVC	Pos: 0.4594	0.5967
	BUS-0015								Zero: 1.4474	1.4693

Cable Name	From Bus To Bus	In/Out Service	Qty /Ph	Length Feet	----- Cable Description -----			Per Unit (100 MVA Base)		
					Size	Cond. Type	Duct Type	Insul	R pu	jX pu
CBL-ATS-11-N	N-SWBD	In	1	25	350	Copper	Magnetic	PVC	Pos: 0.4102	0.5328
	BUS-0016								Zero: 1.2923	1.3118
CBL-ATS-ED2-1	PNL-GH2	In	1	5	4/0	Copper	Magnetic	PVC	Pos: 0.1389	0.1079
	BUS-0012								Zero: 0.4377	0.2656
CBL-ATS-ED2-2	PNL-NED	In	1	450	4/0	Copper	Magnetic	PVC	Pos: 12.5000	9.7070
	BUS-0013								Zero: 39.3945	23.9063
CBL-ED2	BUS-0010	In	1	5	4/0	Copper	Magnetic	PVC	Pos: 0.1389	0.1079
	PNL-ED2								Zero: 0.4377	0.2656
CBL-EL2	PNL-MLS	In	1	450	1	Copper	Magnetic	PVC	Pos: 31.2500	11.1328
	PNL-EL2								Zero: 98.4766	27.4023
CBL-ELL2	BUS-0005	In	1	5	6	Copper	Magnetic	PVC	Pos: 5.8940	0.7917
	PNL-ELL2								Zero: 18.5743	1.9497
CBL-GH2	PNL-BB	In	1	700	350	Copper	Magnetic	PVC	Pos: 11.4844	14.9175
	PNL-GH2								Zero: 36.1849	36.7318
CBL-GL2	BUS-0004	In	1	5	6	Copper	Magnetic	PVC	Pos: 5.8940	0.7917
	PNL-GL2								Zero: 18.5743	1.9497
CBL-MLS	BUS-0017	In	1	5	350	Copper	Magnetic	PVC	Pos: 0.0820	0.1066
	PNL-MLS								Zero: 0.2585	0.2624
CBL-NED	E-SWBD	In	1	5	600	Copper	Magnetic	PVC	Pos: 0.0558	0.1005
	PNL-NED								Zero: 0.1756	0.2474

Cable Name	From Bus To Bus	In/Out Service	Qty /Ph	Length Feet	----- Cable Description -----				Per Unit (100 MVA Base)		
					Size	Cond. Type	Duct Type	Insul	R pu	jX pu	
CBL-T-ELL2	PNL-ED2	In	1	5	10	Copper	Magnetic	PVC	Pos: 2.5608	0.1853	
									Zero: 8.0703	0.4564	
	BUS-0009										
CBL-T-GL2	PNL-GH2	In	1	5	10	Copper	Magnetic	PVC	Pos: 2.5608	0.1853	
									Zero: 8.0703	0.4564	
	BUS-0006										

## 2-Winding Transformers

Xformer Name	In/Out Service	-----Primary & Secondary-----				Nominal kVA	Z PU (100 MVA Base)		
		Bus	Conn.	Volts	FLA		R pu	jX pu	
T-ELL2	In	BUS-0009	D	480	18	15.0	Pos: 140.0000	121.3333	
			WG	208	42		Zero: 140.0000	121.3333	
		BUS-0005							
T-GL2	In	BUS-0006	D	480	18	15.0	Pos: 140.0000	121.3333	
			WG	208	42		Zero: 140.0000	121.3333	
		BUS-0004							

# FAULT-CURRENT RESULTS

## Summary

This section presents the results of the fault-current calculation study. The first page is a summary table of available fault current for all of the switchboards and panelboards. Following the fault-current table are the computer program output results.

All of the new equipment AIC ratings are adequate for the available fault current at the equipment. The fault current values at the existing panelboards/switchboards were obtained from a previous study performed by GE in 1992 and another performed by Nash, Lipsey, Burch in 2000. Regardless, given the length of the feeders from the main building to the parking garage, the available fault current at the garage will always be low.

## Nashville VA Parking Garage - Fault-Current Study Results

Switchboard/Panel	RMS Sym. 3-Phase Current (Amps)	X/R	RMS Sym. Single Line to Ground Current (Amps)	Bus Voltage	Equipment AIC Rating (Amps)	Notes
PNL-ED2	5,810	1.72	3,734	480	22,000	
PNL-EL2	3,170	0.59	1,978	480	22,000	
PNL-ELL2	1,310	0.88	1,334	208	22,000	
PNL-GH2	5,889	1.74	3,794	480	22,000	
PNL-GL2	1,312	0.88	1,335	208	22,000	
PNL-NED	10,518	7.76	10,469	480	22,000	

Jan 30, 2012 15:15:57

-----  
ALL INFORMATION PRESENTED IS FOR REVIEW, APPROVAL  
INTERPRETATION AND APPLICATION BY A REGISTERED ENGINEER ONLY  
SKM DISCLAIMS ANY RESPONSIBILITY AND LIABILITY RESULTING  
FROM THE USE AND INTERPRETATION OF THIS SOFTWARE.  
-----

SKM POWER\*TOOLS FOR WINDOWS  
SHORT CIRCUIT ANALYSIS REPORT  
COPYRIGHT SKM SYSTEMS ANALYSIS, INC. 1995-2009  
-----

ALL PU VALUES ARE EXPRESSED ON A 100 MVA BASE

SWING GENERATORS		
SOURCE NAME	VOLTAGE	ANGLE
=====		
UTIL-E-SWBD	1.00	0.00
UTIL-N-SWBD	1.00	0.00
UTIL-BB	1.00	0.00

## \*\*\*\*\* P R E - F A U L T V O L T A G E P R O F I L E \*\*\*\*\*

BUS#	NAME	BASE VOLTS	PU VOLTS	ANGLE (D)
BUS-0004		208.00	1.0000	-30.
BUS-0005		208.00	1.0000	-30.
BUS-0006		480.00	1.0000	0.
BUS-0009		480.00	1.0000	0.
BUS-0010		480.00	1.0000	0.
BUS-0012		480.00	1.0000	0.
BUS-0013		480.00	1.0000	0.
BUS-0015		480.00	1.0000	0.
BUS-0016		480.00	1.0000	0.
BUS-0017		480.00	1.0000	0.
E-SWBD		480.00	1.0000	0.
N-SWBD		480.00	1.0000	0.
PNL-BB		480.00	1.0000	0.
PNL-ED2		480.00	1.0000	0.
PNL-EL2		480.00	1.0000	0.
PNL-ELL2		208.00	1.0000	-30.
PNL-GH2		480.00	1.0000	0.
PNL-GL2		208.00	1.0000	-30.
PNL-MLS		480.00	1.0000	0.
PNL-NED		480.00	1.0000	0.

\*\*\*\*\* FAULT ANALYSIS REPORT \*\*\*\*\*

FAULT TYPE: 3PH  
MODEL INDUCTION MOTOR CONTRIBUTION: YES  
MODEL TRANSFORMER TAPS: YES  
MODEL TRANSFORMER PHASE SHIFT: YES

=====

E-SWBD VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 10617.0 / -83. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 1.405 +j 11.242 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 8.000

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
14680.2	11066.3	10712.0	10621.1	10617.0	

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.0000 / 0.0 0.0000 / 0.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 10617.0 / -82.9 10617.0 / 157.1 10617.0 / 37.1

E-SWBD ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 PNL-NED 480.0 0.0000 / 0. 0.0000 / 0. 0.0000 / 0.  
 BUS-0015 480.0 0.0000 / 0. 0.0000 / 0. 0.0000 / 0.  
 E-SWBD ===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====

		FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES					
		BRANCH NAME	VBASE LL	-PHASE A-	-PHASE B-	-PHASE C-	
UTIL-E-SWBD	E-SWBD		480.	10617.0/ -83.	10617.0/ 157.	10617.0/	
37.							
E-SWBD	PNL-NED	CBL-NED	480.	0.0/ 0.	0.0/ 0.	0.0/ 0.	0.0/ 0.
0.							
E-SWBD	BUS-0015	CBL-ATS-11-E	480.	0.0/ 0.	0.0/ 0.	0.0/ 0.	0.0/ 0.
0.							

-----

N-SWBD VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 15900.0 / -83. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 0.938 +j 7.506 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 8.000

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
21985.0	16572.9	16042.2	15906.2	15900.1	

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.0000 / 0.0 0.0000 / 0.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 15900.0 / -82.9 15900.0 / 157.1 15900.0 / 37.1

N-SWBD ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 BUS-0016 480.0 0.0000 / 0. 0.0000 / 0. 0.0000 / 0.  
 N-SWBD

===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 UTIL-N-SWBD N-SWBD 480. 15900.0/ -83. 15900.0/ 157. 15900.0/  
 37.  
 N-SWBD BUS-0016 CBL-ATS-11-N 480. 0.0/ 0. 0.0/ 0. 0.0/  
 0.

-----

PNL-BB VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 30576.4 / -83. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 0.489 +j 3.903 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 7.978

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
42256.1	31859.3	30846.3	30588.0	30576.5	

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.0000 / 0.0 0.0000 / 0.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 30576.4 / -82.9 30576.4 / 157.1 30576.4 / 37.1

PNL-BB ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 PNL-GH2 480.0 0.0824 / -29. 0.0824 / -149. 0.0824 / 91.  
 PNL-BB ===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====

		FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES					
		BRANCH NAME	VBASE LL	-PHASE A-	-PHASE B-	-PHASE C-	
UTIL-BB	PNL-BB		480.	30050.0/ -83.	30050.0/ 157.	30050.0/	
37.							
PNL-BB	PNL-GH2	CBL-GH2	480.	526.5/ 98.	526.5/ -22.	526.5/-	
142.							

-----

PNL-ED2 VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 5810.2 / -60. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 10.397 +j 17.902 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 1.722

ASYM RMS INTERRUPTING AMPS  
 1/2 CYCLES 2 CYCLES 3 CYCLES 5 CYCLES 8 CYCLES  
 5959.4 5810.2 5810.2 5810.2 5810.2

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.0000 / 0.0 0.0000 / 0.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 5810.2 / -59.9 5810.2 / -179.9 5810.2 / 60.1

PNL-ED2 ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 BUS-0009 480.0 0.0000 / 0. 0.0000 / 0. 0.0000 / 0.  
 BUS-0010 480.0 0.0077 / -19. 0.0077 / -139. 0.0077 / 101.  
 PNL-ED2 ===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====

FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 ELEVATORS PNL-ED2 480. 567.4/ -84. 567.4/ 156. 567.4/  
 36.  
 PNL-ED2 BUS-0009 CBL-T-ELL2 480. 0.0/ 0. 0.0/ 0. 0.0/  
 0.  
 BUS-0010 PNL-ED2 CBL-ED2 480. 5298.8/ -57. 5298.8/ -177. 5298.8/  
 63.

-----

PNL-EL2 VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 3170.0 / -31. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 32.681 +j 19.279 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 0.590

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
3170.1	3170.0	3170.0	3170.0	3170.0	3170.0

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.0000 / 0.0 0.0000 / 0.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 3170.0 / -30.5 3170.0 / -150.5 3170.0 / 89.5

PNL-EL2 ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 PNL-MLS 480.0 0.8743 / -11. 0.8743 / -131. 0.8743 / 109.  
 PNL-EL2

===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 PNL-MLS PNL-EL2 CBL-EL2 480. 3170.0/ -31. 3170.0/-151. 3170.0/  
 89.

-----

PNL-ELL2

VOLTAGE BASE LL: 208.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 1310.0 / -71. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 158.852 +j 140.212 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 0.883

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
1311.1	1310.0	1310.0	1310.0	1310.0	1310.0

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.0000 / 0.0 0.0000 / 0.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 1310.0 / -71.4 1310.0 / 168.6 1310.0 / 48.6

PNL-ELL2

==== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 208.0 0.0281 / -64. 0.0281 / 176. 0.0281 / 56.

BUS-0005  
PNL-ELL2

==== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 BUS-0005 PNL-ELL2 CBL-ELL2 208. 1310.0/ -71. 1310.0/ 169. 1310.0/

49.

-----

PNL-GH2 VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 5889.5 / -60. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 10.185 +j 17.702 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 1.738

ASYM RMS INTERRUPTING AMPS  
 1/2 CYCLES 2 CYCLES 3 CYCLES 5 CYCLES 8 CYCLES  
 6045.9 5889.5 5889.5 5889.5 5889.5

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.0000 / 0.0 0.0000 / 0.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 5889.5 / -60.1 5889.5 / 179.9 5889.5 / 59.9

PNL-GH2 ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 BUS-0006 480.0 0.0000 / 0. 0.0000 / 0. 0.0000 / 0.  
 PNL-BB 480.0 0.8416 / -5. 0.8416 / -125. 0.8416 / 115.  
 BUS-0012 480.0 0.0008 / -46. 0.0008 / -166. 0.0008 / 74.  
 PNL-GH2

===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 PNL-GH2 BUS-0006 CBL-T-GL2 480. 0.0/ 0. 0.0/ 0. 0.0/  
 0. PNL-BB PNL-GH2 CBL-GH2 480. 5377.3/ -58. 5377.3/ -178. 5377.3/  
 62. PNL-GH2 BUS-0012 CBL-ATS-ED2-1 480. 566.8/ 96. 566.8/ -24. 566.8/  
 144.

-----

PNL-GL2 VOLTAGE BASE LL: 208.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 1311.8 / -71. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 158.640 +j 140.012 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 0.883

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
1312.9	1311.8	1311.8	1311.8	1311.8	1311.8

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.0000 / 0.0 0.0000 / 0.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 1311.8 / -71.4 1311.8 / 168.6 1311.8 / 48.6

PNL-GL2 ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 BUS-0004 208.0 0.0281 / -64. 0.0281 / 176. 0.0281 / 56.  
 PNL-GL2

===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 BUS-0004 PNL-GL2 CBL-GL2 208. 1311.8/ -71. 1311.8/ 169. 1311.8/  
 49.

-----

PNL-MLS VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 14543.5 / -80. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 1.431 +j 8.146 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 5.694

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
18757.6	14718.6	14562.9	14543.8	14543.5	

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.0000 / 0.0 0.0000 / 0.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 14543.5 / -80.0 14543.5 / 160.0 14543.5 / 40.0

PNL-MLS ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 PNL-EL2 480.0 0.0000 / 0. 0.0000 / 0. 0.0000 / 0.  
 BUS-0017 480.0 0.0163 / -28. 0.0163 / -148. 0.0163 / 92.

PNL-MLS ===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 PNL-MLS PNL-EL2 CBL-EL2 480. 0.0/ 0. 0.0/ 0. 0.0/  
 0.  
 BUS-0017 PNL-MLS CBL-MLS 480. 14543.5/ -80. 14543.5/ 160. 14543.5/  
 40.

-----

PNL-NED VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 10517.9 / -83. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 1.461 +j 11.342 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 7.763

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
14461.0	10923.2	10599.5	10521.2	10518.0	

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.0000 / 0.0 0.0000 / 0.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 10517.9 / -82.7 10517.9 / 157.3 10517.9 / 37.3

PNL-NED ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 E-SWBD 480.0 0.0100 / -22. 0.0100 / -142. 0.0100 / 98.  
 BUS-0013 480.0 0.0000 / 0. 0.0000 / 0. 0.0000 / 0.  
 PNL-NED ===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====

		FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES				
		BRANCH NAME	VBASE LL	-PHASE A-	-PHASE B-	-PHASE C-
E-SWBD	PNL-NED	CBL-NED	480.	10517.9/ -83.	10517.9/ 157.	10517.9/ 37.
PNL-NED	BUS-0013	CBL-ATS-ED2-2	480.	0.0/ 0.	0.0/ 0.	0.0/ 0.

\*\*\*\*\*

\*\*\*\*\* FAULT ANALYSIS REPORT \*\*\*\*\*

FAULT TYPE: SLG  
MODEL INDUCTION MOTOR CONTRIBUTION: YES  
MODEL TRANSFORMER TAPS: YES  
MODEL TRANSFORMER PHASE SHIFT: YES

=====

E-SWBD VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 10617.0 / -83. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 4.216 +j 33.725 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 8.000  
 SEQUENCE EQUIVALENT IMPEDANCE Z1: 1.405 +j 11.242 (PU)  
 Z2: 1.405 +j 11.242 (PU)  
 Z0: 1.405 +j 11.242 (PU)

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
14680.2	11066.3	10712.0	10621.1	10617.0	

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 1.0000 / -120.0 1.0000 / 120.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 10617.0 / -82.9 0.0 / 0.0 0.0 / 0.0

E-SWBD ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 PNL-NED 480.0 0.0000 / 0. 1.0000 / -120. 1.0000 / 120.  
 BUS-0015 480.0 0.0000 / 0. 1.0000 / -120. 1.0000 / 120.

E-SWBD ===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 UTIL-E-SWBD E-SWBD 480. 10617.0/ -83. 0.0/ -83. 0.0/ -  
 83.  
 E-SWBD PNL-NED CBL-NED 480. 0.0/ 0. 0.0/ 0. 0.0/  
 0.  
 E-SWBD BUS-0015 CBL-ATS-11-E 480. 0.0/ 0. 0.0/ 0. 0.0/  
 0.

N-SWBD VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 15900.0 / -83. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 2.815 +j 22.519 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 8.000  
 SEQUENCE EQUIVALENT IMPEDANCE Z1: 0.938 +j 7.506 (PU)  
 Z2: 0.938 +j 7.506 (PU)  
 Z0: 0.938 +j 7.506 (PU)

ASYM	RMS	INTERRUPTING AMPS		
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES
21985.0	16572.9	16042.2	15906.2	15900.1

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 1.0000 / -120.0 1.0000 / 120.0

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 15900.0 / -82.9 0.0 / 0.0 0.0 / 0.0

N-SWBD ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 BUS-0016 480.0 0.0000 / 0.0 1.0000 / -120.0 1.0000 / 120.0

N-SWBD ===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 UTIL-N-SWBD N-SWBD 480. 15900.0/ -83. 0.0/ -83. 0.0/ -  
 83.  
 N-SWBD BUS-0016 CBL-ATS-11-N 480. 0.0/ 0. 0.0/ 0. 0.0/  
 0.

PNL-BB VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 30398.9 / -83. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 1.475 +j 11.778 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 7.985  
 SEQUENCE EQUIVALENT IMPEDANCE Z1: 0.489 +j 3.903 (PU)  
 Z2: 0.489 +j 3.903 (PU)  
 Z0: 0.496 +j 3.972 (PU)

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
42018.2	31678.0	30668.4	30410.5	30399.0	

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 1.0030 / -120.3 1.0028 / 120.3

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 30398.9 / -82.9 0.0 / 0.0 0.0 / 0.0

PNL-BB ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 PNL-GH2 480.0 0.0546 / -29. 1.0038 / -122. 1.0265 / 121.  
 PNL-BB

===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 UTIL-BB PNL-BB 480. 30050.0/ -83. 174.5/ -82. 174.5/ -  
 82.  
 PNL-BB PNL-GH2 CBL-GH2 480. 349.0/ 98. 174.5/ -82. 174.5/ -  
 82.

---

PNL-ED2 VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 3733.8 / -53. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 58.351 +j 77.038 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 1.320  
 SEQUENCE EQUIVALENT IMPEDANCE Z1: 10.397 +j 17.902 (PU)  
 Z2: 10.397 +j 17.902 (PU)  
 Z0: 37.557 +j 41.235 (PU)

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
3765.7	3733.8	3733.8	3733.8	3733.8	3733.8

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 1.1679 / -137.6 1.2787 / 132.4

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 3733.8 / -52.9 0.0 / 0.0 0.0 / 0.0

PNL-ED2 ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 BUS-0009 480.0 0.0000 / 0. 1.1679 / -138. 1.2787 / 132.  
 BUS-0010 480.0 0.0086 / -18. 1.1665 / -137. 1.2753 / 132.

PNL-ED2 ===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 ELEVATORS PNL-ED2 480. 243.1/ -77. 121.5/ 103. 121.5/  
 103.  
 PNL-ED2 BUS-0009 CBL-T-ELL2 480. 0.0/ 0. 0.0/ 0. 0.0/  
 0.  
 BUS-0010 PNL-ED2 CBL-ED2 480. 3513.9/ -51. 121.5/ -77. 121.5/ -  
 77.

PNL-EL2 VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 1977.5 / -24. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 166.327 +j 75.040 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 0.451  
 SEQUENCE EQUIVALENT IMPEDANCE Z1: 32.681 +j 19.279 (PU)  
 Z2: 32.681 +j 19.279 (PU)  
 Z0: 100.966 +j 36.483 (PU)

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
1977.5	1977.5	1977.5	1977.5	1977.5	1977.5

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 1.1879 / -137.8 1.2832 / 133.3

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 1977.5 / -24.3 0.0 / 0.0 0.0 / 0.0

PNL-EL2 ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 PNL-MLS 480.0 0.9232 / -7. 1.0057 / -120. 1.0017 / 120.

PNL-EL2 ===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 PNL-MLS PNL-EL2 CBL-EL2 480. 1977.5/ -24. 0.0/ 0. 0.0/

0.

-----

PNL-ELL2

VOLTAGE BASE LL: 208.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 1333.7 / -70. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 476.278 +j 403.707 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 0.848  
 SEQUENCE EQUIVALENT IMPEDANCE Z1: 158.852 +j 140.212 (PU)  
 Z2: 158.852 +j 140.212 (PU)  
 Z0: 158.574 +j 123.283 (PU)

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
1334.5	1333.7	1333.7	1333.7	1333.7	1333.7

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.9734 / -149.7 1.0091 / 88.5

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 1333.7 / -70.3 0.0 / 0.0 0.0 / 0.0

PNL-ELL2

==== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 208.0 0.0490 / -64. 0.9755 / -148. 0.9908 / 88.

BUS-0005  
PNL-ELL2

==== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 PNL-ELL2 CBL-ELL2 208. 1333.7/ -70. 0.0/ 0. 0.0/

BUS-0005  
0.

-----

PNL-GH2 VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 3793.7 / -53. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 57.052 +j 76.107 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 1.334  
 SEQUENCE EQUIVALENT IMPEDANCE Z1: 10.185 +j 17.702 (PU)  
 Z2: 10.185 +j 17.702 (PU)  
 Z0: 36.681 +j 40.704 (PU)

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
3827.7	3793.7	3793.7	3793.7	3793.7	3793.7

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 1.1670 / -137.5 1.2773 / 132.4

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 3793.7 / -53.1 0.0 / 0.0 0.0 / 0.0

PNL-GH2 ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 BUS-0006 480.0 0.0000 / 0. 1.1670 / -138. 1.2773 / 132.  
 PNL-BB 480.0 0.9006 / -4. 1.0024 / -120. 1.0017 / 120.  
 BUS-0012 480.0 0.0004 / -39. 1.1670 / -138. 1.2775 / 132.  
 PNL-GH2

===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 PNL-GH2 BUS-0006 CBL-T-GL2 480. 0.0/ 0. 0.0/ 0. 0.0/  
 0.  
 PNL-BB PNL-GH2 CBL-GH2 480. 3573.0/ -52. 121.7/ -77. 121.7/ -  
 77.  
 PNL-GH2 BUS-0012 CBL-ATS-ED2-1 480. 243.4/ 103. 121.7/ -77. 121.7/ -  
 77.

PNL-GL2 VOLTAGE BASE LL: 208.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 1335.0 / -70. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 475.855 +j 403.307 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 0.848  
 SEQUENCE EQUIVALENT IMPEDANCE Z1: 158.640 +j 140.012 (PU)  
 Z2: 158.640 +j 140.012 (PU)  
 Z0: 158.574 +j 123.283 (PU)

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
1335.8	1335.0	1335.0	1335.0	1335.0	1335.0

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.9736 / -149.7 1.0093 / 88.6

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 1335.0 / -70.3 0.0 / 0.0 0.0 / 0.0

PNL-GL2 ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====  
 FIRST BUS FROM FAULT AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 BUS-0004 208.0 0.0490 / -64. 0.9758 / -149. 0.9910 / 88.  
 PNL-GL2

===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====  
 FIRST BRANCH FROM FAULT AT TIME = 0.5 CYCLES  
 BRANCH NAME VBASE LL -PHASE A- -PHASE B- -PHASE C-  
 BUS-0004 PNL-GL2 CBL-GL2 208. 1335.0/ -70. 0.0/ 0. 0.0/  
 0.

-----

PNL-MLS VOLTAGE BASE LL: 480.0 (VOLTS)  
 INI. SYM. RMS FAULT CURRENT: 13916.0 / -78. ( AMPS/DEG )  
 THEVENIN EQUIVALENT IMPEDANCE: 5.350 +j 25.372 (PU)  
 THEVENIN IMPEDANCE X/R RATIO: 4.742  
 SEQUENCE EQUIVALENT IMPEDANCE Z1: 1.431 +j 8.146 (PU)  
 Z2: 1.431 +j 8.146 (PU)  
 Z0: 2.489 +j 9.081 (PU)

ASYM	RMS	INTERRUPTING AMPS			
1/2 CYCLES	2 CYCLES	3 CYCLES	5 CYCLES	8 CYCLES	
17222.5	13985.3	13920.9	13916.0	13916.0	

INI. SYM. RMS FAULTED BUS VOLTAGES ( PU / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 0.0000 / 0.0 0.9952 / -123.1 1.0502 / 121.2

INI. RMS FAULTED CURRENT ( AMPS / DEG )  
 AT TIME = 0.5 CYCLES  
 ---PHASE A--- ---PHASE B--- ---PHASE C---  
 13916.0 / -78.1 0.0 / 0.0 0.0 / 0.0

PNL-MLS ===== INI. SYM. RMS SYSTEM BUS VOLTAGES ( PU / DEG ) =====

	FIRST BUS FROM FAULT	AT TIME =	0.5 CYCLES			
	---	PHASE A---	---	PHASE B---	---	PHASE C---
PNL-EL2	480.0	0.0000 / 0.0	0.9952 / -123.1	1.0502 / 121.2		
BUS-0017	480.0	0.0245 / -30.0	0.9958 / -123.1	1.0418 / 121.2		

PNL-MLS ===== INI. RMS SYSTEM BRANCH FLOWS ( AMPS ) =====

	FIRST BRANCH FROM FAULT AT TIME =	0.5 CYCLES				
	BRANCH NAME	VBASE LL	-PHASE A-	-PHASE B-	-PHASE C-	
PNL-MLS	PNL-EL2	CBL-EL2	480.0	0.0/ 0.0	0.0/ 0.0	0.0/ 0.0
0.						
BUS-0017	PNL-MLS	CBL-MLS	480.0	13916.0/ -78.0	0.0/ -78.0	0.0/ -78.0
78.						

-----

# TIME-CURRENT COORDINATION

## Protective- Device Settings

The tables on the following pages list the recommended protective-device settings for all devices with adjustable trip settings. These settings achieve the coordination as shown on the coordination curves below. These settings have been chosen to provide adequate protection under National Electrical Code (NEC) guidelines while maximizing selectivity. The settings for the existing static trip circuit breakers have been provided for information only and reflect the values provided in the previous studies or from information provided by Carter Concrete.

## Time-Current Coordination Graphs

The graphs that follow the protective-device settings table show the time-current coordination (TCC) curves for each of the protective devices. Each plot shows the TCC curves along with the associated section of the one-line drawing. It is important to note that the trip curve for each breaker is cut off on the current scale (x-axis) at the maximum available fault current for that device. This is because that device will never operate in the region of the curve that exceeds the maximum available fault. The suffix B is used to indicate the largest branch circuit breaker in the most downstream panelboard in a set of curves.

Each leg of the distribution system for each piece of switchgear has been included in the study. In some cases where the downstream switchboard or panel feeds two loads with breakers, the largest breaker was chosen to be shown as the worst case for coordination. Where parallel feeds exist, the trip curves for only one set of the breakers has been shown for clarity.

It should be noted that in the very short time instantaneous region (less than 0.05 seconds) that the coordination between many of the devices fails as the trip curve tails out.

Overall the coordination between the circuit breakers and fuses within this project is good. The major area where coordination is an issue is within the normal power elevator distribution.

**01-GL2** – There is a lack of coordination between the panel GL2 branch breaker and main and feeder breaker in the instantaneous trip region. There is an overlap of the trip curves for the transformer feeder and panelboard main breakers but this does not constitute a lack of coordination since both circuit breakers serve the same load. There is an overlap of the trip curve for the panelboard BB feeder breaker and the panel GH2 main breaker in the thermal magnetic trip region, but the fuse feeding panel GH2 provides the required coordination.

**02-ELEV-N** – There is a lack of coordination between the elevator feeder breaker and the elevator panel feeder breakers in the instantaneous trip region. There is also a lack of coordination between the panel GH2 feeder fuse, the GH2 main breaker and the elevator panel feeder and main breakers. Using a type RK5 time delay fuse in lieu of the J-Class fuse would help. It might also be possible to provide a smaller circuit breaker feeding the elevators, depending on the starting mechanism for the elevator motors.

**03-ELL2-N** – There is good coordination between the overcurrent protective devices. There is an overlap of the trip curves for the transformer feeder breaker and the panelboard main breaker but this does not constitute a lack of coordination since both circuit breakers serve the same load.

**04-ELEV-E** – There is a lack of coordination between the elevator feeder breaker and the elevator panel feeder breakers in the instantaneous trip region. Otherwise, there is good coordination between the overcurrent protective devices.

**05-ELL2-E** – There is good coordination between the overcurrent protective devices. There is an overlap of the trip curves for the transformer feeder breaker and the panelboard main breaker but this does not constitute a lack of coordination since both circuit breakers serve the same load. The panel MLS main breaker will need to be adjusted up from its current setting. The breaker curve will overlap the panel MLS feeder breaker but this does not constitute a lack of coordination since both circuit breakers serve the same load.

**06-EL2-E** – There is good coordination between the overcurrent protective devices. There is an overlap of the trip curves for the transformer feeder breaker and the panelboard main breaker but this does not constitute a lack of coordination since both circuit breakers serve the same load.

**07-EL2-N** – There is good coordination between the overcurrent protective devices. There is an overlap of the trip curves for the transformer feeder breaker and the panelboard main breaker but this does not constitute a lack of coordination since both circuit breakers serve the same load.



### Nashville VA Parking Garage Static Trip Circuit Breaker Settings

Protective Device	Panel/ Switchboard	Voltage	Manufacturer	Frame Description	Frame Size	Sensor	Plug	LTPU	LTD	STPU	STD (I <sup>2</sup> T)	INST
PD-BB	PNL-BB	480	SQUARE D	LXI	400	400	400	1.0 (400A)	14	8 (3200A)	0.1	8 (3200A)
PD-E SWBD MAIN	E-SWBD	480	GE	TC	2,500	2,500	2,500	1 (2500A)	2	4 (10000A)	Max (I <sup>2</sup> t In)	7 (17500A)
PD-ATS-11-E	E-SWBD	480	GE	TC	800	400	250	1 (250A)	4	9 (2250A)	Min (I <sup>2</sup> t Out)	15 (3750A)
PD-ATS-11-N	E-SWBD	480	GE	TC	800	400	250	1 (250A)	4	9 (2250A)	Min (I <sup>2</sup> t Out)	15 (3750A)
PD-N SWBD MAIN	N-SWBD	480	GE	TC	2,500	2,500	2,500	1 (2500A)	1	1.5 (3750A)	Int (I <sup>2</sup> t Out)	9 (22500A)
PD-NED	E-SWBD	480	GE	TC	800	400	400	1 (400A)	4	9 (3600A)	Min (I <sup>2</sup> t Out)	10 (4000A)

### Nashville VA Parking Garage Adjustable Thermal Magnetic Molded Case Circuit Breaker Settings

Prot Dev	Panel/Switchboard	Amps Frame	Manufacturer	Type	Amps Sensor/Plug	Sensor Type	Instantaneous Trip
PD-ATS-ED2-1	PNL-GH2	250	SQUARE D	JG	225	J-Frame, Powerpact	INST (5-10 x Trip) 9.00
PD-ATS-ED2-2	PNL-NED	250	SQUARE D	JG	225	J-Frame, Powerpact	INST (5-10 x Trip) High
PD-ED2 MAIN	PNL-ED2	225	SQUARE D	LA	225	LA	INST 4
PD-GH2 MAIN	PNL-GH2	400	SQUARE D	LA	300	LA	INST 2
PD-MLS MAIN	PNL-MLS	400	GE	TLB4	250	TLB4	INST (4.5-10 x Trip) HI

CURRENT IN AMPERES




TCC: 01-GL2

Current Scale x 1


Reference Voltage: 480

January 15, 2012

CURRENT IN AMPERES



TIME IN SECONDS





TCC: 02-ELEV-N

Current Scale x 1

Reference Voltage: 480

January 15, 2012

CURRENT IN AMPERES



TIME IN SECONDS


TCC: 03-ELL2-N

Current Scale x 1


Reference Voltage: 480

January 15, 2012

CURRENT IN AMPERES



TIME IN SECONDS





TCC: 04-ELEV-E

Current Scale x 1

Reference Voltage: 480

January 15, 2012

CURRENT IN AMPERES





TCC: 05-ELL2-E

Current Scale x 1

Reference Voltage: 480

January 15, 2012

CURRENT IN AMPERES




TCC: 06-EL2

Current Scale x 1


Reference Voltage: 480

January 15, 2012

CURRENT IN AMPERES



TIME IN SECONDS



TCC: 07-EL2-N

Current Scale x 1

Reference Voltage: 480

January 30, 2012

# STUDY METHODOLOGY

## Fault-Current Calculation

### Fault-Current Study

The fault-current study calculates the fault current for a bolted three-phase fault condition. This represents a “worst-case” condition resulting in maximum thermal and mechanical stress in the system.

### Motor Contributions

In the fault-current studies, all motors are assumed to be running and are assumed to contribute fault current directly to the bus to which they are connected. Motor subtransient impedances are assumed to be in accordance with the ANSI/IEEE Standard 141-186. For simplification, the motors have been shown connected directly to the bus. This errs on the side of conservative with the fault current results.

### Conductor Properties

The conductor properties were obtained from ANSI/IEEE Standard 242-1986.

### Software

The electrical system was modeled and the calculations performed using PowerTools Version 6.5.1.8 (Build 4) by SKM Systems Analysis, Inc. The DAPPER System Studies comprehensive fault-current option was used for the fault-current calculations. The Arc Flash option was used for the arc-flash hazard assessment.

## Coordination Study

The protective-device coordination study and coordination recommendations were developed in accordance with the IEEE Standard 242-1986. The TCC curves were produced with the PowerTools CAPTOR Time-Current Coordination module.

## Specific Input Data Sources

### Utility Source

The available fault current at the existing panelboards/switchboards were obtained from a previous study performed by GE in 1992 and another performed by Nash, Lipsey, Burch in 2000.

### System Information

The feeder sizes and lengths, and the system topology were generated using the one-line drawings and information from Carter Concrete. The new equipment information was obtained from the equipment submittals.