

REQUEST FOR INFORMATION (RFI)
36C25018B0816

PROJECT NUMBER:	610-17-101	Please ensure that before submitting questions or requests for clarification that you thoroughly read the solicitation, specifications, drawings and other pertinent documents. When submitting questions on this project the Government requires contractors to specifically identify the specification and/or solicitation section(s) or drawing number(s) in reference to the question or request for clarification submitted. No question or request for clarification will be answered by the Government unless the above requirements are met. Failure to comply may prevent the Government from responding in a timely manner.
PROJECT TITLE:	Renovate 4 th Floor, Bldg. 138	
PROJECT LOCATION:	Department of Veterans Affairs VA Northern Indiana HCS 1700 E. 38 th Street Marion, IN 46953	

SUBMITTED BY:	Chris J. Stull, RCDD	CITY/STATE:	Fort Wayne, IN
PHONE:	260-497-1570		

TO:

Felecia Beamen, Contracting Officer
Department of Veterans Affairs
Network 10 Contracting Office
8888 Keystone Crossing, Suite 1100
Indianapolis, IN 46240
Felecia.Beamen@va.gov

RFI NO.:2	DATE: 09/17/2018	SPEC/DWG. REFERENCE(s): 281300 – Physical Access Control System
REPLY NEEDED BY:		

INFORMATION NEEDED:

Drawings and specifications do not indicate any information about the existing system pertaining to manufacture and model #, please clarify

REPLY:

RFI's will be answered by amendment(s) posted to fbo.gov.

This system will be an extension of the existing system in the building.

Existing system is a Stanley System. PACS readers System Software based on Stanley/Lenel/HID Global central-Station, workstation operating systems, server operating systems and application software.

REPLY FROM: Dustin Ruby - Korda Engineering Jacob Morrical	DATE: 2018-09-20
ATTACHMENTS:	COPY TO: