

RFI FORM

Contractor Name: IO Environmental & Infrastructure, Inc.

Address:

Phone/Fax:

Send to: cecil.nichols@va.gov

RFI (REQUEST FOR INFORMATION)			
PROJECT NO.:		RFI NO.:	002
PROJECT NAME:	SERVICE to PERFORM UST D.O. Inspections & Monitoring, VALB	DATE REQUESTED:	10/19/2018
SOLICITATION NO.:	36C26219Q0018	REFERENCE:	
DRAWING:		SPECIFICATION SECTION:	
DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED			
Please be specific as possible: Does the VA possess tank charts for every tank? This will be necessary to confirm the 95% level of each tank and shall be attached to the inspection form before submittal to Long Beach Fire.			
PROJECT MANAGER'S RESPONSE			
No, VA Long Beach does not have tank charts. However, they are available on Xerxes website and the overfill is set at 90% as per code.			
TRACKING NO.:		AMENDMENT NO.:	
VA PROJECT ENGINEER/MANAGER: Keith Didrickson, COR		DATE: October 25, 2018	