

**RFI FORM****Contractor Name:** IO Environmental & Infrastructure, Inc.**Address:****Phone/Fax:****Send to:** [cecil.nichols@va.gov](mailto:cecil.nichols@va.gov)

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>		<b>RFI NO.:</b>	003
<b>PROJECT NAME:</b>	SERVICE to PERFORM UST D.O. Inspections & Monitoring, VALB	<b>DATE REQUESTED:</b>	10/19/2018
<b>SOLICITATION NO.:</b>	36C26219Q0018	<b>REFERENCE:</b>	
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
Please be specific as possible: Scope item 8.2.1.10 mentions a pressure test of the vent lines listed with the 30-day designated operator inspection scope. I am not aware of this requirement. Would you please provide more details regarding this requirement, its origin, and frequency it shall be performed?			
<b>PROJECT MANAGER'S RESPONSE</b>			
Pressure test of the vent lines is required every three (3) years during the SB-989 testing.			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b>  Keith Didrickson, COR		<b>DATE:</b>  October 25, 2018	