

1
SS701

DETAIL
SCALE: 1 1/2" = 1'-0"
REFERENCE FIELD OBSERVATION REPORT SS

2 DETAIL REFERENCE RFI 036
SS701 SCALE: 1 1/2" = 1'-0"

NOTE:

1. ALL CORNERS TO BE CUT TO $\frac{3}{8}$ " MIN. RADIUS.
2. WELD WT10.5 AND/OR SLOT REINFORCING PLATE TO BEAM AND PROVIDE CONNECTION TO EXISTING COLUMN N14 PER DTL. 2/S5602.
3. FIELD VERIFY ALL DIMENSIONS AND CONDITIONS BEFORE CUTTING WT OR REINFORCING PLATE. CUTS TO BE MADE ONLY AS LARGE AS REQUIRED FOR INSTALLATION.

4
 SS701

ALTERNATE REINF. PLATE
 CONNECTION DETAIL
 SCALE: N.T.S.
 REFERENCE RFI 021 AND RFI 033 FOR COLUMN J-10
 AT THIRD FLOOR.

5
SS701

DETAIL—COLUMN COVER

SCALE: 1" = 1'-0"

REFERENCE RFI 024

NOTES

3. BASEMENT LEVEL L-4 COLUMN REINFORCING CHANGED TO TYPE 3 WITH PLATE $1\frac{1}{2} \times 11$. WELDS TO BE AS INDICATED WITH DETAIL 1/56602. REFERENCE RIT 026.
4. COLUMN REINFORCING IN THE CRAWL SPACE DELETED FOR COLUMNS L-7, L-8 AND L-10. REFERENCE RIT 025.
5. CONCRETE ENCASEMENT OF THE BASE OF COLUMN G6 TO AT LEAST $16'$ ABOVE THE BASE PLATE WAS PROVIDED FOR PROTECTION. REFERENCE FIELD OBSERVATION REPORT S7.
6. GROUND FLOOR LEVEL L-4 COLUMN REINFORCING CHANGED TO TYPE 3 WITH PLATE $2\frac{1}{2} \times 11$. WELDS TO BE AS INDICATED WITH DETAIL 1/56602. REFERENCE RIT 034.
7. COLUMN G-7 REINFORCING CHANGED AT THE THIRD FLOOR TO ONE PLATE $3\frac{1}{2} \times 11$ SIMILAR TO TYPE 4. SEE DETAIL 13/55701. REFERENCE RIT 011.
8. THE TWO $1\frac{1}{2} \times 3\frac{1}{2} \times 3\frac{1}{2}$ "X"36" CONNECTED TO THE BASE FLOOR PLANGE AT BR-1. (SEAL BEARING REINFORCING SCHEDULE DRAWING S301) ARE DELETED AND REPLACED BY A VERTICAL PLATE PER DETAIL 14/55701. REFERENCE RIT 041.

6 DETAIL REFERENCE RFI 037
SS701 SCALE: 1 1/2" = 1'-0"

7
SS701

DETAIL

REFERENCE RFI 039

SCALE: 1 1/2" = 1'-0"

8 DETAIL REFERENCE RFI 006
SS701 SCALE: 1 1/2" = 1'-0"

9 DETAIL REFERENCE RFI 007 & 008
SS701 SCALE: 1 1/2" = 1'-0"

10
SS701

DETAIL

REFERENCE RFI 002, 005 & 007

SCALE: 1 1/2" = 1'-0"

11
SS701

DETAIL

REFERENCE RFI 009

SCALE: 1 1/2" = 1'-0"

12
SS701

DETAIL

REFERENCE RFI 021

SCALE: 1 1/2" = 1'-0"

13
SS701

DETAIL

REFERENCE RFI 011

SCALE: 1 1/2" = 1'-0"

14
SS701

DETAIL

REFERENCE RFI 041

SCALE: 1 1/2" = 1'-0"

DETAIL—KNEE BRACE
ADDITION @ COL. S8 (3RD FLOOR)
SCALE: 1" = 1'-0"
REFERENCE RF 038

NOTE:
REFERENCE ARCHITECTURAL PLANS
(AS BUILT DRAWINGS AS100,
AS106 THRU AS109) FOR DETAIL
LOCATIONS.

THIS RECORD DRAWING HAS BEEN PREPARED ON INFORMATION PROVIDED BY OTHERS. THE DESIGN PROFESSIONAL HAS NOT VERIFIED THE ACCURACY AND/OR COMPLETENESS OF THIS INFORMATION AND SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS WHICH MAY BE INCORPORATED HEREIN AS A RESULT.

[illegible]