

**Amendment No. 2**

**Q1.** Is the VA exempt from CA sales tax like most Federal Agencies, and can you provide documentation authorizing the exemption?

**A1.** The VA is exempt from paying CA sales tax, document attached.

**Q2.** Is the radiator the only thing that needs be replaced? Or is it also expected that we replace the Frame, Fan and Motor?

**A2.** It is expected that the whole unit be replaced, I.E Frame fan and motor. They are all degraded.

**Q3.** Does the VA expect/require anything from the Generator Engine to be serviced or replaced? i.e. Hoses, block heaters, etc..?

**A3.** Nothing on the generator needs to be serviced, repaired or replaced. This is for the Radiator only.

**Q4.** Do you have on file the part number of the current radiator, if so, could you provided it to us? This is to ensure that the radiator we use will fit inside its current assembly.

**A4.** The part number for the radiator is not known. The radiator and frame came as one unit. The make and model of the emergency generator are noted in the statement of work.

**Q5.** With regards to the copper pipe, Does just the failing section of the pipe need to be replaced/repared or are there larger sections that are required to be replaced?

**A5.** Any failing part attached to the failing pipe shall be replaced.