

ARCHITECTS:

RSP Architects, Ltd.
1220 Marshall Street NE
Minneapolis, Minnesota 55413-1036
612/677-7100
612/677-7499 (FAX)

STRUCTURAL ENGINEERS:

Van Sickle, Allen and Associates
2955 Xenium Lane North, Suite 10
Plymouth, Minnesota 55441
(763) 559-9100

CIVIL ENGINEERS:

EVS
10250 Valley View Road, Suite 123
Eden Prairie, Minnesota 55344
(952) 646-0236

MECHANICAL AND ELECTRICAL ENGINEERS:

Dunham Associates, Inc.
50 South Sixth Street, Suite 1100
Minneapolis, Minnesota 55402-1540
(612) 465-7550

FIRE PROTECTION ENGINEERS:

GTA Engineering Associates
94 Boston Hill
Larksville, Pennsylvania 18651
(570) 779-7843

LANDSCAPE ARCHITECTS:

Damon Farber Associates, Inc.
401 Second Ave. North, Suite 410
Minneapolis, Minnesota 55401
(612) 332-7522

**AMENDMENT 3 _VA DESIGNATION
(ADDENDUM # 2 –Design Team)**

Issue Date: 31 August, 2012

Bid Due Date: 11 September, 2012 -No Change

Contract Documents for:

LONG TERM/INTERMEDIATE PSYCH UNIT
4801 Veterans Drive
St. Cloud, Mn.

for:

OWNER:
VA MEDICAL CENTER – ST. CLOUD
4801 Veterans Drive
St. Cloud, Mn.

Attachments:

Specification Sections: NONE

Partial Drawing Sheets: NONE

Full Drawing Sheets: AS901, AS921

Architect Commission No.: 2032.001.01

To: Prospective Bidders and other Project Manual Holders

The provisions in the Contract Documents, dated 15 March 2012 , and issued 09 August 2012 apply to this addendum.

This Addendum forms a part of the *Contract Documents* and Modifies the *Original Bidding Documents* and all previously issued *Addendum*. [Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.]

This Addendum consists of this Document, ending at the words "END OF ADDENDUM", and the listed attachments:

Item Numbers are in the following configuration:

Addendum # =====>2
Item # =====>-1.

CHANGES TO PRIOR ADDENDA

2-1. (NONE)

CHANGES TO BIDDING REQUIREMENTS

2-2. (NONE)

CHANGES TO CONDITIONS OF THE CONTRACT

2-3. (NONE)

CHANGES TO PROJECT MANUAL

DOCUMENT

a. NONE

SECTION 04 20 00 Unit Masonry

NOT REISSUED

- 2-4. Spec Section 04 20 00 Unit Masonry, make the following changes:
- Add to following to 2.1 B 4 to read: Color and Texture: As selected by Architect from samples submitted of face brick and mortar to match adjacent Building # 111, **ACME- OCHS BRICK-HARVARD SERIES BLEND.**

SECTION 07 21 13 Thermal Insulation

NOT REISSUED

- 2-5. Spec Section 07 21 13 Thermal Insulation, make the following changes:
- ELIMINATE section 2.7 Foamed-in-Place Insulation (INSUL -8) IN ITS ENTIRETY.

SECTION 08 71 00 FINISH HARDWARE

NOT REISSUED

- 2-6. Spec Section 08 71 00 Finish Hardware, make the following changes:
- Hardware Group 22:
 - Change Continous Hinge Model to : **FM-300 EPT**
 - Change Push/Pull Latch to : **Door Pull - VR910NL.**
 - Add: Power Transfer - EPT-10**
 - Add: Panic Hardware - EL-99NL-OP**

SECTION 08 51 13 Aluminum Windows

NOT REISSUED

A
D
D
E
N I
D T
U E
M M

DESCRIPTION

- 2-7. Spec Section 08 51 13 Aluminum Windows, make the following changes:
- Revise 2.8 F to read: Muntins: Provide simulated divided lite muntin bars in pattern indicated on drawings. Muntins to be **integral within insulated glass units. Furnish in a finish to match window framing.**

SECTION 08 80 00 Glazing

NOT REISSUED

- 2-8. Spec Section 08 80 00 Glazing, make the following changes:
- Add the following to 2.6 B to read: Assemble units using glass types specified. **Install muntins (By Aluminum Window Supplier) within insulated glass units. Refer to window types for pattern and locations.**

SECTION 09 51 00 Acoustical Ceilings

NOT REISSUED

- 2-9. Spec Section 09 51 00 Acoustical Ceilings, make the following changes:
- Revise the following 2.8 A. 6 to read: Lay –in panels: Sizes as shown, with **beveled tegular edges.**

CHANGES TO DRAWINGS

ARCHITECTURAL

SHEET AS102 – LINK CONNECTION PLANS AND ELEVATIONS

(NOT REISSUED)

At ELEVATION 5 REVISE Attic Elevation tag to read: **ATTIC- T/PRECAST / 113'-11"**.

SHEET AS105 – DEDUCT Alt. #9 , PLANS

(NOT REISSUED)

- 2-10. At ELEVATION 5 REVISE Attic Elevation tag to read: **ATTIC- T/PRECAST / 113'-11"**. REVISE ROOF SLAB Elevation tag to read: **ROOF SLAB / 128'-5"**.

SHEET AS301- DOOR SCHEDULE

(NOT REISSUED)

- 2-11. DOOR SCHEDULE:
- Revise Glass Type at Openings 113 and 114 to read: **GL-6.**
- 2-12. WINDOW TYPES:
- At Types A and A-2 add the following to the note: Interior Aluminum Security Window –**Shown dashed, see spec section 08 56 63. Glazing shall be GL-5.**

SHEET AS401 EXTERIOR ELEVATIONS

(NOT REISSUED)

DESCRIPTION

- 2-13. At ELEVATIONS 1,2,3,4,5, & 6 REVISE Attic Elevation tag to read: **ATTIC- T/PRECAST / 113'-11"**. REVISE ROOF SLAB Elevation tag to read: **ROOF SLAB / 128'-5"**.

SHEET AS501 BUILDING SECTIONS AND WALL SECTIONS

(NOT REISSUED)

- 2-14. At ELEVATIONS 1, 2, 4, 5, 6, 7, & 8 REVISE Attic Elevation tag to read: **ATTIC- T/PRECAST / 113'-11"**. REVISE ROOF SLAB Elevation tag to read: **ROOF SLAB / 128'-5"**.

SHEET AS601 EXTERIOR DETAILS

(NOT REISSUED)

- 2-15. At DETAILS 1, 4, & 7 REVISE Attic Elevation tag to read: **ATTIC- T/PRECAST / 113'-11"**.
2-16. At ALL DETAILS where Foamed Insulation Air Stop (INSUL-8) is noted, replace with : **INSUL- 3 , 6" long, set in compatible sealant. Seal entire brick cavity with Self Adhering Membrane. Fill all annular spaces as well as window frame with Insul. – 6.**

SHEET AS602 EXTERIOR DETAILS

(NOT REISSUED)

- 2-17. At ALL DETAILS where Foamed Insulation Air Stop (INSUL-8) is noted, replace with : **INSUL- 3 , 6" long, set in compatible sealant. Seal over entire brick cavity with Self Adhering Membrane.**

SHEET AS603 EXTERIOR DETAILS

(NOT REISSUED)

- 2-18. At DETAILS 7, 8, 10, 11, & 14, REVISE TOP OF DECK Elevation tag to read: **TOP OF DECK / 128'-5"**.
2-19. At DETAILS 7 & 8 TOP OF BLOCKING Elevation tag to read: **TOP OF BLOCKING / 130'-5"**.
2-20. At ALL DETAILS where Foamed Insulation Air Stop (INSUL-8) is noted, replace with : **INSUL- 3 , 6" long, set in compatible sealant. Seal over entire brick cavity with Self Adhering Membrane. . Fill all annular spaces as well as window frame with Insul. – 6.**

SHEET AS604 EXTERIOR DETAILS

(NOT REISSUED)

- 2-21. At DETAILS 1 & 4, REVISE Attic Elevation tag to read: **ATTIC- T/PRECAST / 113'-11"**.
2-22. At ALL DETAILS where Foamed Insulation Air Stop (INSUL-8) is noted replace with : **INSUL- 3 , 6" long, set in compatible sealant. Seal over entire brick cavity with Self Adhering Membrane. Fill all annular spaces as well as window frame with Insul. – 6.**

SHEET AS901 INTERIOR ELEVATIONS

(REISSUED)

- 2-23. Revise Casework Notes as shown.

A
D
D
E
N I
D T
U E
M M

DESCRIPTION

SHEET AS902 INTERIOR ELEVATIONS

(NOT REISSUED)

2-24. Revise Casework notes as shown on AS901 drawing.

SHEET AS921 INTERIOR DETAILS

(REISSUED)

2-25. Revise details as noted .

SHEET AS922 INTERIOR DETAILS

(NOT REISSUED)

2-26. At DETAILS 9,10,20,24, & 25 REVISE Attic Elevation tag to read: **ATTIC- T/PRECAST / 113'-11"**

STRUCTURAL

SHEET S8 FRAMING DETAILS

NOT REISSUED

2-27. Detail 2/S8 – Revise detail note to read: 8" CMU Wall, REINF. W/ #5 VERTS @ 40" OC. CENTERED IN CORES.

END OF AMENDMENT #2 - VA

(END OF ADDENDUM #2 – DESIGN TEAM)

P:\Support\Master Contracts\Templates\ADDENDUM_FORM.DOC



