

1 COVE LIGHT POWERED BY DC POWER ADAPTER. PROVIDE MAXIMUM LENGTH AND LINKABLE SECTIONS. MAXIMUM SEGMENT THAT IS LINKABLE AND POWERED BY ONE OUTLET IS 12 FEET. REFER TO POWER PLAN FOR RECEPTACLE LOCATIONS. (TYP FOR TYPES J1 AND J2).

- 2 EXTEND CIRCUIT DOWN TO TO 1ST FLOOR STAIR LIGHTING FIXTURES.
- 3 PROVIDE ELEC CIRCUIT CONNECTION TO PIT LIGHTING CIRCUIT AND TOGGLE SWITCH SHOWN IN THE ELEVATOR SHAFT, THIS PLAN. LOCATE FIXTURE AND TOGGLE SWITCH 48" AFF.
- 4 PROVIDE CONNECTION TO PHOTOCELL AT ROOF AND TIME CLOCK FOR PHOTCELL ON/TIME CLOCK OFF LIGHTING CONTROL OPERATION..
- 5 PROVIDE TIME CLOCK AND LIGHTING CONTACTOR.

L1 = 2NL1
LC1 = 2EL-C1
LS1 = 2EL-LS1

L2 = 2NL2
LC2 = 2EL-C2
LS2 = 2EL-LS2

PROJECT NORTH TRUE NORTH

VA FORM 08-6231