LIGHTING FIXTURE SCHEDULE

TYPE	QTY	DESCRIPTION	APPROVED EQUAL MFRS.	BASIS OF DESIGN MFR.	BASIS OF DESIGN MODEL	VOLTAGE	LAMPS	WATTS	Apparent Load	MOUNTING	COMMENTS
	742										
A2	5	2'x2' ARCHITECTURAL INDIRECT/DIRECT FLUORESCENT WITH METAL PERFORATED CHANNEL AND WHITE ENAMEL FINISH	DAY-BRITE, CORELITE	LITHONIA	2AV-G-214T5-MDR-MVOLT-GEB10PS	120	(2) 14W T5	32	32 VA	LAY-IN	
A3	96	2'x2' ARCHITECTURAL INDIRECT/DIRECT FLUORESCENT WITH METAL PERFORATED CHANNEL AND WHITE ENAMEL FINISH	DAY-BRITE, CORELITE	LITHONIA	2AV-G224T5HO-MDR-MVOLT-GEB10PS	120	(2) 24W T5HO	55	55 VA	LAY-IN	
A5	7	2'x2' ARCHITECTURAL LENSED FLUORESCENT TROFFER WITH 0.125" THICK #12 ACRYLIC LENS	DAY-BRITE, METALUX	LITHONIA	2SP5-G214T5-A12125-MVOLT-GEB10PS	120	(2) 14W T5	32	32 VA	LAY-IN	
A6	4	2'x2' ARCHITECTURAL LENSED FLUORESCENT TROFFER WITH 0.125" THICK #12 ACRYLIC LENS	DAY-BRITE, METALUX	LITHONIA	2SP-F-2U31-A12125-MVOLT-GEB10IS	120	(2) 31W U 1-5/8 T8	32	62 VA	LAY-IN	
A7	2	2'x4' ARCHITECTURAL INDIRECT/DIRECT FLUORESCENT WITH METAL PERFORATED CHANNEL AND WHITE POWDER COAT FINISH	DAY-BRITE, CORELITE	LITHONIA	2AVG328T5MDRMVOLTGEB10PS		(3) 28W T5	80	96 VA	LAY-IN	
A8	6	2'x2' ARCHITECTURAL INDIRECT/DIRECT FLUORESCENT WITH METAL PERFORATED CHANNEL AND WHITE ENAMEL FINISH	DAY-BRITE, CORELITE	LITHONIA	2AV-G324T5HO-MDR-MVOLT-GEB10PS	120	(3) 24W T5HO	55	83 VA	LAY-IN	
B	315	6" HORIZONTAL COMPACT FLUORESCENT DOWNLIGHT WITH WHITE BAFFLE AND CLEAR ALZAK REFLECTOR	HALO, LIGHTOLIER	GOTHAM	AF-1/26DTT-6WB-MVOLT	120	(1) 26W QT	29	29 VA	RECESSED	
B1	81	6" HORIZONTAL COMPACT FLUORESCENT DOWNLIGHT WITH CLEAR ALZAK REFLECTOR, PRISMATIC GLASS LENS, AND WHITE TRIM RING FINISH	HALO, GOTHAM	JUNO	CH6-226Q-650PL-WJ	120	(2) 26W QT	56	56 VA	RECESSED	
B2	52	6" HORIZONTAL COMPACT FLUORESCENT DOWNLIGHT WITH LOW IRIDESCENT CLEAR ALZAK REFLECTOR AND WHITE TRIM RING - DIMMING	HALO, GOTHAM	JUNO	CH6-126Q-600C-WWS-WH-DB120	120	(1) 26W QT	29	29 VA	RECESSED	PROVIDE REQUIRED FRAME-IN KITS NECESSARY FOR CEILING TYPES. PROVIDE 2700K COLOR TEMP LAMPS. PROVIDE DIMMING BALLAST COMPATIBLE WITH DIMMING SWITCH.
B3	24	6" HORIZONTAL COMPACT FLUORESCENT DOWNLIGHT - SHOWER DOWNLIGHT WITH PRISMATIC GLASS LENS AND WHITE TRIM RING	HALO, LIGHTOLIER	LITHONIA	LF6N1/18DTT6LS73MVOLT	120	(1) 18W DTT	21	21 VA	RECESSED	
D1	24	(2) 4' FLUORESCENT STRIP LIGHT SECTIONS FOR END TO END MOUNTING AT COVE. MODEL NUMBER LISTED IS FOR (1) 4' SECTION.	DAY-BRITE, METALUX	LITHONIA	C-1-32-MVOLT-GEB10IS-TILW	120	T-8	62	75 VA	SURFACE	PROVIDE (2) 4 FOOT FIXTURES BACK TO BACK FOR TYPICAL COVE LIGHT IN PATIENT ROOMS. REFER TO ARCH SHEETS FOR INSTALLATION.
F	48	24" VANITY FIXTURE WITH BLADE SILVER FINISH	ARCHITECT TO APPROVE	FORECAST	F351	120	(2) 24W T5HO	55	55 VA	SURFACE	
G	52	48" INDUSTRIAL STRIP LIGHT WITH WIREGUARD	DAY-BRITE, METALUX	LITHONIA	C-2-32-MVOLT-GEB10IS-WGCU NST	120	(2) 32W T8	59	60 VA	SURFACE	
H1	5	PENDANT MOUNTED DECORATIVE FLUORESCENT WITH MATTE METALLIC SILVER FINISH AND WHITE SANDBLASTED GLASS	ARCHITECT TO APPROVE	AMERICAN GLASS	80824-SU	120	(4) 24W BIAX	120	120 VA	SURFACE	
H2	2	PENDANT MOUNTED DECORATIVE POKER LIGHT WITH TIFFANY STYLE PAINTED FINISH.	ARCHITECT TO APPROVE	MEYDA	TIFFANY 82117	120	(4) 60W A-19	120	240 VA	PENDANT	
J1	3	LED COVE LIGHT.	ARCHITECT TO APPROVE	TRESCO	ELLI V: LED-AGLPR-X3500AL	120	LED	64	54 VA	SURFACE	PROVIDE MAXIMUM LENGTH TO FIT COVE AND INCLUDE 90 DEGREE CONNECTORS FROM END TO END. FIXTURE SHALL HAVE NO DARK SPOTS AT 90 DEG CORNERS. PROVIDE MFR'S DIMMER POWER SUPPLY.
J2	5	LED COVE LIGHT.	ARCHITECT TO APPROVE	TRESCO	ELLI V: LED-AGLPR-X3500AL	120	LED	64	47 VA	SURFACE	PROVIDE MAXIMUM LENGTH TO FIT COVE AND INCLUDE 90 DEGREE CONENCTORS FROM END TO END. FIXTURE SHALL HAVE NO DARK SPOTS AT 90 DEG CORNER. PROVIDE MFR'S DIMMER POWER SUPPLY.
N	48	PATIENT ROOM LED NIGHT LIGHT WITH WHITE LED COLOR AND PHOTOCELL CONTROL.	ARCHITECT TO APPROVE	ALKO	WG2V-1-120-SWH-PCC	120	(2) 2W LED	5	5 VA	SURFACE	MOUNT 18" AFF.
S	9	WALL MOUNTED STAIR FIXTURE WITH 2 LAMP DOWNLIGHTS, AND 1 LAMP UPLIGHT; COVERED WITH ACRYLIC LENSES AND WHITE FINISH.	LIGHTOLIER,	PEERLESS	LD6-412205-T8-4-R4-120-GEB10-SCT-LP830-C041-F1	120	(3) 32W T8	100	100 VA	SURFACE	REFER TO ARCH ELEVATIONS FOR MOUNTING HEIGHT.
T	8	PENDANT LTG FOR KITCHEN BAR WITH 5" APERTURE AND GLASS SHADES AND DIMMABLE BALLAST.	ARCHITECT TO APPROVE	LITHONIA	11536	120	(1) 13W	29	18 VA	SURFACE	
W	6	EMERGENCY LIGHTING UNIT, WHITE FINISH, COLD ROLLED STEEL HOUSING WITH (2) 12W MR16 LAMPS	LITHONIA	Cooper Industries, Inc.	ATLITE 12AC54		MR16		12 VA	SURFACE	120V, 12W
X1	26	SINGLE FACED BRUSHED ALUMINUM EXIT SIGN WITH DIRECTIONAL ARROWS AS INDICATED. BLACK TRIM.	MCPHILBEN, SURE-LITES	LITHONIA	LE-S-1-R-120/277	120	LED		5 VA	UNIVERSAL	
X2	21	DUAL FACED BRUSHED ALUMINUM EXIT SIGN WITH DIRECTIONAL ARROWS AS INDICATED. BLACK TRIM.	MCPHILBEN, SURE-LITES	LITHONIA	LE-S-2-R-120/277	120	LED		5 VA	UNIVERSAL	
Y	7	EXTERIOR BUILDING FACADE ENTRY/EXIT DOOR LUMINAIRE WITH DIE CAST ALUMINUM HOUSING AND CUTOFF OPTICS	ARCHITECT TO APPROVE	LITHONIA		120	(2) 43W TRT	93	93 VA	SURFACE	CAT NO: WST-2/42 TRT-MD-MVOLT. ARACHITECT TO PROVIDE FINISH.
Z	2	ELEVATOR PIT LIGHT, DIE CAST ALUMINUM WITH PRISMATIC GLASS LENS AND GUARD	DAY-BRITE, PHOENIX	STONCO	VWXL-32-HFL-1	120	(1) 32W TRT	36	35 VA	SURFACE	

NOTES:

1. FOR TYPE J1 AND J2, PROVIDE FIXTURE MFR'S SLIDE DIMMER SWITCH TO CONTROL ENTIRE COVE SYSTEM OF J1 AND J2 FIXTURES

BID DOCUMENTS

FULLY SPRINKLERED

Revisions:	Date

ARCHITECT:

C.C. HODGSON ARCHITECTURAL GROUP

DAVID E. HAMEL 18076 STATE OF MARYLAND REGISTERED PROFESSIONAL ENGINEER

ENGINEERS:

Westlake Reed Leskosky

1634 EYE ST, NW, STE 900
WASHINGTON, DC 20006

Drawing Title: ELECTRICAL SCHEDULES

Approved: Project Director

Project Title: RELOCATE DEMENTIA UNIT

Location: VAMC MARTINSBURG

Date: 08/06/2012 | Checked: GSL | Drawn: DRW

Project Number: VA PN 613-207

Building Number: 513

Drawing Number: E-601

Dwg. of --

Office of Construction and Facilities Management

Department of Veterans Affairs