

O:\2011\130-01\DWGS\SKE-02.dwg, 8/28/2012 8:51:10 AM, Wesley L. Stiles

PANELBOARD L2

RATINGS: 120/208V, 3PH, 4W + G
MOUNTING: SURFACE

BUS RATING: 100A

MAIN RATING: MLO

MIN. SHORT CIRCUIT RATING: 10000 AMPS

LOAD DESCRIPTION	BKR		CKT NO.		CKT NO.	BKR		LOAD DESCRIPTION
	P	AMP				AMP	P	
OVERHEAD DOOR	3	15	1	A	2	15	1	AIR DRYER (FUTURE)
			3	B	4	15	1	AIR DRYER (FUTURE)
			5	C	6	15	1	SUH1 ,2,3,4 (FUTURE)
RECEPTS - MAIN FLOOR	1	20	7	A	8	15	1	CARBON FILTER CF1
RECEPTS - MAIN FLOOR	1	20	9	B	10	15	1	RO1 CONTROL PANEL
RECEPTS - STORAGE	1	20	11	C	12	15	1	ROCP CONTROL PANEL
RECEPTS - STORAGE	1	20	13	A	14	15	1	STORAGE TANK ST1
RECEPTS - BOILER	1	20	15	B	16	15	1	CFP5
RECEPTS - BOILER PLATFORM	1	20	17	C	18	15	1	SPARE
RECEPTS - EXTERIOR	1	20	19	A	20	15	1	SPARE
*EXISTING OFFICE CIRCUIT	1	20	21	B	22	-	1	PROVISIONAL SPACE
*EXISTING OFFICE CIRCUIT	1	20	23	C	24	-	1	PROVISIONAL SPACE
*EXISTING OFFICE CIRCUIT	1	20	25	A	26	15	2	CCU1 (FUTURE)
*EXISTING OFFICE CIRCUIT	1	20	27	B	28			
AIR DRYER AD1	1	20	29	C	30	15	2	EB1
EX. AIR DRYER	1	20	31	A	32			(FUTURE)
ATC PANEL	1	20	33	B	34	15	3	OVERHEAD DOOR
VAV BOX (SPARE)	1	20	35	C	36			
SPARE	1	20	37	A	38			
SPARE	1	20	39	B	40	20	1	FUEL LEAK DETECTION
SPARE	1	20	41	C	42	20	1	FUEL LEAK DETECTION
PROVISIONAL SPACE	1	-	43	A	44	20	1	EMERGENCY GAS SHUTOFF
PROVISIONAL SPACE	1	-	45	B	46	20	1	DANGEROUS GAS DETECTION
PROVISIONAL SPACE	1	-	47	C	48	20	1	STEAM TRAP MONITORING
PROVISIONAL SPACE	1	-	49	A	50	20	1	BOILER CONTROL PANEL
PROVISIONAL SPACE	1	-	51	B	52	15	1	EX. STEAM UNIT HEATER
PROVISIONAL SPACE	1	-	53	C	54	-	1	PROVISIONAL SPACE
PROVISIONAL SPACE	1	-	55	A	56	-	1	PROVISIONAL SPACE
PROVISIONAL SPACE	1	-	57	B	58	-	1	PROVISIONAL SPACE
PROVISIONAL SPACE	1	-	59	C	60	-	1	PROVISIONAL SPACE

COMMENTS: * EXTEND EXISTING OFFICE LIGHTING AND RECEPTACLE CIRCUITS TO PANEL L2 AS REQUIRED

SHEET NO.
SKE-2

BOILER PLANT UPGRADE
PHASE IV
VAMC MARTINSBURG, VA
PANEL SCHEDULE REVISIONS
REFERENCES DRAWING 320-E601

PROJECT No.
2011130.01

DATE
08-28-12

SCALE
NO SCALE

DESIGNED BY
WLS

DWN. BY
WLS

CKD. BY
BGB

Barton Associates
Consulting Engineers

Susquehanna Commerce Center
North Building
221 West Philadelphia Street
York, PA 17401

Tel.: (614) 237-2180
Web: www.ba-inc.com



We Make Buildings Work

YORK | HARRISBURG | STATE COLLEGE

Copyright © 2012 Barton Associates, Inc.