

**SECTION 08 71 00
DOOR HARDWARE**

PART 1 - GENERAL**1.1 DESCRIPTION**

- A. Door hardware and related items necessary for complete installation and operation of doors.

1.2 RELATED WORK

- A. Caulking: Section 07 92 00 JOINT SEALANTS.
- B. Application of Hardware: also see Section 08 11 13, HOLLOW METAL FRAMES, Section 08 14 00, INTERIOR WOOD DOORS.
- C. Door Schedule: Refer to Drawing sheet AE-611, DOOR FRAME SCHEDULE AND DETAILS
- C. Finishes: Refer to Drawing Sheet IN-601, FINISH SCHEDULE.
- D. Painting: Section 09 91 00, PAINTING.
- E. Card Readers: Section 28 13 11, PHYSICAL ACCESS CONTROL SYSTEMS.

1.3 GENERAL

- A. All hardware shall comply with UFAS, (Uniform Federal Accessible Standards) unless specified otherwise.
- B. Hardware for Labeled Fire Doors and Exit Doors: Conform to requirements of NFPA 80 for labeled fire doors and to NFPA 101 for exit doors, as well as to other requirements specified. Provide hardware listed by UL, except where heavier materials, large size, or better grades are specified herein under paragraph HARDWARE SETS. In lieu of UL labeling and listing, test reports from a nationally recognized testing agency may be submitted showing that hardware has been tested in accordance with UL test methods and that it conforms to NFPA requirements.
- C. Deadlocks specified for psychiatric area doors are not required to have "UL" label.
- D. Hardware for application on metal and wood doors and frames shall be made to standard templates. Furnish templates to the fabricator of these items in sufficient time so as not to delay the construction.
- E. The following items shall be of the same manufacturer, if possible, except as otherwise specified:
 - 1. Mortise locksets.
 - 2. Hinges for wood doors.
 - 3. Surface applied overhead door closers.
 - 4. Exit devices.
 - 5. Floor closers.

AMENDMENT #3 - 09/10/2012**1.4 SUBMITTALS**

- A. Submit in accordance with Section 01 33 23, SHOP DRAWINGS, PRODUCT DATA AND SAMPLES.
- B. Hardware Schedule: Prepare and submit hardware schedule in the following form:

Hardware Item	Quantity	Size	Reference Publication Type No.	Finish	Mfr. Name and Catalog No.	Key Control Symbols	UL Mark (if fire rated and listed)	ANSI/BHMA Finish Designation

- C. Samples and Manufacturers' Literature:
1. Samples: All hardware items (proposed for the project) that have not been previously approved by Builders Hardware Manufacturers Association shall be submitted for approval. Tag and mark all items with manufacturer's name, catalog number and project number.
 2. Samples are not required for hardware listed in the specifications by manufacturer's catalog number, if the contractor proposes to use the manufacturer's product specified.
- D. Certificate of Compliance and Test Reports: Submit certificates that hardware conforms to the requirements specified herein. Certificates shall be accompanied by copies of reports as referenced. The testing shall have been conducted either in the manufacturer's plant and certified by an independent testing laboratory or conducted in an independent laboratory, within four years of submittal of reports for approval.

1.5 DELIVERY AND MARKING

- A. Deliver items of hardware to job site in their original containers, complete with necessary appurtenances including screws, keys, and instructions. Tag one of each different item of hardware and deliver to Contracting Officer's Technical Representative for reference purposes. Tag shall identify items by Project Specification number and manufacturer's catalog number. These items shall remain on file in Contracting Officer's Technical Representative's office until all other similar items have been installed in project, at which time the

AMENDMENT #3 - 09/10/2012

Contracting Officer's Technical Representative will deliver items on file to Contractor for installation in predetermined locations on the project.

1.6 INSTRUCTIONS

- A. Hardware Set Symbols on Drawings: Except for protective plates, door stops, mutes, thresholds and the like specified herein, hardware requirements for each door are indicated on drawings by symbols. Symbols for hardware sets consist of letters "HW" followed by a number. Each number designates a set of hardware items applicable to a door type.
- B. Manufacturers' Catalog Number References: Where manufacturers' products are specified herein, products of other manufacturers which are considered equivalent to those specified may be used. Manufacturers whose products are specified are identified by abbreviations as follows:

CR	Corbin Russwin	Berlin, CT
MC	McKinney Hinge	Berlin, CT
NO	Norton Door Controls	Monroe, NC
PE	Pemko	Memphis, TN
RO	Rockwood Manufacturing	Rockwood, PA
RX	Rixson Specialty Door Controls	Carol Stream, IL
SN	Securitron MagnaLock Corp.	Phoenix, AZ

- C. Keying: All cylinders shall be keyed into existing Corbin Russwin HO Keyway Great Grand Master Key System. Provide removable core cylinders that are removable only with a special key or tool without disassembly of knob or lockset Cylinders shall be 6 pin type. Keying information shall be furnished at a later date by the Contracting Officer's Technical Representative.
1. Keying information will be furnished to the Contractor by the Contracting Officer's Technical Representative.
 2. Supply information regarding key control of cylinder locks to manufacturers of equipment having cylinder type locks. Notify Contracting Officer's Technical Representative immediately when and to whom keys or keying information is supplied. Return all such keys to the Contracting Officer's Technical Representative.

1.7 APPLICABLE PUBLICATIONS

- A. The publications listed below form a part of this specification to the extent referenced. The publications are referenced in the text by the basic designation only. In text, hardware items are referred to by series, types, etc., listed in such specifications and standards, except as otherwise specified.
- B. American Society for Testing and Materials (ASTM):
F883-04.....Padlocks
- C. American National Standards Institute/Builders Hardware Manufacturers Association (ANSI/BHMA):
A156.1-00.....Butts and Hinges
A156.2-03.....Bored and Pre-assembled Locks and Latches
A156.3-01.....Exit Devices
A156.4-00.....Door Controls (Closers)
A156.5-01.....Auxiliary Locks and Associated Products
A156.6-05.....Architectural Door Trim
A156.8-05.....Door Controls-Overhead Stops and Holders
A156.13-05.....Mortise Locks and Latches Series 1000
A156.15-06.....Release Devices-Closer Holder, Electromagnetic
and Electromechanical
A156.16-02.....American National Standard for Auxiliary
Hardware
A156.18-00.....Materials and Finishes
A156.21-06.....Thresholds
A156.22-05.....Door Gasketing and Edge Seal Systems
A156.23-04.....Electromagnetic Locks
A156.24-03.....Delayed Egress Locking Systems
A156.26-00.....Continuous Hinges
A156.31American National Standard for Electric Strikes
and Frame Mounted Actuators
A250.8-03.....Standard Steel Doors and Frames
- D. National Fire Protection Association (NFPA):
80-06.....Fire Doors and Fire Windows
101-05.....Life Safety Code
- E. Underwriters Laboratories, Inc. (UL):
Building Materials Directory (2007)

PART 2 - PRODUCTS

AMENDMENT #3 - 09/10/2012**2.1 BUTT HINGES**

- A. ANSI A156.1. The following types of butt hinges shall be used for the types of doors listed, except where otherwise specified:
1. Exterior Doors: Type A2112 for doors 900 mm (3 feet) wide or less and Type A2111 for doors over 900 mm (3 feet) wide. Hinges for exterior doors shall have non-removable pins.
 2. Interior Doors: Type 8112 for doors 900 mm (3 feet) wide or less and Type A8111 for doors over 900 mm (3 feet) wide.
 3. Automatic doors hung on butts, provide Type A2111 for exterior doors and aluminum doors, and Type A8111 for other doors.
 4. Any door installed in structural steel frames: Type A2412, A8412, A2411 or A8411 as applicable, except where otherwise specified. Such hinges shall be of same quality and weight as other hinges listed above for applicable door sizes.
 5. Labeled Wood Fire Doors: Type 8411 or Type 8412; these hinges shall be thru bolted to door with hex nuts and bolts.
- B. See Articles "MISCELLANEOUS HARDWARE" and "HARDWARE SETS" for pivots and hinges other than butts specified above and continuous hinges specified below.

2.2 CONTINUOUS HINGES

- A. ANSI/BHMA A156.26, Grade 1-150.
1. Listed under Category N in BHMA's "Certified Product Directory."
- B. General: Minimum 0.120-inch- (3.0-mm-) thick, hinge leaves with minimum overall width of 4 inches (102 mm); fabricated to full height of door and frame and to template screw locations; with components finished after milling and drilling are complete:
1. Fire Pins: Steel pins to hold labeled fire doors in place if required by tested listing.
- C. Continuous, Barrel-Type Hinges: Hinge with knuckles formed around a pin that extends entire length of hinge.
1. Base Metal for Exterior Hinges: Stainless steel.
 2. Base Metal for Interior Hinges: Aluminum.
 3. Base Metal for Hinges for Fire-Rated Assemblies: Steel
- D. Continuous, Gear-Type Hinges: Extruded-aluminum, pinless, geared hinge leaves; joined by a continuous extruded-aluminum channel cap; with concealed, self-lubricating thrust bearings.

2.3 DOOR CLOSING DEVICES

- A. Closing devices shall be products of one manufacturer for each type specified.

2.4 OVERHEAD CLOSERS

- A. Conform to ANSI A156.4, Grade 1.
- B. Closers shall conform to the following:
 - 1. The closer shall have 50 percent adjustable closing force over minimum value for that closer and have adjustable hydraulic back check effective between 60 degrees and 85 degrees of door opening.
 - 2. Where specified, closer shall have hold-open feature.
 - 3. Size Requirements: Size closers in accordance with manufacturer's recommendations or provide multi-size closers, sizes 1 through 6.
 - 4. Material of closer shall be forged or cast aluminum.
 - 5. Arm and brackets for closers shall be steel, malleable iron or high strength ductile cast iron.
 - 6. Closers shall have full size cover.
 - 7. Closers shall have adjustable hydraulic back-check and separate valves for closing and latching speed.

2.5 FLOOR CLOSERS AND FLOOR PIVOT SETS

- A. Comply with ANSI A156.4. Provide stainless steel floor plates for floor closers and floor pivots, except where metal thresholds occur. Provide cement cast for all floor closers. Floor closers specified for fire doors shall comply with Underwriters Laboratories, Inc., requirements for concealed type floor closers for classes of fire doors indicated on drawings. Hold-open mechanism, where required, shall engage when door is opened 105 degrees, except when door swing is limited by building construction or equipment, the hold-open feature shall engage when door is opened approximately 90 degrees. Floor closers shall have adjustable hydraulic back-check. Single acting floor closers shall also have built in dead stop. Pivots for non-labeled doors shall be cast, forged or extruded brass or bronze.
- B. Where floor closer appears in hardware set provide the following as applicable.
 - 1. Double Acting Floor Closers: Type C06012.
 - 2. Single Acting Floor Closer: Type C06021 (center pivoted).
(Intermediate pivot is not required).
 - 3. Single Acting Floor Closers: Type C06041 (offset pivoted).

AMENDMENT #3 - 09/10/2012

4. Single Acting Floor Closer for Labeled Fire Doors: Type C06051 (offset pivoted).
5. Single Acting Floor Closer For Lead Lined Doors: Type C06061 (center pivoted). (Intermediate pivot is not required).
6. Single Acting Floor Closers For Lead Lined Doors: Type C06071 (offset pivoted).

2.6 COMBINATION CLOSER - HOLDER

- A. Conform to ANSI A156.15; combination closer-holder with built-in electronic release.
- B. Combination closer-holder shall have the following features:
 1. Control door closing and latching sequence by hydraulic action.
 2. Wiring for 24V DC current. Current draw shall not exceed 0.16 amperes.
 3. Double level arm closing action, and adjustable hydraulic back-check.
 4. Spring power for closing force shall conform to ANSI A156.4 and have 50% spring power adjustment.
 5. Closer Size Requirements:
 - a. Doors, 900 mm (3 feet) and less in width: Size III closer.
 - b. Doors over 900 mm (3 feet) and less than 1050 mm (3 feet 6 inches) in width: Size IV closer.
 - c. Doors 1050 mm (3 feet 6 inches) and over in width: Size V closer.
 6. Hold open mechanism shall hold door open between 85 degrees and 180 degrees depending on wall and frame conditions. Mount device to provide maximum door opening permitted by building construction or equipment.
 7. Electronic release shall release door when signaled by smoke detector. Smoke detectors shall not be incorporated as an integral part of door holders. Smoke detectors are specified in the Section 28 31 00 FIRE ALARM SYSTEMS.
 8. All closers to have full covers.
 9. All closers shall have a 1 ½" piston and an adjustable back check position valve.

2.7 DOOR STOPS

- A. Conform to ANSI A156.16.
- B. Provide door stops wherever an opened door or any item of hardware thereon would strike a wall, column, equipment or other parts of

AMENDMENT #3 - 09/10/2012

building construction. For concrete, masonry or quarry tile construction, use lead expansion shields for mounting door stops.

- C. Where cylindrical locks with turn pieces or pushbuttons occur, equip wall bumpers Type L02251 (rubber pads having concave face) to receive turn piece or button.
- D. Substitute floor stops Type L02141 or L02161 as appropriate, when wall bumpers would not provide an effective door stop.
- E. Where drywall partitions occur, use floor stops, Type L02141 or L02161.
- F. Provide stop Type L02011 or L02181, as applicable for exterior doors.
- G. Omit stops where floor mounted door holders are required and where automatic operated doors occur.
- H. Provide appropriate roller bumper for each set of doors (except where closet doors occur) where two doors would interfere with each other in swinging.
- I. Provide appropriate door mounted stop on doors in individual toilets where floor or wall mounted stops cannot be used.
- J. Provide overhead surface applied stop Type C02541, ANSI A156.8 on patient toilet doors in bedrooms where toilet door could come in contact with the bedroom door.
- K. Provide door stops on doors where combination closer magnetic holders are specified.

2.8 OVERHEAD DOOR HOLDERS

- A. Conform to ANSI Standard A156.8. Overhead holders shall be of sizes recommended by holder manufacturer for each width of door. Set overhead holders for 110 degree opening, unless limited by building construction or equipment.

2.9 FLOOR DOOR HOLDERS

- A. Conform to ANSI Standard A156.16. Provide extension strikes for Types L01301 and L01311 holders where necessary.

2.10 LOCKS AND LATCHES

- A. Conform to ANSI A156.2. Locks and latches for doors 45 mm (1-3/4 inch) thick or over shall have beveled fronts. Lock cylinders shall have not less than six pins. Cylinders for all locksets shall be removable core type. Cylinder shall be removable by special key or tool. Construct all cores so that they will be interchangeable into the core housings of all mortise locks, rim locks, cylindrical locks, and any other type lock included in the Great Grand Master Key System. Disassembly of lever or lockset shall not be required to remove core from lockset. All

AMENDMENT #3 - 09/10/2012

locksets or latches on double doors with fire label shall have latch bolt with 19 mm (3/4 inch) throw. Provide temporary keying device or construction core of allow opening and closing during construction and prior to the installation of final cores.

- B. In addition to above requirements, locks and latches shall comply with following requirements:
1. Mortise Lock and Latch Sets: Conform to ANSI/BHMA A156.13. Mortise locksets shall be series 1000, minimum Grade 2. All locksets and latchsets, except on designated doors in Psychiatric (Mental Health) areas, shall have lever handles similar to Falcon S-lever Design. Lever handle shall be fabricated from wrought stainless steel. No substitute lever design or material shall be accepted. All locks and latchsets shall be furnished with curved lip strike and wrought box. Lock function F02 shall be furnished with key plates similar to Russwin's No. A70. All lock cases installed on lead lined doors shall be lead lined before applying final hardware finish. Furnish armored fronts for all mortise locks.
 2. Cylindrical Lock and Latch Sets: levers shall meet ADA (Americans with Disabilities Act) requirements. Cylindrical locksets shall be series 4000 Grade I. Knobs for series 4000 lock and latch sets shall have 57 mm (2-1/4 inch) diameters. Where two turn pieces are specified for lock F76, turn piece on inside knob shall lock and unlock inside knob, and turn piece on outside knob shall unlock outside knob when inside knob is in the locked position. (This function is intended to allow emergency entry into these rooms without an emergency key or any special tool.)
 3. Auxiliary locks shall be as specified under hardware sets and conform to ANSI A156.5.

2.11 PUSH-BUTTON COMBINATION LOCKS

- A. ANSI/BHMA A156.5, Grade 1. Mechanical or electrically operated as indicated.
- B. Construction: Heavy duty cylindrical lock housing conforming to ANSI/BHMA A156.2, Grade 1. Lever handles and operating components in compliance with the UFAS and the ADA Accessibility Guidelines.
- C. Special Features: Key override to permit a master keyed security system and a key activated passage feature to allow access without using the entry code.

2.12 ELECTROMAGNETIC LOCKS

- A. ANSI/BHMA A156.23; electrically powered, of strength and configuration indicated; with electromagnet attached to frame and armature plate attached to door. Listed under Category E in BHMA's "Certified Product Directory."
1. Type: Full exterior or full interior, as required by application indicated.
 2. Strength Ranking: 1500 lbf (6672 N).
 3. Inductive Kickback Peak Voltage: Not more than 53 OV.
 4. Residual Magnetism: Not more than 4 lbf (18 N) to separate door from magnet.
- B. Delayed-Egress Locks: BHMA A156.24. Listed under Category G in BHMA's "Certified Product Directory".
1. Means of Egress Doors: Lock releases within 15 seconds after applying a force not more than 15 lbf (67 N) for not more than 3 seconds, as required by NFPA 101.
 2. Security Grade: Activated from secure side of door by initiating device.
 3. Movement Grade: Activated by door movement as initiating device.

2.13 ELECTRIC STRIKES

- A. ANSI/ BHMA A156.31 Grade 1.
- B. General: Use fail-secure electric strikes with fire-rated devices.

2.14 KEYS

- A. Stamp all keys with change number and key set symbol. Furnish keys in quantities as follows:

Locks/Keys	Quantity
Cylinder locks	2 keys each
Cylinder lock change key blanks	100 each different key way
Master-keyed sets	6 keys each
Grand Master sets	6 keys each
Great Grand Master set	5 keys
Control key	1 key

2.15 ARMOR PLATES, COMBINATION KICK-MOP PLATES AND DOOR EDGING

- A. Conform to ANSI Standard A156.6.
- B. Provide protective plates as specified below:

AMENDMENT #3 - 09/10/2012

1. Kick-mop plates and armor plates plastic or metal, Type J100 series, color as required.
2. Provide kick-mop plates for both sides of each door, except where noted as not required. Kick-mop plates shall be 200 mm (8 inches) high. On push side of doors where jamb stop extends to floor, make combination kick-mop plates 38 mm (1-1/2 inches) less than width of door, except pairs of metal doors which shall have plates 25 mm (1 inch) less than width of each door. Extend all other combination kick-mop plates to within 6 mm (1/4 inch) of each edge of doors. Kick mop plates shall butt astragals. For jamb stop requirements, see specification sections pertaining to door frames.
3. Kick-mop plates are not required on following door sides:
 - a) Armor plate side of doors;
 - b) Exterior side of exterior doors;
 - c) Closet side of closet doors;
 - d) Storage side of doors to or from storage spaces; and
 - e) Both sides of aluminum entrance doors.
4. Armor plates for doors are listed under Article "Hardware Sets". Armor plates shall be 875 mm (35 inches) high and 38 mm (1-1/2 inches) less than width of doors, except on pairs of metal doors. Plates on pairs of metal doors shall be 25 mm (1 inch) less than width of each door. Where top of intermediate rail of door is less than 875 mm (35 inches) from door bottom, extend armor plates to within 13 mm (1/2 inch) of top rail. On doors equipped with panic devices, extend armor plates to within 13 mm (1/2 inch) of panic bolt cross bar.
5. Where louver or grille occurs in lower portion of doors, substitute stretcher plate and kick-mop plate in place of armor plate. Size of stretcher plate and kick-mop plate shall be 200 mm (8 inches) high.

2.16 EXIT DEVICES

- A. Conform to ANSI Standard A156.3. Exit devices shall be Grade 1; type and function are specified in hardware sets. Provide flush with finished floor strikes for vertical rod exit devices in interior of building. Trim shall have lever handles similar to locksets, unless otherwise specified.
- B. Exit devices for fire doors shall comply with Underwriters Laboratories, Inc., requirements for Fire Exit Hardware. Submit proof of compliance.

AMENDMENT #3 - 09/10/2012**2.17 FLUSH BOLTS (LEVER EXTENSION)**

- A. Conform to ANSI A156.16. Flush bolts shall be Type L24081 unless otherwise specified. Furnish proper dustproof strikes conforming to ANSI A156.16, for flush bolts required on lower part of doors. Modify flush bolts to fit stiles of aluminum doors on double-acting doors.
- B. Face plates for cylindrical strikes shall be rectangular and not less than 25 mm by 63 mm (1 inch by 2-1/2 inches).
- C. Friction-fit cylindrical dustproof strikes with circular face plate may be used only where metal thresholds occur.

2.18 FLUSH BOLTS (AUTOMATIC)

- A. Conform to ANSI A156.16. Dimension of flush bolts shall conform to ANSI A115. Bolts shall conform to Underwriters Laboratories, Inc., requirements for fire door hardware. Flush bolts shall automatically latch and unlatch. Furnish dustproof strikes conforming to ANSI A156.16 for bottom flushbolt. Face plates for dustproof strike shall be rectangular and not less than 38 mm by 90 mm (1-1/2 by 3-1/2 inches).

2.19 DOOR PULLS

- A. Conform to ANSI A156.6. Pull plate 90 mm by 350 mm (3-1/2 inches by 14 inches), unless otherwise specified. Cut plates of door pulls for cylinders, or turn pieces where required.

2.20 PUSH PLATES

- A. Conform to ANSI A156.6. Plastic, Type J302, 200 mm (8 inches) wide by 350 mm (14 inches) high. Provide plastic Type J300 plates 100 mm (4 inches wide by 350 mm (14 inches) high) where push plates are specified for doors with stiles less than 200 mm (8 inches) wide. Color shall be selected from manufacturer's standards. Cut plates for cylinders, and turn pieces where required.

2.21 COMBINATION PUSH AND PULL PLATES

- A. Conform to ANSI 156.6. Type J303, stainless steel 3 mm (1/8 inch) thick, 80 mm (3-1/3 inches) wide by 800 mm (16 inches) high), top and bottom edges shall be rounded. Secure plates to wood doors with 38 mm (1-1/2 inch) long No. 12 wood screws. Cut plates for turn pieces, and cylinders where required. Pull shall be mounted down.

2.22 COORDINATORS

- A. Conform to ANSI A156.16. Coordinators, when specified for fire doors, shall comply with Underwriters Laboratories, Inc., requirements for fire door hardware. Coordinator may be omitted on exterior pairs of doors where either door will close independently regardless of the

AMENDMENT #3 - 09/10/2012

position of the other door. Coordinator may be omitted on interior pairs of non-labeled open where open back strike is used. Open back strike shall not be used on labeled doors. Paint coordinators to match door frames, unless coordinators are plated.

2.23 THRESHOLDS

- A. Conform to ANSI A156.21, mill finish extruded aluminum, except as otherwise specified. In existing construction, thresholds shall be installed in a bed of sealant with machine screws and expansion shields. In new construction, embed aluminum anchors coated with epoxy in concrete to secure thresholds. Furnish thresholds for the full width of the openings.

2.24 AUTOMATIC DOOR BOTTOM SEAL AND RUBBER GASKET FOR LIGHT PROOF DOORS

- A. Conform to ANSI A156.22.

2.25 WEATHERSTRIPS (FOR EXTERIOR DOORS)

- A. Conform to ANSI A156.22. Air leakage shall not to exceed 0.50 CFM per foot of crack length ($0.000774\text{m}^3/\text{s/m}$).

2.26 MISCELLANEOUS HARDWARE

- A. Access Doors (including Sheet Metal, Screen and Woven Wire Mesh Types): Except for fire-rated doors and doors to Temperature Control Cabinets, equip each single or double metal access door with Lock Type E76213, conforming to ANSI A156.5. Key locks as directed. Ship lock prepaid to the door manufacturer. Hinges shall be provided by door manufacturer.
- B. Cylinders for Various Partitions and Doors: Key cylinders same as entrance doors of area in which partitions and door occur, except as otherwise specified. Provide cylinders to operate locking devices where specified for following partitions and doors:
 - 1. Folding doors and partitions.
 - 2. Wicket door (in roll-up door assemblies).
 - 3. Slide-up doors.
 - 4. Swing-up doors.
 - 5. Fire-rated access doors-Engineer's key set.
 - 6. Doors from corridor to electromagnetic shielded room.
 - 7. Day gate on vault door.
- C. Mutes: Conform to ANSI A156.16. Provide door mutes or door silencers Type L03011, of white or light gray color, on each steel door frame, except lead-lined frames and frames for sound-resistant, lightproof and electromagnetically shielded doors. Furnish 3 mutes for single doors and 2 mutes for each pair of doors, except double-acting doors. Provide

AMENDMENT #3 - 09/10/2012

4 mutes or silencers for frames for each Dutch type door. Provide 2 mutes for each edge of sliding door which would contact door frame.

2.27 PADLOCKS FOR VARIOUS DOORS, GATES AND HATCHES

- A. ASTM E883, size 50 mm (2 inch) wide chain; furnish extended shackles as required by job conditions. Provide padlocks, with key cylinders, for each door in following areas as noted.

2.28 FINISHES

- A. Exposed surfaces of hardware shall have ANSI A156.18, finishes as specified below. Finishes on all hinges, pivots, closers, thresholds, etc., shall be as specified below under "Miscellaneous Finishes." For field painting (final coat) of ferrous hardware, see Section 09 91 00, PAINTING.
- B. 626 or 630: All surfaces on exterior and interior of buildings, except where other finishes are specified.
- C. Miscellaneous Finishes:
1. Hinges-Interior Doors: 652.
 3. Pivots: Match door trim.
 4. Door Closers: Factory applied paint finish. Dull or Satin Aluminum color.
 5. Thresholds: Mill finish aluminum.
 6. Cover plates for floor hinges and pivots: 630.
 7. Other primed steel hardware: 652.
- D. Hardware Finishes for Existing Buildings: U.S. Standard finishes shall match finishes of hardware in (similar) existing spaces except where otherwise specified.
- E. Color of Plastic Items: Where colors other than chocolate brown or black are specified, color of core material may be different than color of face.
- F. Special Finish: Exposed surfaces of hardware for dark bronze anodized aluminum doors shall have oxidized oil rubbed bronze finish (dark bronze) finish on door closers shall closely match doors.

2.29 BASE METALS

- A. Apply specified U.S. Standard finishes on different base metals as following:

Finish	Base Metal
652	Steel
626	Brass or bronze

630

Stainless steel

PART 3 - EXECUTION**3.1 HARDWARE HEIGHTS**

- A. For existing buildings locate hardware on doors at heights to match existing hardware. The Contractor shall visit the site, verify location of existing hardware and submit locations to Contracting Officer's Technical Representative for approval.
- B. Hardware Heights from Finished Floor:
1. Exit devices centerline of strike (where applicable) 1000 mm (40-5/16 inches).
 2. Locksets and latch sets centerline of strike 1000 mm (40-5/16 inches).
 3. Deadlocks centerline of strike 1200 mm (48 inches).
 4. Hospital arm pull 1170 mm (46 inches) to centerline of bottom supporting bracket.
 5. Centerline of door pulls to be 1000 mm (40 inches).
 6. Push plates and push-pull shall be 1250 mm (50 inches) to top of plate.
 7. Push-pull latch to be 1000 mm (40-5/16 inches) to centerline of strike.
 8. Centerline of deadlock strike to be 840 mm (33 inches) when used with push-pull latch.
 9. Locate other hardware at standard commercial heights. Locate push and pull plates to prevent conflict with other hardware.

3.2 INSTALLATION

- A. Closer devices, including those with hold-open features, shall be equipped and mounted to provide maximum door opening permitted by building construction or equipment. Closers shall be mounted regular arm. Where closers are mounted on doors they shall be mounted with sex nuts and bolts; foot shall be fastened to frame with machine screws.
- B. Substitute parallel arm or top jamb mounting for regular arm mounting where the following conditions occur:
1. Where door swing, in full open position, would be limited to less than 90 degrees due to partition construction and closer location.
 2. Where door to room opens outward into corridor, except security bedroom, bathroom and anteroom doors which shall have closer installed parallel arm on exterior side of doors.

AMENDMENT #3 - 09/10/2012

3. Where exterior doors open outward.
4. On doors equipped with roller latch.

C. Hinge Size Requirements:

Door Thickness	Door Width	Hinge Height
45 mm (1-3/4 inch)	900 mm (3 feet) and less	113 mm (4-1/2 inches)
45 mm (1-3/4 inch)	Over 900 mm (3 feet) but not more than 1200 mm (4 feet)	125 mm (5 inches)
35 mm (1-3/8 inch) (hollow core wood doors)	Not over 1200 mm (4 feet)	113 mm (4-1/2 inches)

D. Hinge leaves shall be sufficiently wide to allow doors to swing clear of door frame trim.

E. Where new hinges are specified for new doors in existing frames or existing doors in new frames, sizes of new hinges shall match sizes of existing hinges; or, contractor may reuse existing hinges provided hinges are restored to satisfactory operating condition as approved by Contracting Officer's Technical Representative. Existing hinges shall not be reused on door openings having new doors and new frames. Coordinate preparation for hinge cut-outs and screw-hole locations on doors and frames.

F. Hinges Required Per Door:

Doors 1500 mm (5 ft) or less in height	2 butts
Doors over 1500 mm (5 ft) high and not over 2280 mm (7 ft 6 in) high	3 butts
Doors over 2280 mm (7 feet 6 inches) high	4 butts
Doors with spring hinges 1370 mm (4 feet 6 inches) high or less	2 butts
Doors with spring hinges over 1370 mm (4 feet 6 inches)	3 butts

G. Fastenings: Suitable size and type and shall harmonize with hardware as to material and finish. Provide machine screws and lead expansion shields to secure hardware to concrete, ceramic or quarry floor tile, or solid masonry. Fiber or rawl plugs and adhesives are not permitted. All fastenings exposed to weather shall be of nonferrous metal.

AMENDMENT #3 - 09/10/2012

H. After locks have been installed; show in presence of Contracting Officer's Technical Representative that keys operate their respective locks in accordance with keying requirements. (All keys, Master Key level and above shall be sent Registered Mail to the Medical Center Director along with the bitting list. Also a copy of the invoice shall be sent to the Contracting Officer's Technical Representative for his records.) Installation of locks which do not meet specified keying requirements shall be considered sufficient justification for rejection and replacement of all locks installed on project.

3.3 HARDWARE SETS

A. Following sets of hardware correspond to hardware symbols shown on drawings. Where hardware set for a single door is specified for a pair of doors; equip each leaf of such pair of doors with set noted. Only those hardware sets that are shown on drawings will be required. Disregard hardware sets listed in specifications but not shown on drawings.

AMENDMENT #3 - 09/10/2012

HW SET: 01

DOOR NUMBER:

BB494	BB495	BB497A	BB503	BB505	BB512
BB514B	BB527	BB552	BB553	BB567	BB588
BB613	BB615	BB616	BB617	BB618	BB620
BB491					

EACH TO HAVE:

2	EA	HINGE	TA2714 4 1/2 X 4 1/2 (ANSI/BHMA A8112)	26D	MC
1	EA	ELECTRIC HINGE	TA2714 4 1/2 X 4 1/2 QC8 (ANSI/BHMA A8112)	26D	MC
1	EA	ELECTRIFIED LOCKSET	ML20930 LSA (ANSI/BHMA F07)	630	CR
1	EA	CLOSER REG	7500 (ANSI/BHMA CO2021)	689	NO
1	EA	PROTECTION PLATES	K1050 10" X 34" 4BE CSK (ANSI/BHMA J101)	US32D	RO
1	EA	WALL BUMPER	407 (ANSI/BHMA LO2101)	US32D	RO
1	SET	SMOKE SEALS	S88 BL 17'		PE
1	EA	POWER SUPPLY	BPS-24-1		CR

NOTE: ACCESS CONTROL, CARD READERS, CARDS, ETC. TO BE SUPPLIED BY OTHERS.

HW SET: 02

DOOR NUMBER:

BB547	BB560C	BB560D	BB560E	BB590B	BB545
-------	--------	--------	--------	--------	-------

EACH TO HAVE:

2	EA	HINGE	TA2714 4 1/2 X 4 1/2 NRP (ANSI/BHMA A8112)	26D	MC
1	EA	ELECTRIC HINGE	TA2714 4 1/2 X 4 1/2 QC8 NRP (ANSI/BHMA A8112)	26D	MC
1	EA	ELECTRIFIED LOCKSET	ML20930 LSA (ANSI/BHMA F07)	630	CR
1	EA	CLOSER PA 180	7500 (ANSI/BHMA CO2021)	689	NO
1	EA	PROTECTION PLATES	K1050 10" X 34" 4BE CSK (ANSI/BHMA J101)	US32D	RO
1	EA	WALL BUMPER	407 (ANSI/BHMA LO 2101)	US32D	RO
1	SET	SMOKE SEALS	S88 BL 17'		PE
1	EA	POWER SUPPLY	BPS-24-1		CR

NOTE: ACCESS CONTROL, CARD READERS, CARDS, ETC. TO BE SUPPLIED BY OTHERS.

HW SET: 03

DOOR NUMBER:

BB453	BB561	BB563	BB565	BB569	
BB493					BB603B

EACH TO HAVE:

2	EA	HINGE	TA2714 4 1/2 X 4 1/2 (ANSI/BHMA A8112)	26D	MC
1	EA	ELECTRIC HINGE	TA2714 4 1/2 X 4 1/2 QC8 (ANSI/BHMA A8112)	26D	MC
1	EA	ELECTRIFIED LOCKSET	ML20930 LSA (ANSI/BHMA F07)	630	CR
1	EA	CLOSER REG	7500 (ANSI/BHMA CO2021)	689	NO
1	EA	CON OH STOP	1-336 (ANSI/BHMA CO 2511)	689	RX
1	EA	PROTECTION PLATES	K1050 10" X 34" 4BE CSK (ANSI/BHMA J101)	US32D	RO
1	SET	SMOKE SEALS	S88 BL 17'		PE
1	EA	POWER SUPPLY	BPS-24-1		CR

NOTE: ACCESS CONTROL, CARD READERS, CARDS, ETC. TO BE SUPPLIED BY OTHERS.

AMENDMENT #3 - 09/10/2012

HW SET: 04

DOOR NUMBER:

BB497B BB551 BB611 BB570

EACH TO HAVE:

2	EA	HINGE	TA2714 4 1/2 X 4 1/2 NRP (ANSI/BHMA A8112)	26D	MC
1	EA	ELECTRIC HINGE	TA2714 4 1/2 X 4 1/2 QC8 NRP (ANSI/BHMA A8112)	26D	MC
1	EA	ELECTRIFIED LOCKSET	ML20930 LSA (ANSI/BHMA F07)	630	CR
1	EA	CLOSER PA 180	7500 (ANSI/BHMA CO2021)	689	NO
1	EA	PROTECTION PLATES	K1050 10" X 34" 4BE CSK (ANSI/BHMA J101)	US32D	RO
1	EA	WALL BUMPER	407 (ANSI/BHMA LO 2101)	US32D	RO
1	EA	POWER SUPPLY	BPS-24-1		CR

NOTE: ACCESS CONTROL, CARD READERS, CARDS, ETC. TO BE SUPPLIED BY OTHERS.

HW SET: 05

DOOR NUMBER:

BB524A BB526A BB581C BB582C BB523A BB528A
BB581D

EACH TO HAVE:

2	EA	HVY HINGE	TA3386 4 1/2 X 4 1/2 (ANSI/BHMA A2111)	26D	MC
1	EA	ELECTRIC HINGE	TA3386 4 1/2 X 4 1/2 QC8 (ANSI/BHMA A8111)	26D	MC
1	EA	ELECTRIFIED LOCKSET	ML20930 LSA (ANSI/BHMA F07)	630	CR
1	EA	CLOSER REG	7500 (ANSI/BHMA CO 2021)	689	NO
1	EA	PROTECTION PLATES	K1050 10" X 34" 4BE CSK (ANSI/BHMA J101)	US32D	RO
1	EA	WALL BUMPER	407 (ANSI/BHMA LO 2101)	US32D	RO
1	EA	POWER SUPPLY	BPS-24-1		CR

NOTE: ACCESS CONTROL, CARD READERS, CARDS, ETC. TO BE SUPPLIED BY OTHERS.

HW SET: 06

DOOR NUMBER:

BB560B BB531C BB560A

EACH TO HAVE:

2	EA	HVY HINGE	TA3386 4 1/2 X 4 1/2 (ANSI/BHMA A2111)	26D	MC
1	EA	ELECTRIC HINGE	TA3386 4 1/2 X 4 1/2 QC8 (ANSI/BHMA A8111)	26D	MC
1	EA	ELECTRIFIED LOCKSET	ML20930 LSA (ANSI/BHMA F07)	630	CR
1	EA	CLOSER REG	7500 (ANSI/BHMA CO 2021)	689	NO
1	EA	PROTECTION PLATES	K1050 10" X 34" 4BE CSK (ANSI/BHMA J101)	US32D	RO
1	EA	WALL BUMPER	407 (ANSI/BHMA LO 2101)	US32D	RO
1	EA	POWER SUPPLY	BPS-24-1		CR
1	SET	SMOKE SEALS	S88 BL 17'		PE

NOTE: ACCESS CONTROL, CARD READERS, CARDS, ETC. TO BE SUPPLIED BY OTHERS.

AMENDMENT #3 - 09/10/2012

HW SET: 07

DOOR NUMBER:

BB533C BB511 BB604

EACH TO HAVE:

2	EA	HVY HINGE	TA3386 4 1/2 X 4 1/2 (ANSI/BHMA A2111)	26D	MC
1	EA	ELECTRIC HINGE	TA3386 4 1/2 X 4 1/2 QC8 (ANSI/BHMA A8111)	26D	MC
1	EA	ELECTRIFIED LOCKSET	ML20930 LSA (ANSI/BHMA F07)	630	CR
1	EA	CLOSER REG	7500 (ANSI/BHMA CO 2021)	689	NO
1	EA	CON OH STOP	1-336 (ANSI/BHMA CO 2511)	689	RX
1	EA	PROTECTION PLATES	K1050 10" X 34" 4BE CSK (ANSI/BHMA J101)	US32D	RO
1	SET	SMOKE SEALS	S88 BL 17'		PE
1	EA	POWER SUPPLY	BPS-24-1		CR

NOTE: ACCESS CONTROL, CARD READERS, CARDS, ETC. TO BE SUPPLIED BY OTHERS.

HW SET: 08

DOOR NUMBER:

BB537 BB612 BB614

EACH TO HAVE:

3	EA	HINGE	TA2714 4 1/2 X 4 1/2 (ANSI/BHMA A8112)	26D	MC
1	EA	PRIVACY SET	ML2030 LSA (ANSI/BHMA F19)	630	CR
1	EA	CLOSER REG/PA	7500 (ANSI/BHMA CO 2021)	689	NO
1	EA	PROTECTION PLATE	K1050 10" X 34" 4BE CSK (ANSI/BHMA J 101)	US32D	RO
1	EA	WALL BUMPER	409 (ANSI/BHMA LO 2251)	US32D	RO
1	SET	SMOKE SEALS	S88 BL 17'		PE

HW SET: 09

DOOR NUMBER:

BB453B BB532B **BB533B** **BB535B****BB531B BB602**

EACH TO HAVE:

3	EA	HINGE	TA2714 4 1/2 X 4 1/2 (ANSI/BHMA A8112)	26D	MC
1	EA	PRIVACY SET	ML2030 LSA (ANSI/BHMA F19)	630	CR
1	EA	PROTECTION PLATE	K1050 10" X 34" 4BE CSK (ANSI/BHMA J 101)	US32D	RO
1	EA	WALL BUMPER	409 (ANSI/BHMA LO 2251)	US32D	RO

HW SET: 10

DOOR NUMBER:

BB587 BB524B **BB526B** **BB528B**

EACH TO HAVE:

3	EA	HINGE	TA2714 4 1/2 X 4 1/2 (ANSI/BHMA A8112)	26D	MC
1	EA	PRIVACY SET	ML2030 LSA (ANSI/BHMA F19)	630	CR
1	EA	OVERHEAD STOP	10-336 (ANSI/BHMA CO 5442)	630	RX
1	EA	PROTECTION PLATE	K1050 10" X 34" 4BE CSK (ANSI/BHMA J 101)	US32D	RO

AMENDMENT #3 - 09/10/2012

HW SET: 11
DOOR NUMBER:
490T

EACH TO HAVE:

2	EA	HINGE	TA2714 4 1/2 X 4 1/2 NRP (ANSI/BHMA A8112)	26D	MC
1	EA	ELECTRIC HINGE	TA2714 4 1/2 X 4 1/2 QC8 (ANSI/BHMA A8112)	26D	MC
1	EA	FIRE EXIT DEVICE	ED5200A X N9905 (ANSI/BHMA F09)	630	CR
1	EA	CLOSER REG/PA	7500 (ANSI/BHMA CO2021)	689	NO
1	EA	PROTECTION PLATE	K1050 10" X 34" 4BE CSK (ANSI/BHMA J 101)	US32D	RO
1	EA	WALL BUMPER	407 (ANSI/BHMA LO 2101)	US32D	RO
1	EA	POWER SUPPLY	BPS-24-1		CR

NOTE: ACCESS CONTROL, CARD READERS, CARDS, ETC. TO BE SUPPLIED BY OTHERS.

HW SET: 12 – BI-PARTING BREAKAWAY
DOOR NUMBER:
BB600

NOTE: ALL HARDWARE SUPPLIED BY THE DOOR MANUFACTURER.

HW SET: 13
DOOR NUMBER:

BB582A BB583A BB601A BB605A BB581A

EACH TO HAVE:

2	EA	BOTTOM PIVOT	L147 3/4" OFFSET	626	RX
2	EA	TOP PIVOT	L180	626	RX
1	EA	ELECTRIFIED PIVOT	CSEM19 12-WIRE QC-12	626	RX
1	EA	SIDE PIVOT	M19	626	RX
2	EA	FLUSH BOLTS	555 (ANSI/BHMA LO 4251)	US26D	RO
1	EA	ELECTRIFIED LOCKSET	ML20930 LSA (ANSI/BHMA F07)	630	CR
1	EA	OVERHEAD STOP	10-436 (ANSI/BHMA CO5442)	689	RX
1	EA	PROTECTION PLATE	K1050 10" X 10" 4BE CSK (ANSI/BHMA J101)	US32D	RO
1	EA	POWER SUPPLY	BPS-24-1		CR
1	EA	DUST PROOF STRIKE	570 (ANSI/BHMA L 4021)	US26D	RO

NOTE: ACCESS CONTROL, CARD READERS, CARDS, ETC. TO BE SUPPLIED BY OTHERS.

HW SET: 14
DOOR NUMBER:
BB490 BB530

EACH TO HAVE:

4	EA	HVY HINGE	TA3786 4 1/2 X 4 1/2 (ANSI/BHMA A8111)	26D	MC
2	EA	ELECTRIC HINGE	TA3786 4 1/2 X 4 1/2 QC8 (ANSI/BHMA A8111)	26D	MC
2	EA	EL EXIT DEVICE	ED5400A X N955 M55 M94 (ANSI/BHMA A156.3)	630	CR
2	EA	POWER OPERATOR	5900 X-IN POWER OPERATOR	689	NO

AMENDMENT #3 - 09/10/2012

2	EA	CLOSER REG/PA	7500 (ANSI/BHMA CO 2021)	689	NO
2	EA	PROTECTION PLATE	K1050 10" X 34" 4BE CSK (ANSI/BHMA J 101)	US32D	RO
2	EA	WALL BUMPER	407 (ANSI/BHMA LO 2101)	US32D	RO
1	EA	POWER SUPPLY	BPS-24-2		CR
2	EA	DOOR SWITCH	661		NO
1	EA	EXIT MOTION SENSOR	XMS		SN
2	EA	ASTRAGAL	357 C 84"		PE
1	SET	SMOKE SEALS	S88 BL 25'		PE

HW SET: 15

DOOR NUMBER:

BB540

EACH TO HAVE:

4	EA	HVY HINGE	TA3786 4 1/2 X 4 1/2 (ANSI/BHMA A8111)	26D	MC
2	EA	ELECTRIC HINGE	TA37864 4 1/2 X 4 1/2 QC8 (ANSI/BHMA A8111)	26D	MC
2	EA	EL EXIT DEVICE	ED5400A X N955 M55 M94 (ANSI/BHMA A156.3)	630	CR
2	EA	POWER OPERATOR	5900 X-IN POWER OPERATOR	689	NO

2	EA	PROTECTION PLATE	K1050 10" X 34" 4BE CSK (ANSI/BHMA J 101)	US32D	RO
2	EA	WALL BUMPER	407 (ANSI/BHMA LO 2101)	US32D	RO
1	EA	POWER SUPPLY	BPS-24-2		CR
2	EA	DOOR SWITCH	661		NO
1	EA	EXIT MOTION SENSOR	XMS		SN
2	EA	ASTRAGAL	357 C 84"		PE
1	SET	SMOKE SEALS	S88 BL 25'		PE

HW SET: 16

DOOR NUMBER:

BB510 BB580

EACH TO HAVE:

4	EA	HVY HINGE	TA37864 4 1/2 X 4 1/2 (ANSI/BHMA A8111)	26D	MC
2	EA	ELECTRIC HINGE	TA37864 4 1/2 X 4 1/2 QC8 (ANSI/BHMA A8111)	26D	MC
2	EA	EL EXIT DEVICE	ED5400A X N955 M55 M94 (ANSI/BHMA A156.3)	630	CR
2	EA	POWER OPERATOR	5900 X-IN POWER OPERATOR	689	NO
2	EA	PROTECTION PLATE	K1050 10" X 46" 4BE CSK (ANSI/BHMA J101)	US32D	RO
2	EA	WALL BUMPER	407 (ANSI/BHMA LO 2101)	US32D	RO
1	EA	POWER SUPPLY	BPS-24-2		CR
2	EA	DOOR SWITCH	661		NO
1	EA	EXIT MOTION SENSOR	XMS		SN
1	SET	SMOKE SEALS	S88 BL 25'		PE
2	EA	WEATHERSTRIP	18041 CNB 84"		PE

HW SET: 17 - BI-PASS

DOOR NUMBER:

BB582D BB601B BB605B

AMENDMENT #3 - 09/10/2012

EACH TO HAVE:

6	EA	FLUSH PULL	94	US32D RO
1	EA	BI-PASS DOOR SET	HPB280A TRACK X HANGERS X FLOOR GUIDE	PE

HW SET: 18

DOOR NUMBER:

BB531A	BB533A	BB535A	BB541A	BB543A
BB514A				

EACH TO HAVE:

1	EA	BOTTOM PIVOT	L147 3/4" OFFSET	626	RX
1	EA	TOP PIVOT	L180	626	RX
1	EA	ELECTRIFIED PIVOT	CSEM19 12-WIRE QC-12	626	RX
1	EA	ELECTRIFIED LOCKSET	ML20930 LSA (ANSI/BHMA F07)	630	CR
1	EA	CLOSER REG/PA	7500 (ANSI/BHMA CO 2021)	689	NO
1	EA	PROTECTION PLATE	K1050 10" X 34" 4BE CSK (ANSI/BHMA J 101)	US32D	RO
1	EA	WALL BUMPER	409 (ANSI/BHMA LO 2251)	US32D	RO
1	EA	POWER SUPPLY	BPS-24-1		CR
1	SET	SMOKE SEALS	S88 BL 17'		PE

HW SET: 19

DOOR NUMBER:

BB531D	BB533D	BB535C	BB582B	BB583B	BB581B
BB543B	BB541B				

EACH TO HAVE:

1	EA	BOTTOM PIVOT	L147 3/4" OFFSET	626	RX
1	EA	TOP PIVOT	L180	626	RX
1	EA	SIDE PIVOT	M19	626	RX
1	EA	PASSAGE SET	ML2010 NSA (ANSI/BHMA CO 2021)	630	CR
1	EA	CLOSER REG/PA	7500 (ANSI/BHMA CO 2021)	689	NO
1	EA	PROTECTION PLATE	K1050 10" X 34" 4BE CSK (ANSI/BHMA J 101)	US32D	RO
1	EA	WALL BUMPER	409 (ANSI/BHMA LO 2251)	US32D	RO

HW SET: 20

DOOR NUMBER:

BB603A	BB521
--------	-------

EACH TO HAVE:

1	EA	ELECTRIC HINGE	TA2714 4 1/2 X 4 1/2 QC8 (ANSI/BHMA A8111)	26D	MC
2	EA	HINGE	TA2714 4 1/2 X 4 1/2 (ANSI/BHMA A8112)	26D	MC
1	EA	ELECTRIFIED LOCKSET	ML20930 LSA (ANSI/BHMA F07)	630	CR
1	EA	CLOSER REG/PA	7500 (ANSI/BHMA CO 2021)	689	NO
1	EA	CON OH STOP	1-336 (ANSI/BHMA CO 2511)	689	RX
1	EA	POWER SUPPLY	BPS-24-1		CR
1	EA	PROTECTION PLATE	K1050 10" X 34" 4BE CSK (ANSI/BHMA J 101)	US32D	RO

HW SET: 21

541-10-1003

LOUIS STOKES VAMC CLEVELAND

AMENDMENT #3 - 09/10/2012

DOOR NUMBER:

BB583C

EACH TO HAVE:

6	EA	HINGE	TA2714 4 1/2 X 4 1/2 (ANSI/BHMA A8112)	26D	MC
2	EA	SURFACE DUMMY	ML 2050 LSA	630	CR
2	EA	ROLLER CATCH	590 (ANSI/BHMA A156.16)	26D	RO
2	EA	OVERHEAD STOP	10-336 (ANSI/BHMA CO 5442)	630	RX
2	EA	PROTECTION PLATE	K1050 10" X 2" LTDW 4BE CSK	US32D	RO

- - - E N D - - -