

GENERAL NOTE:
 ALL EXISTING PIPING, DUCTWORK, SPRINKLERS, CONDUIT, LIGHTING OR OTHER CONSTRUCTION SHALL BE RELOCATED AS NECESSARY FOR ALL DEMOLITION AND INSTALLATION WORK.



**2ND FLOOR PLUMBING & FIRE PROTECTION DEMOLITION
 PLUMBING & FIRE PROTECTION**


GRAPHIC SCALE SUPERSEDES NUMERIC SCALE
 0 2' 4' 8'
 SCALE: 1/4" = 1'-0"

GENERAL NOTES

1. ALL EXISTING SPRINKLER HEADS, PIPES, ALARMS, ETC. ARE TO REMAIN INTACT FOR USE AFTER RENOVATION. SPRINKLER SYSTEM SHALL REMAIN IN OPERATION THROUGHOUT PERIOD OF WORK. MC SHALL ENSURE THAT NO DAMAGE IS DONE TO EXISTING SPRINKLER SYSTEM - I.E. PROTECTIVE CAGES SHALL BE INSTALLED OVER SPRINKLER HEADS DURING RENOVATION, ETC.

KEYNOTES

1. REMOVE EXISTING COLD WATER AND HOT WATER SERVICE TO SINK AND CAP WASTE LINE SHALL BE REMOVED TO NEAREST MAIN AND CAPPED FOR FUTURE USE WITH NEW SCRUB SINK. SEE SHEET PFP2.0 FOR INFORMATION.
2. EXISTING SPRINKLER HEAD TO BE RELOCATED. SEE SHEET PFP2.0 FOR INFORMATION.



KEY PLAN

RECORD DRAWINGS T-659

DATE	
REVISIONS	

DATE	05-21-12
MADE BY	JEM
CHECKED	HB
PLUMBING AND FIRE PROTECTION DEMOLITION	
DRAWING NO.	PFP1.0
SHEET NO.	80 PAGES