

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.

1. CONTRACT ID CODE

PAGE 1 OF PAGES 2

2. AMENDMENT/MODIFICATION NUMBER
0001

3. EFFECTIVE DATE

4. REQUISITION/PURCHASE REQ. NUMBER

5. PROJECT NUMBER (if applicable)
NA

605-19-3-6022-1026

6. ISSUED BY CODE

00262

7. ADMINISTERED BY (If other than Item 6)

CODE 00262

Department of Veterans Affairs
Network Contracting Office 22
4811 Airport Plaza Drive
Suite 600
Long Beach CA 90815Department of Veterans Affairs
Network Contracting Office 22
4811 Airport Plaza Drive
Suite 600
Long Beach CA 90815

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)

To all Offerors/Bidders

(X)

9A. AMENDMENT OF SOLICITATION NUMBER

36C26219Q1137

9B. DATED (SEE ITEM 11)

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED (SEE ITEM 13)

CODE

FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE

 A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b). C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: D. OTHER (Specify type of modification and authority)**E. IMPORTANT:** Contractor is not, is required to sign this document and return 0 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

THIS AMENDMENT IS ISSUED TO ADDRESS SUBMISSION OF QUESTIONS DURING THE SOLICITATION AND SITE WALK THRU. PLEASE REVIEW ATTACHMENT.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)

16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)

FREDY A ARTEAGA
CONTRACTING OFFICER

NCO2216L2-71331

15B. CONTRACTOR/OFFEROR

15C. DATE SIGNED

16B. UNITED STATES OF AMERICA

16C. DATE SIGNED

(Signature of person authorized to sign)

(Signature of Contracting Officer)

SOLICITATION #36C26219Q1137
QUESTIONS AND CLARIFICATIONS

1. Are there any floor plans?

Yes. They will be attached to amendment.

2. Are cable call outs available in the floor plans?

Yes.

3. Have locations been identified for monitoring?

No. Each of the 2 locations will have a monitoring location. A VA directive has been created to provide patient privacy and protection. Monitoring can no longer be available in common areas.

4. What color cable is being requested?

Orange

5. During the site walk the end user representative stated that the use of infectious control measures (including containment booths) will not be required for this project.

As the area is not occupied, infection control measures (carts, HEPA filters, etc) will NOT be required. Contractors are required to clean up after themselves.

6. Is there a preferred manufacturer for the horizontal cabling system and components?

Please see the cabling specifications dated June 2019, and specifically section 2.1-B

7. Can you Please clarify whether horizontal cabling, connectors, patch panels and patch cords should be Cat 6 rated or Cat 6a rated?

The Department of Veterans Affairs requires that ALL FUTURE CABLING be CAT6A, and the SOW should be amended to reflect that.

CLARIFICATIONS

- Loma Linda VA Medical Center confirms that cabling should be orange in color is the desired color for copper horizontal cables
- Loma Linda VA Medical Center confirms that cabling should be orange in color is the desired color for copper patch cables
- VA will not be providing switches
- Cameras are for patient monitoring by nurses. No recording or saving -is required. All video will be live feed
- The primary focus is to capture patient bed