

SOLICITATION # 36E77619B0013 PROJECT NAME: Roof Replacement Buildings 1,3, & 4 - Salisbury VA
TECHNICAL QUESTIONS AND VA RESPONSE TRACKING SHEET

ITEM NO.	DATE QUESTION RECEIVED	DATE QUESTION ANSWERED	QUESTION	GOVERNMENT RESPONSE
1.	8/28/19		Could the government provide an asbestos report?	N/A-no asbestos has been discovered in other on-going roofing projects on the campus
2.	8/28/19		With the size of the project, and the amount of coordination that will be needed, we do not feel 120 calendar days will be adequate. Could performance period be extended to 150 calendar days?	P.O.P to be increased to 150 calendar days
3.	8/28/19		In reference to the stainless steel flashings on the parapets, will we be able to extend our membrane over the substrate and demo the stainless steel flashing? If not, could the government provide a detail for the stainless steel flashing?	Existing flashing can be removed as required for a warranted re-roof project.
4.	8/28/19		Could the government provide the location of the lay down area we will be able to utilize during this project?	Will be determined.