



ATTACHMENT 04

Request for Information (RFI) Log

Part 1 of 1

2 pages

19 September 2019

San Diego, California VA Health Care System (664)

664-19-426

B171B SPS Sterilization Room Remediation

CONSTRUCTION



Request for Information (RFI) Log B171B SPS Sterilization Room Remediation Construction

18 September 2019

San Diego, California VA Health Care System (664)

RFI Number	Date	Question	Answer
001.	16 Sep 2019	Per detailed SOW issued with this solicitation, all walls and ceiling shall be demolished and rebuilt to match existing epoxy paint finishes as the main focus of this remediation project, please confirm.	Yes. Intent is to match existing epoxy paint finish.
002.	16 Sep 2019	It wasn't made clear during the job walk if the interstitial space directly above the affected project is asbestos free. If so, please state formally	The interstitial space above the project space is asbestos free.
003.	16 Sep 2019	The 20 – calendar day duration may not be enough to carry out all the project requirements. Please check if this can be extended to 30-45 days.	The period of performance will remain 20 days.