

## **RFI FORM**

**Contractor Name:** Sentinel Builders LLC

**Address:** 5945 S. Los Altos Pkwy Sparks NV 89436

**Phone/Fax:** 209-752-9213

**Send to:** timothy.saffles@va.gov

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>	640-20-906	<b>RFI NO.:</b>	2
<b>PROJECT NAME:</b>	Replace HVAC Equipment Bldg 8	<b>DATE REQUESTED:</b>	9-26-2019
<b>SOLICITATION NO.:</b>	36C26119Q0992	<b>REFERENCE:</b>	
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
Please be specific as possible: Are any of the compressors burned out?			
<b>PROJECT MANAGER'S RESPONSE</b>			
All of the compressors are running and operational.			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b>		<b>DATE:</b>	