

## **RFI FORM**

**Contractor Name:** Sentinel Builders LLC

**Address:** 5945 S. Los Altos Pkwy Sparks NV 89436

**Phone/Fax:** 209-752-9213

**Send to:** timothy.saffles@va.gov

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>	640-20-906	<b>RFI NO.:</b>	3
<b>PROJECT NAME:</b>	Replace HVAC Equipment Bldg 8	<b>DATE REQUESTED:</b>	9-26-2019
<b>SOLICITATION NO.:</b>	36C26119Q0992	<b>REFERENCE:</b>	General Requirements J.1
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
<p>Please be specific as possible:</p> <p>The General Requirements references maintaining temperature, is it anticipated that temporary heating or cooling will be required by the contractor, during the change out and repair of the condensers and TXV valves?</p>			
<b>PROJECT MANAGER'S RESPONSE</b>			
<p>The Fisher House is designed to house families of injured servicemen with spinal cord and ploy -trauma injuries. Their comfort while staying at the Fisher House is paramount. To mitigate the issue of discomfort for the families, temporary heating/cooling is required.</p>			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b>		<b>DATE:</b>	