

**RFI FORM**

**Contractor Name:** Acierto LLC  
**Address:** 2053 N. 2000 W. Farr West, Ut. 84404  
**Phone/Fax:** 801 917 0070  
**Send to:** timothy.saffles@va.gov

<b>RFI (REQUEST FOR INFORMATION)</b>			
<b>PROJECT NO.:</b>	640-20-904	<b>RFI NO.:</b>	001
<b>PROJECT NAME:</b>	New Air Compressor	<b>DATE REQUESTED:</b>	Sept 27,2019
<b>SOLICITATION NO.:</b>	36C26119Q1115	<b>REFERENCE:</b>	
<b>DRAWING:</b>		<b>SPECIFICATION SECTION:</b>	
<b>DESCRIPTION OF PROBLEM OR INFORMATION BEING REQUESTED</b>			
Please be specific as possible:  Replacement equipment is not specified. Please specify sizing and capacities for (1) Lab Air Compressor Lab Vac Pump and (2) HVAC Air Compressors.			
<b>PROJECT MANAGER'S RESPONSE</b>			
Control Air Compressors shall be replaced with like or equal to Powerex Scroll tank mounted air system, Model STD0504-3-4, 30.4 CFM@100 psig,10 HP total Lab Air: Powerex lab scroll air system, model LSD05A3-3-5-P,25 CFM@145 PSI Lab Vac: Powerex lab claw type system w/PBMI &auto purge,Model LCVD0203-3-P, 32 CFM @ 19 Hg, 4HP total(2 x 2 HP), 80 gallon tank,204 V,3 PH,60 HZ.			
<b>TRACKING NO.:</b>		<b>AMENDMENT NO.:</b>	
<b>VA PROJECT ENGINEER/MANAGER:</b>		<b>DATE:</b>	