

1. REFER TO G-002 - G-006 LIFE SAFETY PLANS FOR OVERALL FLOOR PLANS REGARDING ELECTRICAL ROOM LOCATIONS.
2. NEW & EXISTING CONDUIT SHOWN FOR VISUAL PURPOSES ONLY & DO NOT REFLECT ACTUAL OR FINAL LAYOUT .
3. ALL MECHANICAL EQUIPMENT, PANELS, AND CONDUITS SHOWN ARE BASED ON SITE OBSERVATIONS AND EXISTING DOCUMENTS. CONTRACTOR SHALL VERIFY IN A NON-DESTRUCTIVE MANNER ALL EXISTING CONDITIONS PRIOR TO CONSTRUCTION.
4. NOT ALL ITEMS ARE SHOWN ON THIS PLAN, INCLUDING CABLING AND CONDUITS. CONTRACTOR SHALL COORDINATE WITH ALL OTHER TRADES.
5. ALL OUTAGES TO BE COORDINATED WITH VA COR AND APPROVED IN WRITING BY VA, MEDICAL CENTER.
6. CONTRACTOR SHALL BE RESPONSIBLE FOR SCANNING ANY FLOOR OR ROOF PRIOR TO MAKING ANY DUCT, PIPE, OR CONDUIT PENETRATION. CONTRACTOR IS TO VERIFY THE PRESENCE OF EXISTING CONDUIT IN THE EXISTING SLAB PRIOR TO ANY WORK TAKING PLACE.
7. CONNECT NEW & EXISTING FIRE/SMOKE DETECTION SYSTEMS TO EXISTING FIRE ALARM SYSTEM WHERE REQUIRED.

— = EXISTING ELECTRICAL CONDUIT

— = DEMOLISH EXISTING ELECTRICAL CONDUIT

1 = INSTALL ELECTRICAL CONDUIT PIPE SUPPORTS PER DETAIL 14/M-201. SPACE PER MANUFACTURER'S INSTRUCTIONS

2 = ANCHOR CONDUIT TO MASONRY WALL BEHIND REFRIGERANT LINES



1 B-200 MECHANICAL ROOM FLOOR PLAN (SF-2 & 3) Scale: 1/4" = 1'0" NORTH



2 ROOF PLAN
Scale: 1/4" = 1'0"

[illegible]

Office of
Construction
and Facilities
Management

VA U.S. Department
of Veterans Affairs

Drawing Title SF-2 ELECTRICAL PROPOSED PLAN		Phase BID DOCUMENTS		Project Title BLDG 43 SF1 & SF2 HVAC REPLACEMENT		Project Number 695-19-137	
Approved: Project Director DLK		SPRINKLERED		Location BLDG 43 A & B WING PENTHOUSES		Building Number 43	
				Issue Date 10/2/19		Checked MSO	
				Drawn ASB			
						Drawing Number E-101	