

PATRIOT Construction, LLC



An 8(a), Service Disabled Veteran Owned Small Business (SDVOSB)

2 November 2012

Ms. Shari Kesecker
Department of Veterans Affairs
Medical Center
510 Butler Avenue
Martinsburg, WV 25405

Regarding: Y--Relocate Dementia Unit
Solicitation Number: VA24512B0113

Dear Ms. Kesecker,

Please find following questions/requests for information regarding the above referenced solicitation for response.

1. On drawing CS109A Bid Alternate #4 note indicates to see structural plans for details

- Provide structural details for the retaining wall included in Alternate 4. **NA. See revised CS109A, attached**
- Provide structural details for the pedestrian bridge included in Alternate 4
- Confirm 6' high fence with one gate including monitoring system per detail on LP104 is being installed at wall **The fence to be installed w/ Bid Alternate #4 is the 6' high metal fence on LP104.**

2. In specification section 090600 - Schedule of Finishes several of the detail charts are cut off. Please provide revised specification section. **See Amendment A00002 dated 11-05-2012**

3. Provide a profile for the 12" storm line that crosses the 2" and 4" dementia building water supply line. **The profile for the 12" storm line from structure 7 to structure 8 is indicated on CS109. The water service should deflect under the storm to provide adequate clearance.**

If you have any questions, please contact me directly at 443-546-7980.

Sincerely,

Rhonda Baumgartner
Project Manager
Patriot Construction, LLC.