

PLUMBING FIXTURE SCHEDULE

TAG	FIXTURE TYPE	WASTE	VENT	HW	CW	DESCRIPTION	BASIS OF DESIGN	
							MANUFACTURER	MODEL NO.
SK-1	STAINLESS STEEL SINGLE BOWL	1 1/2"	1 1/2"	1/2"	1/2"	STAINLESS STEEL COUNTERTOP LAY-IN 16" X 19" X 7.5" DEEP, FAUCET HOLES 4" CENTERS. FAUCET CHICAGO 895-317CP, ADM MIXING VALVE. GRID STRAINER	ELKAY	LR-2222
WHA-1	WATER HAMMER ARRESTER	-	-	-	-	STAINLESS STEEL SHOCK ARRESTOR, MAX 150 PSI, CONNECTION 1/2". LOCATE ON HOT AND COLD WATER SUPPLIES.	WATTS	SS SERIES

- SUPPLY (5) EXTRA BATTERIES.
- LAMINAR FLOW SPRAY HEAD

GENERAL NOTES:



- ALL PIPING SHOWN IS DIAGRAMMATIC ONLY, EXACT LOCATION TO BE DETERMINED IN FIELD.
- PROVIDE ACCESS TO ALL EQUIPMENT REQUIRING PERIODIC SERVICE AND MAINTENANCE.
- PIPING SHALL RUN CONCEALED IN ALL AREAS WITH THE EXCEPTION OF MECHANICAL ROOMS OR WHERE NO CEILING EXISTS.
- INSTALL DIELECTRIC COUPLINGS BETWEEN DISSIMILAR MATERIALS.
- FIRESTOP ALL FLOOR AND WALL PENETRATIONS TO MATCH RATING OF ASSEMBLY PENETRATED. REFER TO ARCHITECTURAL DRAWINGS FOR PARTITION RATINGS.
- ALL ITEMS THAT REQUIRE ACCESS, SUCH AS FOR OPERATING, CLEANING, SERVICING, MAINTENANCE, AND CALIBRATION, SHALL BE EASILY AND SAFELY ACCESSIBLE BY PERSONS STANDING AT FLOOR LEVEL, OR STANDING ON PERMANENT PLATFORMS, WITHOUT THE USE OF PORTABLE LADDERS. EXAMPLES OF THESE ITEMS INCLUDE, BUT NOT LIMITED TO: ALL TYPES OF VALVES, FILTERS AND STRAINERS, TRANSMITTERS, CONTROL DEVICES.
- CLEAN AND CERTIFY MEDICAL GAS PIPING BACK TO SHUT-OFF ISOLATION VALVE OR ZONE VALVE, NFPA-99, 5.3.12.3 SYSTEM VERIFICATION.
- COORDINATE SHUT OFF OF THE MEDICAL GAS SYSTEM WITH THE HOSPITAL STAFF.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL COSTS ASSOCIATED WITH FREEZING EXISTING PIPING LINES IF REQUIRED FOR NEW PIPING CONNECTIONS TO EXISTING PIPING LINES. VA PERSONNEL SHALL ATTEMPT TO MANUALLY CLOSE EXISTING SHUT-OFF VALVES UPSTREAM OF TIE-IN CONNECTIONS, BUT THERE IS NO CONTRACTURAL GUARANTEE THAT EXISTING SHUT-OFF VALVES WILL HOLD DUE TO AGE AND WEAR.

LEGEND

- COLD WATER PIPING (DCW)
- HOT WATER PIPING (DHW)
- SANITARY PIPING ABOVE GROUND
- VENT PIPING
- BALL VALVE
- CLEAN OUT
- POINT OF DISCONNECT
- POINT OF CONNECTION

ABBREVIATIONS LEGEND



- CO CLEAN OUT
- DCW DOMESTIC COLD WATER PIPING
- DIA DIAMETER
- DN DOWN
- DHW DOMESTIC HOT WATER PIPING
- DHWR DOMESTIC HOT WATER RETURN PIPING
- MAX MAXIMUM
- MIN MINIMUM
- SAN SANITARY PIPING
- ST STORM PIPING
- TYP TYPICAL
- V VENT PIPING



SUPPLY PIPING DETAIL TO LAVATORY OR SINK
SCALE: NONE

NOTES:

- DEAD LEGS ON DHW TO BE KEPT AS SHORT AS POSSIBLE. 6" OR LESS IS PREFERRED.
- DETAIL AS SHOWN IS FOR PREFERRED REVERSE-RETURN SYSTEM. IF CONVENTIONAL DIRECT RETURN SYSTEM IS USED, INCLUDE THIS FURTHER DETAIL AT POINT A:



WORK KEY PLAN
SCALE: NONE

100% DESIGN SUBMISSION

Revisions:	Date
100% SUBMISSION	05/13/11
95% SUBMISSION - REISSUED	06/04/10
95% SUBMISSION	02/12/10
60% SUBMISSION	07/17/09

CONSULTANTS:	

ARCHITECT/ENGINEERS:	
SAGE ENGINEERING ASSOCIATES, LLP 1211 WESTERN AVENUE ALBANY, NY 12203 (518)453-6091 FAX(518)453-6092	
SEA PROJECT NO. 2217	

Drawing Title	
PLUMBING PLAN PARTIAL C-WING 5TH FLOOR	
Approved: Project Director	

Project Title	
VISION CLINIC RENOVATIONS	
Location ALBANY, NEW YORK	
Date MAY 13, 2011	Checked DPL
Drawn EJG	

Project Number	
528A8-08-830	
Building Number 1	
Drawing Number	
P100	

STRATTON VA MEDICAL CENTER
Department of Veterans Affairs