9TH FLOOR PARTIAL PLAN - HVAC DUCTWORK PLAN

SCALE: 1/4" = 1'-0"

NORTH

GENERAL NOTES:

1. ALL VAV BOXES AND SUPPLY DIFFUSERS (SD-1) AND RETURN GRILLES (RG-1) INDICATED AS NEW ON THIS PLAN ARE RELOCATED AND RE-INSTALLED EXISTING EQUIPMENT. BALANCE RE-INSTALLED EQUIPMENT TO MATCH NEW AIRFLOW AND HOT WATER GPM TO VALUES INDICATED ON THE PLANS AND SCHEDULE.
2. MODIFY EXISTING DUCTWORK MAINS CAPPING ANY UN-USED TAPS AS NECESSARY.



KEY PLAN

Scale: As Noted

Revisions:	Date

CONSULTANTS:

LICENSED PROFESSIONAL ENGINEER SAMUEL J. COSAMANO NO. 085534 UNIVERSITY OF THE STATE OF NEW YORK

ARCHITECT/ENGINEERS:

dwyer ARCHITECTURAL

SYRACUSE
313 East Willow Street
Suite 107
Syracuse, NY 13203
ph: 315.299.7188

ROCHESTER
1344 University Avenue
Suite 140
Rochester, NY 14607
ph: 585.461.4771

IPD: Engineering
INTEGRATED PROJECT DELIVERY
ONE WEBSTER'S LANDING
SYRACUSE, NEW YORK 13202
315.423.0185

Drawing Title: 9th FLOOR HVAC DUCTWORK PLAN

Approved: Project Director

Project Title: RENOVATE FOR WOMEN'S CLINIC

Location: 800 IRVING AVENUE, SYRACUSE NY 13210

Date: 12.18.2012 | Checked: SBG | Drawn: NCB

Project Number: VA# 528A7-13-701 IPD# 11-7230

Building Number: 1

Drawing Number: M-101

Dwg. 29 of 41

VA HEALTHCARE NETWORK UPSTATE NEW YORK

VA FORM 08-6231