

9TH FLOOR PARTIAL PLAN - HVAC PIPING DEMOLITION

SCALE: 1/4" = 1'-0"

NORTH

KEYED NOTES:

1. REMOVE EXISTING VAV BOX AND ASSOCIATED PIPING BACK TO EXTENT SHOWN AND PREPARE REMAINING PIPING FOR CONNECTION TO NEW. VAV BOX AND ASSOCIATED VALVES TO BE CLEANED, FLUSHED AND PREPARED FOR RE-INSTALLAION.
2. REMOVE AND RECONDITION ALL RADIANT PANELS/ SUPPLY DIFFUSER. PANELS TO BE CLEANED AND FLUSHED. REMOVE EXISTING BRANCH PIPING AND PREPARE REMAINING PIPING FOR CONNECTION TO NEW.
3. REMOVE EXISTING TEMPERATURE SENSORS AND PULL WIRES ABOVE CEILING. SAVE ELEMENTS FOR REINSTALLATION INTO NEW WALL.



KEY PLAN

Scale: As Noted

Revisions:	Date

CONSULTANTS:

LICENSED PROFESSIONAL ENGINEER SAMUEL J. COSAMANO NO. 085524 STATE OF NEW YORK

ARCHITECT/ENGINEERS:

dwyer ARCHITECTURAL

SYRACUSE
313 East Willow Street
Suite 107
Syracuse, NY 13203
ph: 315.299.7188

ROCHESTER
1344 University Avenue
Suite 140
Rochester, NY 14607
ph: 585.461.4771

IPD: Engineering
INTEGRATED PROJECT DELIVERY
ONE WEBSTER'S LANDING
SYRACUSE, NEW YORK 13202
315.423.0185

Drawing Title: 9th FLOOR HVAC PIPING DEMOLITION PLAN

Approved: Project Director

Project Title: RENOVATE FOR WOMEN'S CLINIC

Location: 800 IRVING AVENUE, SYRACUSE NY 13210

Date	Checked	Drawn
12.18.2012	SBG	NCB

Project Number: VA# 528A7-13-701 IPD# 11-7230

Building Number: 1

Drawing Number: MD-102

Dwg. 28 of 41

VA HEALTHCARE NETWORK UPSTATE NEW YORK

VA FORM 08-6231