


# 9TH FLOOR PARTIAL PLAN - HVAC DUCTWORK DEMOLITION

SCALE: 1/4" = 1'-0"

NORTH

KEYED NOTES:

1. REMOVE EXISTING VAV BOX AND ASSOCIATED DUCTWORK BACK TO EXTENT SHOWN AND PREPARE REMAINING DUCTWORK FOR CONNECTION TO NEW. VAV BOX TO BE CLEANED, FLUSHED AND PREPARED FOR RE-INSTALLAION.
2. REMOVE AND RECONDITION ALL RADIANT PANELS/ SUPPLY DIFFUSER PANELS TO BE CLEANED AND FLUSHED. REMOVE EXISTING BRANCH DUCTWORK. PREPARE REMAINING DUCTWORK FOR CONNECTION TO NEW.
3. REMOVE AND RECONDITION EXISTING RETURN GRILLE. REMOVE ASSOCIATED DUCTWORK BACK TO EXTENT SHOWN AND PREPARE REMAINING DUCTWORK FOR CONNECTION TO NEW. GRILLE TO BE CLEANED AND PREPARED FOR REINSTALLATION.
4. EXISTING TAP MAY BE REUSED. IF NOT USED, REMOVE TAP, FLUSH AND SEAL OPENING.




KEY PLAN

Scale: As Noted

three inches = one foot
one and one half inches = one foot
one inch = one foot
three quarters inch = one foot
one half inch = one foot
three eighths inch = one foot
one quarter inch = one foot
one eighth inch = one foot

| Revisions: | Date |
|---|---|
| | |

CONSULTANTS:

FLORIDA PROFESSIONAL ENGINEER SAMUEL J. COSAMANO NO. 085524 STATE OF THE UNIVERSITY OF NEW YORK

ARCHITECT/ENGINEERS:

dwyer ARCHITECTURAL

SYRACUSE
313 East Willow Street
Suite 107
Syracuse, NY 13203
ph: 315.299.7188

ROCHESTER
1344 University Avenue
Suite 140
Rochester, NY 14607
ph: 585.461.4771

IPD: Engineering
INTEGRATED PROJECT DELIVERY
ONE WEBSTER'S LANDING
SYRACUSE, NEW YORK 13202
315.423.0185

| | |
|---|---|
| Drawing Title | 9th FLOOR HVAC DUCTWORK DEMOLITION PLAN |
| Approved: Project Director | |
| Project Title | RENOVATE FOR WOMEN'S CLINIC |
| Location | 800 IRVING AVENUE, SYRACUSE NY 13210 |
| Date | 12.18.2012 |
| Checked | SBG |
| Drawn | NCB |
| Project Number | VA# 528A7-13-701<br>IPD# 11-7230 |
| Building Number | 1 |
| Drawing Number | MD-101 |
| Dwg. 27 of 41 | |

VA HEALTHCARE NETWORK UPSTATE NEW YORK

VA FORM 08-6231