



AHU COOLING COIL CONNECTION
NOT TO SCALE



- NOTES:
1. SEE PLAN FOR PIPE SIZES.
 2. SEE VAV SCHEDULE FOR BALANCING VALVE GPM


TYPICAL VAV PIPING DETAIL
NOT TO SCALE




NOTE:

1. SECURE CURB CAP TO WOOD NAILING STRIP WITH 3/8" (10mm) CADMIUM PLATED LAG BOLTS NOT OVER 12" (300mm) ON CENTER.
2. SECURE ROOF CURB, DUCTWORK AND DAMPER TO ROOF WITH EXPANSION BOLTS (CONCRETE ROOF) OR RUST RESISTANT BOLTS (METAL DECK AND BAR JOIST ROOF).
3. RUN ELECTRICAL LINES THROUGH CLEARANCE HOLE PROVIDED IN GRAVITY DAMPER, THEN THROUGH VENTILATOR ELECTRICAL CONDUIT GUIDE.
4. COORDINATE INSTALLATION WITH OTHER TRADES.

POWER ROOF VENTILATOR DETAIL
NOT TO SCALE




DUCTWORK TRANSITIONS
(WITH EQUIPMENT MOUNTED IN DUCT)
SCALE: NONE



NOTES:

1. DELETE INSULATION STAND-OFF ON DUCTWORK WITHOUT EXTERIOR INSULATION.
2. DETAIL SHOWS SINGLE BLADE DAMPER. DAMPER INSTALLATION SHALL BE SIMILAR FOR MULTI-BLADE DAMPERS & ROUND DAMPERS.


VOLUME DAMPER DETAIL
SCALE: NONE



NOTE:


1. ALL VANE ELBOWS SHALL BE CONSTRUCTED AND INSTALLED AS DETAILED BY SMACNA.
2. WHEN W1 DOES NOT EQUAL W2, VANE SHALL BE SINGLE THICKNESS VANE TYPE REGARDLESS OF W DIMENSION.
3. ALL SINGLE THICKNESS VANES SHALL HAVE A 2" (50mm) RADIUS, 1 1/2" (40mm) MAXIMUM SPACE BETWEEN VANES AND A 3/4" (20mm) TRAILING EDGE.
4. WHEN W1 EQUALS W2 AND W1 IS GREATER THAN 20" (500mm) VANES SHALL BE DOUBLE VANE TYPE.

DUCTWORK SQUARE VANE ELBOWS
SCALE: NONE




| ABBREVIATIONS | |
|---------------|-----------------------------------|
| AFF | ABOVE FINISHED FLOOR |
| AHU | AIR HANDLING UNIT |
| AS | AIR SEPARATOR |
| B | BOLTER |
| CB | CHILLED BEAM |
| CFM | CUBIC FEET OF AIR PER MINUTE |
| CH | CHILLER |
| CHWR | CHILLED WATER RETURN |
| CHWS | CHILLED WATER SUPPLY |
| CUH | CABINET UNIT HEATER |
| CWR | CONDENSER WATER RETURN |
| CWS | CONDENSER WATER SUPPLY |
| EA | EXHAUST AIR |
| EAT | EXHAUST AIR TEMPERATURE |
| ECV | EXHAUST AIR CONSTANT VOLUME BOX |
| ET | EXPANSION TANK |
| ETW | ENTERING WATER TEMPERATURE |
| FCU | FAN COIL UNIT |
| FTT | FIN TUBE RADIATION |
| GPM | GALLONS PER MINUTE |
| HP | HEAT PUMP |
| HPC | HIGH PRESSURE CONDENSATE |
| HPS | HIGH PRESSURE STEAM |
| HWR | HOT WATER RETURN |
| HWS | HOT WATER SUPPLY |
| LPC | LOW PRESSURE CONDENSATE |
| LPS | LOW PRESSURE STEAM |
| LWT | LEAVING WATER TEMPERATURE |
| MAT | MIXED AIR TEMPERATURE |
| PC | PUMPED CONDENSATE |
| PD | PRESSURE DROP |
| PR | PERIMETER RADIATION |
| PTAC | PACKAGED TERMINAL AIR CONDITIONER |
| RA | RETURN AIR |
| ISI | SECONDARY |
| SAT | SUPPLY AIR TEMPERATURE |
| SCV | SUPPLY AIR CONSTANT VOLUME BOX |
| ITI | TERTIARY |
| VAV | VARIABLE AIR VOLUME BOX |
| VFD | VARIABLE FREQUENCY DRIVE |
| VST | VALVE STATION |
| WR | WALL MOUNTED RADIANT PANEL |

- GENERAL NOTES:
1. DRAWINGS ARE DIAGRAMMATIC AND INDICATE GENERAL ARRANGEMENT OF SYSTEMS AND WORK INCLUDED IN THE CONTRACT. IT IS NOT INTENDED TO SPECIFY OR SHOW EVERY OFFSET, FITTING OR COMPONENT. HOWEVER, CONTRACT DOCUMENTS REQUIRE COMPONENTS AND MATERIALS WHETHER OR NOT INDICATED OR SPECIFICALLY SPECIFIED TO MAKE THE SYSTEMS BEING INSTALLED COMPLETE, CODE COMPLIANT, TESTED AND OPERATIONAL.
 2. CONTRACTOR SHALL FIELD VERIFY ALL LOCATIONS, DIMENSIONS AND ELEVATIONS PRIOR TO CONSTRUCTION.
 3. ALL MATERIALS, EQUIPMENT, METHODS OF INSTALLATION, REMOVALS AND DISPOSAL SHALL BE IN ACCORDANCE WITH THE STANDARDS, REGULATIONS, CODES, ORDINANCES AND LAWS OF LOCAL, STATE, AND FEDERAL GOVERNMENTS, AND OTHER AUTHORITIES THAT HAVE LAWFUL JURISDICTION.
 4. PERFORM WORK, PROVIDE MATERIALS AND EQUIPMENT FOR SYSTEMS SHOWN, SPECIFIED AND DESCRIBED ON DRAWINGS. COMPLETELY COORDINATE ALL TRADES OF THIS CONTRACT AND PROVIDE COMPLETE AND FULLY FUNCTIONAL INSTALLATION. ALL WORK IN THIS SET TO BE COMPLETED UNDER THIS CONTRACT, UNLESS OTHERWISE INDICATED.
 5. PROTECT ALL EXISTING AND NEW BUILDING ELEMENTS FROM DAMAGE. CONTRACTOR SHALL RESTORE ALL DAMAGED ELEMENTS TO ORIGINAL OR BETTER CONDITION.
 6. WORK SHALL BE EXECUTED IN A WORKMANLIKE MANNER AND SHALL PRESENT NEAT, RECTILINEAR APPEARANCE WHEN COMPLETED. MAINTAIN MAXIMUM HEAD ROOM AT ALL TIMES. DO NOT RUN PIPES, DUCTS, AND CONDUIT EXPOSED UNLESS SHOWN AND NOTED TO BE EXPOSED ON DRAWINGS.
 7. MATERIALS AND EQUIPMENT SHALL BE NEW AND INSTALLED ACCORDING TO MANUFACTURER'S INSTRUCTIONS AND RECOMMENDATIONS. MAINTAIN MANUFACTURER'S EQUIPMENT CLEARANCES.
 8. CONTRACTOR IS RESPONSIBLE FOR ALL WORK RELATED TO ISOLATING, SHUTTING DOWN, DRAINING, FILLING AND TESTING SYSTEMS TO ALLOW FOR COMPLETION OF WORK. INTERRUPTIONS TO EXISTING SERVICES AND SYSTEMS SHALL BE AS SHORT AS POSSIBLE AND AT A TIME AND DURATION APPROVED BY THE OWNER AND UTILITY AS APPLICABLE. INCLUDE ALL PREMIUM TIME ASSOCIATED WITH INTERRUPTIONS. ALL SYSTEM INTERRUPTIONS SHALL BE SCHEDULED WITH OWNER, UTILITY AND COORDINATED WITH OTHER TRADE WORK.
 9. SEAL ALL PENETRATIONS THROUGH FIRE RATED WALLS, PARTITIONS AND FLOORS WITH UL RATED MATERIALS/METHODS EQUIVALENT TO FIRE RATING OF ASSEMBLY.
 10. PROVIDE PROPER ACCESS TO EQUIPMENT THAT REQUIRES INSPECTION, REPLACEMENT OR REPAIR. ACCESS PANELS/DOORS SHALL BE A MINIMUM OF 12"x12", UNLESS OTHERWISE NOTED.
 11. DO NOT SUPPORT EQUIPMENT FROM SUSPENDED CEILINGS. ALL SUPPORT SHALL BE FROM BUILDING STRUCTURE OR FROM CEILING SUSPENSION SYSTEM WHICH HAS BEEN REINFORCED. SUPPORTS SHALL BE SELECTED AND INSTALLED TO PROVIDE A VIBRATION FREE INSTALLATION.
 12. PRIOR TO CONSTRUCTION, ENLIST A CERTIFIED TESTING & BALANCING AGENCY TO DETERMINE BASELINE AIR AND WATER FLOW VALUES FOR EXISTING AIR HANDLING UNIT. 'AC-SO' PROVIDE A WRITTEN REPORT OF THE FINDINGS TO THE COR AND ENGINEER.
 13. DUCTWORK SHALL BE CONSTRUCTED AND INSTALLED IN ACCORDANCE WITH THE LATEST ISSUE OF SMACNA STANDARDS.
 14. THOROUGHLY CLEAN INSIDE OF ALL NEW AND EXISTING TO REMAIN DUCT SYSTEMS AND REPLACE FILTERS PRIOR TO TURNOVER/START-UP OF SYSTEM.
 15. PATCH, REPAIR AND PAINT ALL SURFACES LEFT EXPOSED BY THE REMOVAL OF EQUIPMENT, PIPING, SUPPORTS AND APPURTENANCES TO MATCH ADJACENT CONSTRUCTION AND FINISHES.
 16. THESE GENERAL NOTES APPLY TO ALL DRAWINGS WITHIN THIS TRADE.




BRANCH DUCTWORK DETAIL
SCALE: NONE



NOTES:

1. THE OPERATION OF VARIABLE AIR VOLUME TERMINAL BOX IS AFFECTED BY EXCESSIVE TURBULENCE ON THE ENTERING SIDE OF EACH TERMINAL BOX. THEREFORE, TERMINAL BOX MUST NOT BE INSTALLED TOO CLOSE TO MAIN DUCTS, ELBOWS AND FITTINGS.
2. WHEN MINIMUM UPSTREAM STRAIGHT DUCT CONNECTION TO TERMINALS AS INDICATED ABOVE CANNOT BE MAINTAINED, PROVIDE ORIFICE PLATE, STRAIGHTENING VANES OR OTHER DEVICE AS RECOMMENDED BY TERMINAL BOX MANUFACTURER AND SUBMIT TO ENGINEER FOR REVIEW PRIOR TO INSTALLATION.
3. DDC PANELS & MOTORS FOR NEW VAV TERMINAL BOXES SHALL BE PROVIDED BY CONTROLS MANUFACTURER AND SHALL BE DELIVERED TO VAV BOX MANUFACTURER. DDC PANEL SHALL CONTAIN STEP DOWN TRANSFORMER (120V AC TO 24V AC) TO POWER CONTROL & MOTOR. BOX MANUFACTURER SHALL FACTORY MOUNT DDC CONTROLLER & MOTOR ON LEFT OR RIGHT HAND SIDE OF VAV BOXES TO SUIT FIELD CONDITION. VAV BOX MANUFACTURER WILL PROVIDE ALL SENSORS & DAMPER WITH LINKAGES.
4. ARRANGE ACCESS TO PERMIT EASY FIELD BALANCE AND MAINTENANCE OF TERMINAL UNIT.


TYPICAL VAV BOX INSTALLATION
DETAIL
NOT TO SCALE



NOTE:

1. MINIMUM FLOW SHALL BE NO LESS THAN 0.5 GPM (1.9 LPM)

HYDRONIC RADIANT CEILING
PANELS - PIPING CONNECTIONS
SCALE: NONE



KEY PLAN

| | | | | | | | | | | | |
|--------------|--|----------------------|--|--------------------------------|--|-----------------------------|--|--------------------------------------|--|-----------------|--|
| CONSULTANTS: | | ARCHITECT/ENGINEERS: | | Drawing Title | | Project Title | | Project Number | | Building Number | |
| | | | | MECHANICAL GENERAL INFORMATION | | RENOVATE FOR WOMEN'S CLINIC | | VA# 528A7-13-701 | | IPD# 11-7230 | |
| | | | | Approved: Project Director | | Location | | 800 IRVING AVENUE, SYRACUSE NY 13210 | | Drawing Number | |
| | | | | | | Date | | Checked | | Drawn | |
| | | | | | | 12.18.2012 | | SBG | | NCB | |
| | | | | | | | | | | M-001 | |
| | | | | | | | | | | Dwg. 26 of 41 | |