



<u>BUILDING CODE STUDY DATA</u>		
<u>APPLICABLE CODES</u>		
FIRE/LIFE SAFETY:	NFPA 101 2009	
<u>BUILDING NO. 5</u>		
EXISTING USE GROUP:	E - EDUCATIONAL (DAY CARE)	
BUILDING IS RENOVATION AND ADDITION WITH CHANGE OF USE CLASS.		
EXISTING RENOVATED CONSTRUCTION - FIRST FLOOR:	4968 GSF	
EXISTING RENOVATED CONSTRUCTION - BASEMENT:	433 GSF	
NEW ADDITION CONSTRUCTION:	860 GSF	
TOTAL NEW AND RENOVATED CONSTRUCTION:	6261 GSF	
NEW USE GROUP:	NEW BUSINESS	
CONSTRUCTION TYPE:	TYPE V [000]	
FIRE PROTECTION SYSTEMS:		
	<u>EXISTING</u>	<u>NEW</u>
AUTOMATIC SPRINKLERS (FULLY SPRINKLERED)	YES	YES
PORTABLE FIRE EXTINGUISHERS	YES	YES
FIRE ALARM SYSTEM	YES	YES

NOTE: PROJECT SHALL NOT BE OCCUPIED DURING CONSTRUCTION

PROVIDED EXIT CAPACITY CALCULATIONS

6261 GSF = GROSS BUILDING AREA

BUSINESS OCCUPANCY = 1 OCCUPANT PER 100 SQ. FT.

EDUCATION (TRAINING) = 1 OCCUPANT PER 20 NET SQ. FT.

TOTAL OCCUPANCY PER NFPA = 103 OCCUPANT

MINIMUM REQUIRED NUMBER OF EXITS = 2

REQ'D EGRESS WIDTH PER OCCUPANT = 0.2 INCH PER OCCUPANT

MINIMUM EXIT WIDTH = 44" MIN

103 OCCUPANTS x 0.2" = 20.6"

PROVIDED EGRESS WIDTH AND NUMBER OF EXITS = 216" WIDTH, 5 EXITS

PROVIDED EGRESS WIDTH ALLOWS EXIT CAPACITY FOR 1080 OCCUPANTS

GENERAL LEGEND	← 86'	EGRESS PATH - TRAVEL DISTANCE
	← 44"/220	MEANS OF EGRESS [WIDTH IN INCHES / EXIT CAPACITY]
	◊	REINSTALL EXISTING FIRE ALARM SPEAKER
	✕	FIRE ALARM VISUAL DEVICE.
	■	FIRE ALARM MANUAL STATION.
	⊠	FIRE ALARM SPEAKER/HORN WITH VISUAL DEVICE.
	⊙	CEILING MOUNTED EXIT SIGN
	F.E.C.	FIRE EXTINGUISHER CABINET - RECESSED
	①	OCCUPANT LOAD
	⊗	SMOKE DETECTOR

FULLY SPRINKLERED  
CONTRACT DOCUMENTS SUBMISSION

<b>Additions:</b>     <b>Revisions:</b>     	<b>Date:</b>     	<b>Consultants</b> <b>BURDETTE KOEHLER MURPHY &amp; ASSOCIATES, INC.</b> MECHANICAL / ELECTRICAL CONSULTING ENGINEERING 1423 CLARKVIEW ROAD, SUITE 500 BALTIMORE, MARYLAND 21209 410.323.0600 - FAX 410.377.2543 <b>RICKERT ENGINEERING, INC.</b> STRUCTURAL ENGINEER 8813 WALTHAM WOODS RD. SUITE 310 BALTIMORE, MARYLAND 21234 410.663.5110 - FAX 410.663.5114	<b>BUILDING COST CONSULTANTS</b> COST ESTIMATING 12917 - 30TH AVENUE PLATTSMOUTH, NEBRASKA 68048 402.298.6260 - FAX 402.298.8290 <b>CENTURY ENGINEERING, INC.</b> CIVIL ENGINEER 10710 GILROY ROAD HUNT VALLEY, MARYLAND 21031 443.589.2400 - FAX 443.589.2401	<b>Seal:</b>     	<b>ARCHITECTURE PLANNING ENGINEERING</b> <b>POLT DESIGN GROUP</b> 1301 Enterprise Court, Suite 103-C Bel Air, Maryland 21014-1847 fax 410.803.2141 410.838.1603 www.polt-design.com	<b>Drawing Scale:</b>  <b>Drawing Start Date:</b>  <b>Drawing Finish Date:</b>  <b>Drawing Approved:</b>  <b>Drawing Title:</b> <b>LIFE SAFETY PLAN</b> <b>Approved: Associate Director for Operations:</b>  <b>Approved: Chief, Facilities Engineer:</b>  <b>Approved: Director, Medical Center:</b>  	<b>Project Title:</b> <b>BUILDING 5 RENOVATION</b> <b>Building No:</b> <b>5</b> <b>Checked:</b> <b>CAJ</b> <b>Drawn:</b> <b>BMH/BDA</b> <b>Location:</b> <b>VAMHCS MEDICAL CENTER WILMINGTON, DELAWARE</b>	<b>Date:</b> <b>6-15-2012</b> <b>Project No:</b> <b>460-13-111</b> <b>DRAWING NO:</b> <b>LS-1</b> <b>Dwg. 10 Of 67</b>	<b>DEPARTMENT OF VETERANS AFFAIRS</b>	