

VA Bath – Campus Wide Security Upgrade Phase II

VA Project #: 528A6-11-623

A|E works Project #: 11-011

Date: January 17, 2013Phase: BiddingRevision: 0

This Addendum and the attached responses to contractor RFI's shall all form a part of the Contract Documents and shall constitute the modifications to the original Contract Documents, which make-up Solicitation No. VA528-13-B-0060 for Project No. 528A6-11-623 as issued by the Department of Veterans Affairs, 76 Veterans Avenue Bath, NY dated 12/21/12. The contractors shall incorporate this Addendum as part of the original Project Manual and related drawings issued for the project, Acknowledge receipt of this Addendum in space provided in the appropriate Bid Form. Failure to do so may subject Bidder to disqualification.

PART I – CHANGES TO PROJECT SOLICITATION FORM

Modify the following sentence found in SF 1442 BLOCK 17 - Page 1 – “*A public bid opening will be held at 2:00 PM on January 22, 2013 in building 41, 3rd floor at the VA Medical Center, Bath, New York*” to read as:

A public bid opening will be held at 2:00 PM on January 25, 2013 in building 41, 3rd floor at the VA Medical Center, Bath, New York”.

Modify the following sentence found in SF 1442 BLOCK 17 - Page 1 – “*Please note, any reference to add alternates in the specifications or shown on drawings is not considered to be a part of this project*” to read as:

“Please note, any reference to add alternates in the specifications or shown on drawings is not considered to be a part of this project” (Alternates 4 through 10 as indicated on drawings ES-301 through ES-303)

Modify the following sentence found in SF 1442 BLOCK 17 - CLIN 1 “*Included shall be the installation of a fiber network to connect the individual security, video, and alarm components to the command and control security monitoring center*” to read as:

“Included shall be the connection to existing fiber network as indicated in order to support the operation of the individual security, video, and alarm components to the command and control security monitoring center”

VA Bath – Campus Wide Security Upgrade Phase II

VA Project #: 528A6-11-623

A|E works Project #: 11-011

Date: January 17, 2013Phase: BiddingRevision: 0**PART II – CHANGES TO PROJECT MANUAL**

Add the following article to specification 28 13 00, 2.11 “NETWORK ACCESS CONTROL SERVER (ACNS)” which shall read as follows;

- A. Provide network servers in sufficient quantities and properly sized in accordance with all manufacturers’ requirements to support all physical access control system functions and user data bases in conformance with all system performance requirements and shall include a 25% built-in expansion capability. At the minimum the network server shall meet the following requirements:

1. Intel Core II E8400 (6MB,3.0 GHz, 1333FSB) processor w/4GB SDRAM (Rack Mount)
2. Hard Drive:750GB 7200RPM, SATA 3.0Gb/s, 16MB Cache
3. One (1) 16x/10x/40x CD/DVD-Read/Write Drive
4. Two (2) - 10/100/1000 MB Ethernet ports
5. 128 MB SVGA card capable of displaying 1080p/1080i resolutions (64 bit true color)
6. 15” LCD Flat Panel Monitor (Rack Mount)(May be shared with video surveillance system)
7. Keyboard and Mouse (Rack Mount)(May be shared with video surveillance system)
8. Minimum Operating System: Windows XP (or newer)
9. All Required Manufacturers Software, Licenses and Software Keys

PART III – CHANGES TO PROJECT DRAWINGS

Provide the appropriate modifications to drawing 76-ES-02-101B as indicated on sketch SK-001. (Copy attached)

Provide the appropriate modifications to drawing ES301 as indicated on sketch SK-002. (Copy attached)

Provide the appropriate modifications to drawing 33-ES-B-02-101 as indicated on sketch SK-003. (Copy attached)

Provide the appropriate modifications to drawing ES-501 as indicated on sketch SK-004. (Copy attached)

Provide the appropriate modifications to drawing 76-ES-02-101A as indicated on sketch SK-005. (Copy attached)

VA Bath – Campus Wide Security Upgrade Phase II

VA Project #: 528A6-11-623

A|E works Project #: 11-011

Date: January 17, 2013

Phase: Bidding

Revision: 0

Provide the appropriate modifications to drawing ES-302 as indicated on sketch SK-006.
(Copy attached)

Provide the appropriate modifications to drawing 76-ES-01-101B as indicated on sketch SK-007. (Copy attached)

End of Project Addendum

Respectfully Submitted,

Scott Kraynak, PE

A|E Works Project Manager

Cc: Participants (Email)

File